

CONSULTING SERVICE REPORT

Client: Serco Middle East
 Project: Rihan Heights, Abu Dhabi
 Sampling Location: Rihan Heights, Abu Dhabi Date: 06-01-2022
 Sampling Point: Swimming Pool Sampled By: Crystalline Representative

SWIMMING POOL WATER ANALYSIS

PARAMETER	CONTROL LIMITS	MAIN POOL	STATUS
pH	7.2 - 7.6	7.43	SATISFACTORY
TDS, ppm	Max 1000	720	SATISFACTORY
'P' Alkalinity, ppm as CaCO ₃	70 - 100	80	SATISFACTORY
Calcium Hardness, ppm as CaCO ₃	100 - 500	150	SATISFACTORY
Treatment Residuals			
Dipslide	<10 ³	ND	SATISFACTORY
Free Chlorine as Cl, mg/l	1.0 - 2.0	1.4	SATISFACTORY
Bromine, mg/l	2.0 - 4.0	--	N/A
Cyanuric Acid	20 - 60	38	SATISFACTORY

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

RECOMMENDATION:


1. All tested parameters are found to be satisfactory.

SUMMARY:

The water analysis shows that the chlorine levels are lower than control limits.

"Certified that the Water Analysis Results has been tested * in accordance with the Standard Method, APHA-AWWA-WPCF,"

Reported By:


 Murugaraaj
 Service Engineer

END OF REPORT