

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-25-R-722
Attention Person	Mr. Jasman Pinto	Sample No	ACE-25-S-722
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	13/01/2025
		Sample Certificate No	1280
Sample Description	Water	Sampling Date / Time	10/01/2025 / 10.15 am
Sampling Point	Tower A P3 ETS Room Chilled Water	Sample Received Date / Time/ Temp °C	10/01/2025 3.30 pm/4°C
Sample Location	Rihan Heights Abu Dhabi	Date(s) Tested	10-12/01/25
Source of Sample	Chiller Line	Sampling Method	ACE-MB-SOP-11
Onsite Treatment/Preservation of Sample	4°C	Sample Collected By	ACE Rep
Sample Container	1 × 500ml PB	Sample Onsite Temperature °C	11°C
Client Reference	Not Applicable	Sample Appearance	Clear

MICROBIOLOGICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
Heterotrophic Plate Count	APHA 9215B (24 th Edition) 2023	CFU/ml	10000	72
Total Coliform	APHA 9222B (24 th Edition) 2023	CFU/100ml	-	Zero
Faecal Coliform	APHA 9222D (24 th Edition) 2023	CFU/100ml	-	Zero
<i>Escherichia coli</i>	APHA 9222I (24 th Edition) 2023	CFU/100ml	-	Zero
<i>Pseudomonas aeruginosa</i>	ISO: 16266/2006	CFU/100ml	-	Zero
<i>Enterococci</i>	BS EN/ISO: 7899-2:2000	CFU/100ml	-	Zero
Remarks	The sample meets DM water systems quality 2022 specifications for cooling water system (DM-HSD-GU44-LCWS2: 2022) with respect to the above tests only.			
Test Method Variation	None			
Keywords	Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, HSD: Health and Safety Department, LCWS: Legionella Control in Water System, NP: Not provided			
Test Performed By (Emp ID)			07	
Report Prepared By (Emp ID)			08	
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC


For, Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-25-R-725
Attention Person	Mr. Jasman Pinto	Sample No	ACE-25-S-725
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	13/01/2025
		Sample Certificate No	1280
Sample Description	Water	Sampling Date / Time	10/01/2025 / 10.45 am
Sampling Point	Tower B P3 ETS Room Chilled Water	Sample Received Date / Time/ Temp °C	10/01/2025 3.30 pm/4°C
Sample Location	Rihan Heights Abu Dhabi	Date(s) Tested	10-12/01/25
Source of Sample	Chiller Line	Sampling Method	ACE-MB-SOP-11
Onsite Treatment/Preservation of Sample	4°C	Sample Collected By	ACE Rep
Sample Container	1× 500ml PB	Sample Onsite Temperature °C	8.4°C
Client Reference	Not Applicable	Sample Appearance	Clear

MICROBIOLOGICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
Heterotrophic Plate Count	APHA 9215B (24 th Edition) 2023	CFU/ml	10000	69
Total Coliform	APHA 9222B (24 th Edition) 2023	CFU/100ml	-	Zero
Faecal Coliform	APHA 9222D (24 th Edition) 2023	CFU/100ml	-	Zero
<i>Escherichia coli</i>	APHA 9222I (24 th Edition) 2023	CFU/100ml	-	Zero
<i>Pseudomonas aeruginosa</i>	ISO: 16266/2006	CFU/100ml	-	Zero
<i>Enterococci</i>	BS EN/ISO: 7899-2:2000	CFU/100ml	-	Zero
Remarks	The sample meets DM water systems quality 2022 specifications for cooling water system (DM-HSD-GU44-LCWS2: 2022) with respect to the above tests only.			
Test Method Variation	None			
Keywords	Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, HSD: Health and Safety Department, LCWS: Legionella Control in Water System, NP: Not provided			
Test Performed By (Emp ID)			07	
Report Prepared By (Emp ID)			08	
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC



Prabakaran Ganesan M.Phil., Ph.D.

Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-01 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-25-R-726
Attention Person	Mr. Jasman Pinto	Sample No	ACE-25-S-726
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	13/01/2025
		Sample Certificate No	1280
Sample Description	Water	Sampling Date / Time	10/01/2025 / 10.50 am
Sampling Point	Tower C P3 ETS Room Chilled Water	Sample Received Date / Time/ Temp °C	10/01/2025 3.30 pm/4°C
Sample Location	Rihan Heights Abu Dhabi	Date(s) Tested	10-12/01/25
Source of Sample	Chiller Line	Sampling Method	ACE-MB-SOP-11
Onsite Treatment/Preservation of Sample	4°C	Sample Collected By	ACE Rep
Sample Container	1 × 500ml PB	Sample Onsite Temperature °C	10.4°C
Client Reference	Not Applicable	Sample Appearance	Clear

MICROBIOLOGICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
Heterotrophic Plate Count	APHA 9215B (24 th Edition) 2023	CFU/ml	10000	95
Total Coliform	APHA 9222B (24 th Edition) 2023	CFU/100ml	-	Zero
Faecal Coliform	APHA 9222D (24 th Edition) 2023	CFU/100ml	-	Zero
<i>Escherichia coli</i>	APHA 9222I (24 th Edition) 2023	CFU/100ml	-	Zero
<i>Pseudomonas aeruginosa</i>	ISO: 16266/2006	CFU/100ml	-	Zero
<i>Enterococci</i>	BS EN/ISO: 7899-2:2000	CFU/100ml	-	Zero
Remarks	The sample meets DM water systems quality 2022 specifications for cooling water system (DM-HSD-GU44-LCWS2: 2022) with respect to the above tests only.			
Test Method Variation	None			
Keywords	Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, HSD: Health and Safety Department, LCWS: Legionella Control in Water System, NP: Not provided			
Test Performed By (Emp ID)			07	
Report Prepared By (Emp ID)			08	
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC



Prabakaran Ganesan M.Phil., Ph.D.

Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-25-R-727
Attention Person	Mr. Jasman Pinto	Sample No	ACE-25-S-727
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	13/01/2025
		Sample Certificate No	1280
Sample Description	Water	Sampling Date / Time	10/01/2025 / 11.00 am
Sampling Point	Tower D P3 ETS Room Chilled Water	Sample Received Date / Time/ Temp °C	10/01/2025 3.30 pm/4°C
Sample Location	Rihan Heights Abu Dhabi	Date(s) Tested	10-12/01/25
Source of Sample	Chiller Line	Sampling Method	ACE-MB-SOP-11
Onsite Treatment/Preservation of Sample	4°C	Sample Collected By	ACE Rep
Sample Container	1 × 500ml PB	Sample Onsite Temperature °C	9.6°C
Client Reference	Not Applicable	Sample Appearance	Clear

MICROBIOLOGICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
Heterotrophic Plate Count	APHA 9215B (24 th Edition) 2023	CFU/ml	10000	74
Total Coliform	APHA 9222B (24 th Edition) 2023	CFU/100ml	-	Zero
Faecal Coliform	APHA 9222D (24 th Edition) 2023	CFU/100ml	-	Zero
<i>Escherichia coli</i>	APHA 9222I (24 th Edition) 2023	CFU/100ml	-	Zero
<i>Pseudomonas aeruginosa</i>	ISO: 16266/2006	CFU/100ml	-	Zero
<i>Enterococci</i>	BS EN/ISO: 7899-2:2000	CFU/100ml	-	Zero
Remarks	The sample meets DM water systems quality 2022 specifications for cooling water system (DM-HSD-GU44-LCWS2: 2022) with respect to the above tests only.			
Test Method Variation	None			
Keywords	Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, HSD: Health and Safety Department, LCWS: Legionella Control in Water System, NP: Not provided			
Test Performed By (Emp ID)			07	
Report Prepared By (Emp ID)			08	
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC



For, Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-25-R-728
Attention Person	Mr. Jasman Pinto	Sample No	ACE-25-S-728
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	13/01/2025
		Sample Certificate No	1280
Sample Description	Water	Sampling Date / Time	10/01/2025 / 11.05 am
Sampling Point	Tower E P3 ETS Room Chilled Water	Sample Received Date / Time/ Temp °C	10/01/2025 3.30 pm/4°C
Sample Location	Rihan Heights Abu Dhabi	Date(s) Tested	10-12/01/25
Source of Sample	Chiller Line	Sampling Method	ACE-MB-SOP-11
Onsite Treatment/Preservation of Sample	4°C	Sample Collected By	ACE Rep
Sample Container	1 × 500ml PB	Sample Onsite Temperature °C	10°C
Client Reference	Not Applicable	Sample Appearance	Clear

MICROBIOLOGICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
Heterotrophic Plate Count	APHA 9215B (24 th Edition) 2023	CFU/ml	10000	81
Total Coliform	APHA 9222B (24 th Edition) 2023	CFU/100ml	-	Zero
Faecal Coliform	APHA 9222D (24 th Edition) 2023	CFU/100ml	-	Zero
<i>Escherichia coli</i>	APHA 9222I (24 th Edition) 2023	CFU/100ml	-	Zero
<i>Pseudomonas aeruginosa</i>	ISO: 16266/2006	CFU/100ml	-	Zero
<i>Enterococci</i>	BS EN/ISO: 7899-2:2000	CFU/100ml	-	Zero
Remarks	The sample meets DM water systems quality 2022 specifications for cooling water system (DM-HSD-GU44-LCWS2: 2022) with respect to the above tests only.			
Test Method Variation	None			
Keywords	Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, HSD: Health and Safety Department, LCWS: Legionella Control in Water System, NP: Not provided			
Test Performed By (Emp ID)			07	
Report Prepared By (Emp ID)			08	
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC

For, 
Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-01 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-25-R-750
Attention Person	Mr. Jasman Pinto	Sample No	ACE-25-S-750
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	12.01.2025
		Sample Certificate No	1280
Sample Description	Chilled Water	Sampling Date / Time	10.01.2025/10.15am
Sampling Point	Tower A P3 ETS Room Chilled Water	Sample Received Date / Time/ Temp °C	10.01.2025/ 3.30 pm/ 4 °C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	10.01.2025-11.01.2025
Source of Sample	Chiller Line	Sampling Method	ACE-CH-SOP-39
Onsite Treatment/Preservation of Sample	NA	Sample Collected By	ACE Rep
Sample Container	1×500ml PB	Sample Onsite Temperature °C	11°C
Client Reference	NA	Sample Appearance	Clear

CHEMICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
pH @ 25°C	APHA 4500-H ⁺ B, (24 th Edition)2023	-	Min 8.5-Max 10.5	10.66**
Conductivity @ 25°C	APHA 2510 B, (24 th Edition)2023	µS/cm	Max 2250	465
Total Dissolved Solids dried at 180°C*	APHA 2540 C, (24 th Edition)2023	mg/L	Max 1500	301
Nitrite as NaNO ₂	HACH Method 8153, 01/2014 (Edition 9)	mg/L	Min 800-Max 1100	37**
Iron as Fe ²⁺ *	HACH Method 8146, 08/2019 (Edition 11)	mg/L	Max 1	0.06
Remarks	**The sample does not meet contractual specifications with respect to the above tests only. *Non-Accredited Parameters			
Test Method Variation	None			

Sample No: ACE-25-S-750
Report No : ACE-25-R-750

Date Received : 10.01.2025
Date Reported : 12.01.2025

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, NA: Not Applicable, NP: Not Provided
Test Performed By (Emp ID)	05
Report Prepared By (Emp ID)	08
The above test results are only applicable to the sample(s) referred above.	

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC


For, Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-25-R-753
Attention Person	Mr. Jasman Pinto	Sample No	ACE-25-S-753
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	12.01.2025
		Sample Certificate No	1280
Sample Description	Chilled Water	Sampling Date / Time	10.01.2025/10.45am
Sampling Point	Tower B P3 ETS Room Chilled Water	Sample Received Date / Time/ Temp °C	10.01.2025/ 3.30 pm/ 4 °C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	10.01.2025-11.01.2025
Source of Sample	Chiller Line	Sampling Method	ACE-CH-SOP-39
Onsite Treatment/Preservation of Sample	NA	Sample Collected By	ACE Rep
Sample Container	1×500ml PB	Sample Onsite Temperature °C	8.4°C
Client Reference	NA	Sample Appearance	Clear

CHEMICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
pH @ 25°C	APHA 4500-H ⁺ B, (24 th Edition)2023	-	Min 8.5-Max 10.5	9.93
Conductivity @ 25°C	APHA 2510 B, (24 th Edition)2023	μS/cm	Max 2250	870
Total Dissolved Solids dried at 180°C*	APHA 2540 C, (24 th Edition)2023	mg/L	Max 1500	566
Nitrite as NaNO ₂	HACH Method 8153, 01/2014 (Edition 9)	mg/L	Min 800-Max 1100	250**
Iron as Fe ²⁺ *	HACH Method 8146, 08/2019 (Edition 11)	mg/L	Max 1	0.08
Remarks	**The sample does not meet contractual specifications with respect to the above tests only. *Non-Accredited Parameters			
Test Method Variation	None			

Sample No: ACE-25-S-753
Report No : ACE-25-R-753

Date Received : 10.01.2025
Date Reported : 12.01.2025

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, NA: Not Applicable, NP: Not Provided
Test Performed By (Emp ID)	05
Report Prepared By (Emp ID)	08
The above test results are only applicable to the sample(s) referred above.	

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC



For, Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-25-R-754
Attention Person	Mr. Jasman Pinto	Sample No	ACE-25-S-754
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	12.01.2025
		Sample Certificate No	1280
Sample Description	Chilled Water	Sampling Date / Time	10.01.2025/10.50am
Sampling Point	Tower C P3 ETS Room Chilled Water	Sample Received Date / Time/ Temp °C	10.01.2025/ 3.30 pm/ 4 °C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	10.01.2025-11.01.2025
Source of Sample	Chiller Line	Sampling Method	ACE-CH-SOP-39
Onsite Treatment/Preservation of Sample	NA	Sample Collected By	ACE Rep
Sample Container	1×500ml PB	Sample Onsite Temperature °C	10.4°C
Client Reference	NA	Sample Appearance	Clear

CHEMICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
pH @ 25°C	APHA 4500-H ⁺ B, (24 th Edition)2023	-	Min 8.5-Max 10.5	11.02**
Conductivity @ 25°C	APHA 2510 B, (24 th Edition)2023	µS/cm	Max 2250	2930**
Total Dissolved Solids dried at 180°C*	APHA 2540 C, (24 th Edition)2023	mg/L	Max 1500	1906**
Nitrite as NaNO ₂	HACH Method 8153, 01/2014 (Edition 9)	mg/L	Min 800-Max 1100	845
Iron as Fe ²⁺ *	HACH Method 8146, 08/2019 (Edition 11)	mg/L	Max 1	0.06
Remarks	**The sample does not meet contractual specifications with respect to the above tests only. *Non-Accredited Parameters			
Test Method Variation	None			

Sample No: ACE-25-S-754
Report No : ACE-25-R-754

Date Received : 10.01.2025
Date Reported : 12.01.2025

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, NA: Not Applicable, NP: Not Provided
Test Performed By (Emp ID)	05
Report Prepared By (Emp ID)	08
The above test results are only applicable to the sample(s) referred above.	

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC



For, **Prabakaran Ganesan M.Phil., Ph.D.**
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-25-R-755
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-755
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	12.01.2025
		Sample Certificate No	1280
Sample Description	Chilled Water	Sampling Date / Time	10.01.2025/11.00am
Sampling Point	Tower D P3 ETS Room Chilled Water	Sample Received Date / Time/ Temp °C	10.01.2025/ 3.30 pm/ 4 °C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	10.01.2025-11.01.2025
Source of Sample	Chiller Line	Sampling Method	ACE-CH-SOP-39
Onsite Treatment/Preservation of Sample	NA	Sample Collected By	ACE Rep
Sample Container	1×500ml PB	Sample Onsite Temperature °C	9.6°C
Client Reference	NA	Sample Appearance	Clear

CHEMICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
pH @ 25°C	APHA 4500-H ⁺ B, (24 th Edition)2023	-	Min 8.5-Max 10.5	9.86
Conductivity @ 25°C	APHA 2510 B, (24 th Edition)2023	µS/cm	Max 2250	845
Total Dissolved Solids dried at 180°C*	APHA 2540 C, (24 th Edition)2023	mg/L	Max 1500	550
Nitrite as NaNO ₂	HACH Method 8153, 01/2014 (Edition 9)	mg/L	Min 800-Max 1100	225**
Iron as Fe ²⁺ **	HACH Method 8146, 08/2019 (Edition 11)	mg/L	Max 1	0.04
Remarks	**The sample does not meet contractual specifications with respect to the above tests only. *Non-Accredited Parameters			
Test Method Variation	None			

Sample No: ACE-25-S-755
Report No : ACE-25-R-755

Date Received : 10.01.2025
Date Reported : 12.01.2025

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, NA: Not Applicable, NP: Not Provided
Test Performed By (Emp ID)	05
Report Prepared By (Emp ID)	08
The above test results are only applicable to the sample(s) referred above.	

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC


For, Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-25-R-756
Attention Person	Mr. Jasman Pinto	Sample No	ACE-25-S-756
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	12.01.2025
		Sample Certificate No	1280
Sample Description	Chilled Water	Sampling Date / Time	10.01.2025/11.05am
Sampling Point	Tower E P3 ETS Room Chilled Water	Sample Received Date / Time/ Temp °C	10.01.2025/ 3.30 pm/ 4 °C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	10.01.2025-11.01.2025
Source of Sample	Chiller Line	Sampling Method	ACE-CH-SOP-39
Onsite Treatment/Preservation of Sample	NA	Sample Collected By	ACE Rep
Sample Container	1×500ml PB	Sample Onsite Temperature °C	10°C
Client Reference	NA	Sample Appearance	Clear

CHEMICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
pH @ 25°C	APHA 4500-H ⁺ B, (24 th Edition)2023	-	Min 8.5-Max 10.5	9.68
Conductivity @ 25°C	APHA 2510 B, (24 th Edition)2023	µS/cm	Max 2250	745
Total Dissolved Solids dried at 180°C*	APHA 2540 C, (24 th Edition)2023	mg/L	Max 1500	504
Nitrite as NaNO ₂	HACH Method 8153, 01/2014 (Edition 9)	mg/L	Min 800-Max 1100	275**
Iron as Fe ²⁺ *	HACH Method 8146, 08/2019 (Edition 11)	mg/L	Max 1	0.06
Remarks	**The sample does not meet contractual specifications with respect to the above tests only. *Non-Accredited Parameters			
Test Method Variation	None			

Sample No: ACE-25-S-756
Report No : ACE-25-R-756

Date Received : 10.01.2025
Date Reported : 12.01.2025

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, NA: Not Applicable, NP: Not Provided
Test Performed By (Emp ID)	05
Report Prepared By (Emp ID)	08
The above test results are only applicable to the sample(s) referred above.	

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC


For, Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00