

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-25-R-607
Attention Person	Mr. Jasman Pinto	Sample No	ACE-25-S-607
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	07/01/2025
		Sample Certificate No	1271
Sample Description	Water	Sampling Date / Time	07/01/2025/10.00am
Sampling Point	Swimming Pool	Sample Received Date / Time/ Temp °C	07/01/2025/ 12.00 pm/4°C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	07-09/01/2025
Source of Sample	Pool	Sampling Method	ACE-MB-SOP-11
Onsite Treatment/Preservation of Sample	4°C	Sample Collected By	ACE Rep
Sample Container	1 × 500ml PB	Sample Onsite Temperature °C	22°C
Client Reference	Not Applicable	Sample Appearance	Clear

MICROBIOLOGICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
Heterotrophic Plate Count	APHA 9215B (24 th Edition) 2023	CFU/ml	1000	77
Total Coliform	APHA 9222B (24 th Edition) 2023	CFU/100ml	Zero	Zero
Faecal Coliform	APHA 9222D (24 th Edition) 2023	CFU/100ml	Zero	Zero
<i>Escherichia coli</i>	APHA 9222I (24 th Edition) 2023	CFU/100ml	-	Zero
<i>Pseudomonas aeruginosa</i>	ISO: 16266/2006	CFU/100ml	Zero	Zero
<i>Enterococci</i>	BS EN/ISO: 7899-2:2000	CFU/100ml	Zero	Zero
Remarks	The sample meets ADM specifications for swimming pools issued by the Head of Urban Planning and Municipalities No. (3) 2012 with respect to the above tests only.			
Test Method Variation	None			
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, ADM: Abu Dubai Municipality, NP: Not provided			
Test Performed By (Emp ID)			07	
Report Prepared By (Emp ID)			08	
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC

Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-25-R-608
Attention Person	Mr. Jasman Pinto	Sample No	ACE-25-R-608
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	21/01/2025
		Sample Certificate No	1271
Sample Description	Water	Sampling Date / Time	07/01/2025 / 10.00am
Sampling Point	Swimming Pool	Sample Received Date / Time/ Temp °C	07/01/2025 / 12.00 pm/ 24°C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	07-17/01/2025
Source of Sample	Pool	Sampling Method	ACE-MB-SOP-12
Onsite Treatment/Preservation of Sample	24°C	Sample Collected By	ACE Rep
Sample Container	1 × 1 L PB	Sample Onsite Temperature °C	22°C
Client Reference	Not Applicable	Sample Appearance	Clear

LEGIONELLA ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A; Procedure 5)	CFU/Litre	<1	<1
IDENTIFICATION				
Legionella Species	ISO 11731:2017 E	-	-	Absent
<i>Legionella pneumophila</i> sero group 1	ISO 11731:2017 E	-	-	Absent
<i>Legionella pneumophila</i> sero group 2 - 15	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets Dubai Municipality Health and Safety Department specifications for swimming pools (DM-HSD-GU81-PSPS2) 2020 with respect to the above tests only.			
Test Method Variation	None			
Keywords	Colony Forming Unit, APHA: American Public Health Association, DM-HSD: Dubai Municipality Health and Safety Department, NP: Not provided: Culture Media Used: BCYE Agar			
Test Performed By (Emp ID)			07	
Report Prepared By (Emp ID)			08	
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC

for
Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-25-R-609
Attention Person	Mr. Jasman Pinto	Sample No	ACE-25-S-609
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	09.01.2025
		Sample Certificate No	1271
Sample Description	Swimming Pool Water	Sampling Date / Time	07.01.2025/10.00 am
Sampling Point	Swimming Pool	Sample Received Date / Time/ Temp °C	07.01.2025/ 12.00 pm/ 4 °C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	07.01.2025
Source of Sample	Pool	Sampling Method	ACE-CH-SOP-39
Onsite Treatment/Preservation of Sample	NA	Sample Collected By	Ace Rep
Sample Container	1×500 ml PB	Sample Onsite Temperature °C	22°C
Client Reference	NA	Sample Appearance	Clear

CHEMICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
pH @ 25°C	APHA 4500-H ⁺ B, (24 th Edition)2023	-	Min 7.2-Max 7.6	7.48
Total Alkalinity as CaCO ₃	APHA 2320 B, (24 th Edition)2023	mg/L	Min 70-Max 100	83.2
Calcium Hardness as CaCO ₃	APHA 3500 Ca B, (24 th Edition)2023	mg/L	Max 100-Max 500	121.6
Free Chlorine	HACH Method 8021,01/2014 (Edition 9)	mg/L	Min 1-Max 2	1.42
Bromine*	HACH Method 8021,01/2014 (Edition 9)	mg/L	Min 2-Max 4	3.41
Cyanuric Acid*	HACH Method 8021,01/2014 (Edition 9)	mg/L	Min 20-Max 60	28

Sample No: ACE-25-S-609
Report No : ACE-25-R-609

Date Received : 07.01.2025
Date Reported : 09.01.2025

Langelier Saturation Index*	By Calculation	-	Min -0.5 - Max 0.5	-0.39
Remarks	The sample meets the ADM Specifications-Guide to the Executive Regulations of Law No. (2) for the year 2012 (Swimming pools) Issued by the Head of Urban Planning and Municipalities No. (3) for the year 2018 with respect to the above tests only. *Non-accredited parameters.			
Test Method Variation	None			
Keywords	pH: Potential Hydrogen, ADM: Abu Dhabi Municipality, APHA: American Public Health Association, NA: Not Applicable, NP: Not Provided			
Test Performed By (Emp ID)	04			
Report Prepared By (Emp ID)	04			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC



For, Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00