

**SWIMMING POOL - WATER ANALYSIS REPORT**

<b>Client Name:</b> SERCO FACILITY MANAGEMENT, ABU DHABI			
<b>Site Name:</b>	Zayed University	<b>Visit Date:</b>	26-06-2019
<b>Sampled By:</b>	Crystalline Rep.	<b>Sample Point</b>	Main Swimming Pool
<b>Source of Sample</b>	Swimming Pool		

**TEST RESULT**

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.54
2	Conductivity at 25°C, µs/cm	---	714
3	TDS, ppm	Max 1500	446
4	Alkalinity	70 - 100	74
5	Calcium Hardness	100 - 500	108
6	Residual Chlorine	1.0 - 3.0	1.45
7	Cyanuric Acid	20 - 60	18
8	Dip slide	<10 <sup>3</sup>	ND

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

**COMMENTS AND RECOMMENDATIONS**

<ul style="list-style-type: none"> <li>• Cyanuric acid levels are low – Please maintain the desired limit.</li> <li>• pH &amp; Chlorine levels found satisfactory.</li> </ul>

Reported By,

Murugaraaj  
Service Engineer

