


TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3022
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3022
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	15/10/2024
		Sample Certificate No	0351
Sample Description	Water	Sampling Date / Time	10/10/2024/ 2.25 pm
Sampling Point	Tower C P3 Pump Room Water Tank	Sample Received Date / Time/ Temp °C	10/10/2024 / 5.40 pm/4°C
Sample Location	Rihan Heights-Abu Dhabi	Date(s) Tested	10-12/10/2024
Source of Sample	Tank	Sampling Method	ACE-MB-SOP-11
Onsite Treatment/Preservation of Sample	NP	Sample Collected By	ACE Rep
Sample Container	1× 500ml PB	Sample Onsite Temperature °C	38°C
Client Reference	Not Applicable	Sample Appearance	Clear

MICROBIOLOGICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
Heterotrophic Plate Count	APHA 9215B (24 th Edition) 2023	CFU/ml	-	<8*
Total Coliform	APHA 9222B (24 th Edition) 2023	CFU/100ml	Zero	Zero
Faecal Coliform	APHA 9222D (24 th Edition) 2023	CFU/100ml	Zero	Zero
<i>Escherichia coli</i>	APHA 9222I (24 th Edition) 2023	CFU/100ml	Zero	Zero
<i>Pseudomonas aeruginosa</i>	ISO: 16266/2006	CFU/100ml	Zero	Zero
<i>Enterococci</i>	BS EN/ISO: 7899-2:2000	CFU/100ml	Zero	Zero
Remarks	The sample meets Department of Energy Water Quality Regulations (5 th Edition/ DoE/PD/R01/003) January 2021 requirements for potable water with respect to the above tests only. *Estimated CFU/ml			
Test Method Variation	None			
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, ISO: International Organization for Standardization, NP: Not provided			
Test Performed By (Emp ID)	07			
Report Prepared By (Emp ID)	08			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC


Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00


TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3018
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3018
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	15/10/2024
		Sample Certificate No	0351
Sample Description	Water	Sampling Date / Time	10/10/2024/ 1.55 pm
Sampling Point	Tower C Level 17 Tank No.01	Sample Received Date / Time/ Temp °C	10/10/2024 / 5.40 pm/4°C
Sample Location	Rihan Heights-Abu Dhabi	Date(s) Tested	10-12/10/2024
Source of Sample	Tank	Sampling Method	ACE-MB-SOP-11
Onsite Treatment/Preservation of Sample	NP	Sample Collected By	ACE Rep
Sample Container	1× 500ml PB	Sample Onsite Temperature °C	34.3°C
Client Reference	Not Applicable	Sample Appearance	Clear

MICROBIOLOGICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
Heterotrophic Plate Count	APHA 9215B (24 th Edition) 2023	CFU/ml	-	87
Total Coliform	APHA 9222B (24 th Edition) 2023	CFU/100ml	Zero	Zero
Faecal Coliform	APHA 9222D (24 th Edition) 2023	CFU/100ml	Zero	Zero
<i>Escherichia coli</i>	APHA 9222I (24 th Edition) 2023	CFU/100ml	Zero	Zero
<i>Pseudomonas aeruginosa</i>	ISO: 16266/2006	CFU/100ml	Zero	Zero
<i>Enterococci</i>	BS EN/ISO: 7899-2:2000	CFU/100ml	Zero	Zero
Remarks	The sample meets Department of Energy Water Quality Regulations (5 th Edition/ DoE/PD/R01/003) January 2021 requirements for potable water with respect to the above tests only.			
Test Method Variation	None			
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, ISO: International Organization for Standardization, NP: Not provided			
Test Performed By (Emp ID)	07			
Report Prepared By (Emp ID)	08			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC


Prabakaran Ganesan M.Phil., Ph.D.

Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3019
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3019
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	15/10/2024
		Sample Certificate No	0351
Sample Description	Water	Sampling Date / Time	10/10/2024/ 2.00 pm
Sampling Point	Tower C Level 17 Tank No.02	Sample Received Date / Time/ Temp °C	10/10/2024 / 5.40 pm/4°C
Sample Location	Rihan Heights-Abu Dhabi	Date(s) Tested	10-12/10/2024
Source of Sample	Tank	Sampling Method	ACE-MB-SOP-11
Onsite Treatment/Preservation of Sample	NP	Sample Collected By	ACE Rep
Sample Container	1× 500ml PB	Sample Onsite Temperature °C	33.9°C
Client Reference	Not Applicable	Sample Appearance	Clear

MICROBIOLOGICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
Heterotrophic Plate Count	APHA 9215B (24 th Edition) 2023	CFU/ml	-	76
Total Coliform	APHA 9222B (24 th Edition) 2023	CFU/100ml	Zero	Zero
Faecal Coliform	APHA 9222D (24 th Edition) 2023	CFU/100ml	Zero	Zero
<i>Escherichia coli</i>	APHA 9222I (24 th Edition) 2023	CFU/100ml	Zero	Zero
<i>Pseudomonas aeruginosa</i>	ISO: 16266/2006	CFU/100ml	Zero	Zero
<i>Enterococci</i>	BS EN/ISO: 7899-2:2000	CFU/100ml	Zero	Zero
Remarks	The sample meets Department of Energy Water Quality Regulations (5 th Edition/ DoE/PD/R01/003) January 2021 requirements for potable water with respect to the above tests only.			
Test Method Variation	None			
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, ISO: International Organization for Standardization, NP: Not provided			
Test Performed By (Emp ID)	07			
Report Prepared By (Emp ID)	08			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC

Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00


TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3020
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3020
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	15/10/2024
		Sample Certificate No	0351
Sample Description	Water	Sampling Date / Time	10/10/2024/ 2.05 pm
Sampling Point	Tower C Level 17 Tank No.03	Sample Received Date / Time/ Temp °C	10/10/2024 / 5.40 pm/4°C
Sample Location	Rihan Heights-Abu Dhabi	Date(s) Tested	10-12/10/2024
Source of Sample	Tank	Sampling Method	ACE-MB-SOP-11
Onsite Treatment/Preservation of Sample	NP	Sample Collected By	ACE Rep
Sample Container	1× 500ml PB	Sample Onsite Temperature °C	36°C
Client Reference	Not Applicable	Sample Appearance	Clear

MICROBIOLOGICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
Heterotrophic Plate Count	APHA 9215B (24 th Edition) 2023	CFU/ml	-	<1*
Total Coliform	APHA 9222B (24 th Edition) 2023	CFU/100ml	Zero	Zero
Faecal Coliform	APHA 9222D (24 th Edition) 2023	CFU/100ml	Zero	Zero
<i>Escherichia coli</i>	APHA 9222I (24 th Edition) 2023	CFU/100ml	Zero	Zero
<i>Pseudomonas aeruginosa</i>	ISO: 16266/2006	CFU/100ml	Zero	Zero
<i>Enterococci</i>	BS EN/ISO: 7899-2:2000	CFU/100ml	Zero	Zero
Remarks	The sample meets Department of Energy Water Quality Regulations (5 th Edition/ DoE/PD/R01/003) January 2021 requirements for potable water with respect to the above tests only. *Estimated CFU/ml			
Test Method Variation	None			
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, ISO: International Organization for Standardization, NP: Not provided			
Test Performed By (Emp ID)	07			
Report Prepared By (Emp ID)	08			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC


Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00


TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3021
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3021
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	15/10/2024
		Sample Certificate No	0351
Sample Description	Water	Sampling Date / Time	10/10/2024/ 2.15 pm
Sampling Point	Tower C Level 15 Waste Room	Sample Received Date / Time/ Temp °C	10/10/2024 / 5.40 pm/4°C
Sample Location	Rihan Heights-Abu Dhabi	Date(s) Tested	10-12/10/2024
Source of Sample	Tap	Sampling Method	ACE-MB-SOP-11
Onsite Treatment/Preservation of Sample	NP	Sample Collected By	ACE Rep
Sample Container	1 × 500ml PB	Sample Onsite Temperature °C	29.6°C
Client Reference	Not Applicable	Sample Appearance	Clear

MICROBIOLOGICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
Heterotrophic Plate Count	APHA 9215B (24 th Edition) 2023	CFU/ml	-	66
Total Coliform	APHA 9222B (24 th Edition) 2023	CFU/100ml	Zero	Zero
Faecal Coliform	APHA 9222D (24 th Edition) 2023	CFU/100ml	Zero	Zero
<i>Escherichia coli</i>	APHA 9222I (24 th Edition) 2023	CFU/100ml	Zero	Zero
<i>Pseudomonas aeruginosa</i>	ISO: 16266/2006	CFU/100ml	Zero	Zero
<i>Enterococci</i>	BS EN/ISO: 7899-2:2000	CFU/100ml	Zero	Zero
Remarks	The sample meets Department of Energy Water Quality Regulations (5 th Edition/ DoE/PD/R01/003) January 2021 requirements for potable water with respect to the above tests only.			
Test Method Variation	None			
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, ISO: International Organization for Standardization, NP: Not provided			
Test Performed By (Emp ID)	07			
Report Prepared By (Emp ID)	08			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC


Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3092
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3092
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	22/10/2024
		Sample Certificate No	0351
Sample Description	Water	Sampling Date / Time	10/10/2024 / 2.25 pm
Sampling Point	Tower C P3 Pump Room Water Tank	Sample Received Date / Time/ Temp °C	10/10/2024 / 5.40 pm/ 24°C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	10-20/10/2024
Source of Sample	Tank	Sampling Method	ACE-MB-SOP-12
Onsite Treatment/Preservation of Sample	24°C	Sample Collected By	ACE Rep
Sample Container	1 × 1 L PB	Sample Onsite Temperature °C	38°C
Client Reference	Not Applicable	Sample Appearance	Clear

LEGIONELLA ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A; Procedure 5)	CFU/Litre	<1	<1
IDENTIFICATION				
Legionella Species	ISO 11731:2017 E	-	-	Absent
<i>Legionella pneumophila</i> sero group 1	ISO 11731:2017 E	-	-	Absent
<i>Legionella pneumophila</i> sero group 2 - 15	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets Department of Energy Water Quality Regulations (5 th Edition/ DoE/PD/R01/003) January 2021 requirements for potable water with respect to the above tests only.			
Test Method Variation	None			
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization DoE: Department of Energy, NP: Not provided: Culture Media Used: BCYE Agar			
Test Performed By (Emp ID)	02			
Report Prepared By (Emp ID)	08			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC

Prabakaran Ganesan M.Phil., Ph.D.

Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3088
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3088
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	22/10/2024
		Sample Certificate No	0351
Sample Description	Water	Sampling Date / Time	10/10/2024 / 1.55 pm
Sampling Point	Tower C Level 17 Tank No.01	Sample Received Date / Time/ Temp °C	10/10/2024 / 5.40 pm/ 24°C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	10-20/10/2024
Source of Sample	Tank	Sampling Method	ACE-MB-SOP-12
Onsite Treatment/Preservation of Sample	24°C	Sample Collected By	ACE Rep
Sample Container	1 × 1 L PB	Sample Onsite Temperature °C	34.3°C
Client Reference	Not Applicable	Sample Appearance	Clear

LEGIONELLA ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A; Procedure 5)	CFU/Litre	<1	<1
IDENTIFICATION				
Legionella Species	ISO 11731:2017 E	-	-	Absent
<i>Legionella pneumophila</i> sero group 1	ISO 11731:2017 E	-	-	Absent
<i>Legionella pneumophila</i> sero group 2 - 15	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets Department of Energy Water Quality Regulations (5 th Edition/ DoE/PD/R01/003) January 2021 requirements for potable water with respect to the above tests only.			
Test Method Variation	None			
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization DoE: Department of Energy, NP: Not provided: Culture Media Used: BCYE Agar			
Test Performed By (Emp ID)	02			
Report Prepared By (Emp ID)	08			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC

Prabakaran Ganesan M.Phil., Ph.D.

Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3089
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3089
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	22/10/2024
		Sample Certificate No	0351
Sample Description	Water	Sampling Date / Time	10/10/2024 / 2.00 pm
Sampling Point	Tower C Level 17 Tank No.02	Sample Received Date / Time/ Temp °C	10/10/2024 / 5.40 pm/ 24°C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	10-20/10/2024
Source of Sample	Tank	Sampling Method	ACE-MB-SOP-12
Onsite Treatment/Preservation of Sample	24°C	Sample Collected By	ACE Rep
Sample Container	1× 1 L PB	Sample Onsite Temperature °C	33.9°C
Client Reference	Not Applicable	Sample Appearance	Clear

LEGIONELLA ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A; Procedure 5)	CFU/Litre	<1	<1
IDENTIFICATION				
Legionella Species	ISO 11731:2017 E	-	-	Absent
<i>Legionella pneumophila</i> sero group 1	ISO 11731:2017 E	-	-	Absent
<i>Legionella pneumophila</i> sero group 2 - 15	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets Department of Energy Water Quality Regulations (5 th Edition/ DoE/PD/R01/003) January 2021 requirements for potable water with respect to the above tests only.			
Test Method Variation	None			
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization DoE: Department of Energy, NP: Not provided; Culture Media Used: BCYE Agar			
Test Performed By (Emp ID)	02			
Report Prepared By (Emp ID)	08			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC

Prabakaran Ganesan M.Phil., Ph.D.

Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-01 Issue: 1; 05-11-2023 Rev:00


TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3090
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3090
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	22/10/2024
		Sample Certificate No	0351
Sample Description	Water	Sampling Date / Time	10/10/2024 / 2.05 pm
Sampling Point	Tower C Level 17 Tank No.03	Sample Received Date / Time/ Temp °C	10/10/2024 / 5.40 pm/ 24°C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	10-20/10/2024
Source of Sample	Tank	Sampling Method	ACE-MB-SOP-12
Onsite Treatment/Preservation of Sample	24°C	Sample Collected By	ACE Rep
Sample Container	1 × 1 L PB	Sample Onsite Temperature °C	36°C
Client Reference	Not Applicable	Sample Appearance	Clear

LEGIONELLA ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A; Procedure 5)	CFU/Litre	<1	<1
IDENTIFICATION				
Legionella Species	ISO 11731:2017 E	-	-	Absent
<i>Legionella pneumophila</i> sero group 1	ISO 11731:2017 E	-	-	Absent
<i>Legionella pneumophila</i> sero group 2 - 15	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets Department of Energy Water Quality Regulations (5 th Edition/ DoE/PD/R01/003) January 2021 requirements for potable water with respect to the above tests only.			
Test Method Variation	None			
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization DoE: Department of Energy, NP: Not provided: Culture Media Used: BCYE Agar			
Test Performed By (Emp ID)	02			
Report Prepared By (Emp ID)	08			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC


Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3091
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3091
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	22/10/2024
		Sample Certificate No	0351
Sample Description	Water	Sampling Date / Time	10/10/2024 / 2.15 pm
Sampling Point	Tower C Level 15 Waste Room	Sample Received Date / Time/ Temp °C	10/10/2024 / 5.40 pm/ 24°C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	10-20/10/2024
Source of Sample	Tap	Sampling Method	ACE-MB-SOP-12
Onsite Treatment/Preservation of Sample	24°C	Sample Collected By	ACE Rep
Sample Container	1 × 1 L PB	Sample Onsite Temperature °C	29.6°C
Client Reference	Not Applicable	Sample Appearance	Clear

LEGIONELLA ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A; Procedure 5)	CFU/Litre	<1	<1
IDENTIFICATION				
Legionella Species	ISO 11731:2017 E	-	-	Absent
<i>Legionella pneumophila</i> sero group 1	ISO 11731:2017 E	-	-	Absent
<i>Legionella pneumophila</i> sero group 2 - 15	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets Department of Energy Water Quality Regulations (5 th Edition/ DoE/PD/R01/003) January 2021 requirements for potable water with respect to the above tests only.			
Test Method Variation	None			
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization DoE: Department of Energy, NP: Not provided: Culture Media Used: BCYE Agar			
Test Performed By (Emp ID)	02			
Report Prepared By (Emp ID)	08			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC

Prabakaran Ganesan M.Phil., Ph.D.

Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3059
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3059
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	12.10.2024
		Sample Certificate No	0351
Sample Description	Potable Water	Sampling Date / Time	10.10.2024/2.25 pm
Sampling Point	Tower C P3 Pump Room Water Tank	Sample Received Date / Time/ Temp °C	10.10.2024/ 5.40 pm/ 4°C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	11.10.2024
Source of Sample	Tank	Sampling Method	ACE-CH-SOP-39
Onsite Treatment/Preservation of Sample	NA	Sample Collected By	ACE Rep
Sample Container	1×500 ml PB	Sample Onsite Temperature °C	38°C
Client Reference	NA	Sample Appearance	Clear

CHEMICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
pH @ 25°C	APHA 4500-H ⁺ B, (24 th Edition)2023	-	Min 7.0-Max 9.2	8.11
Total Intensity of Odor	ACE-CH-SOP-01 Issue 01 dated 28/11/2023 Rev 1 dated 05/03/2024 based on APHA 2150 C, (24 th Edition)2023	-	Unobjectionable	0 @ 25°C #
Apparent Colour	HACH Method 8025,10/2014 (Edition 10)	Pt-Co units	Max 15.0	<5
Turbidity	APHA 2130 B, (24 th Edition)2023	NTU	Max 4.0	0.10
Total Dissolved Solids dried at 180°C	APHA 2540 C, (24 th Edition)2023	mg/L	Min 100-Max 600	136
Total Hardness as CaCO ₃	APHA 2340 C, (24 th Edition)2023	mg/L	Max 300	49.3
Calcium Hardness as CaCO ₃	APHA 3500 Ca B, (24 th Edition)2023	mg/L	Max 200	39.4
Chloride	APHA 4500-Cl ⁻ B, (24 th Edition)2023	mg/L	Max 250	38.1

Sample No: ACE-24-S-3059

Report No : ACE-24-R-3059

Date Received : 10.10.2024

Date Reported : 12.10.2024

Nitrate as NO ₃ -N	HACH Method 8192, 01/2019 (Edition 11)	mg/L	Max 50.0	<0.01
Nitrite as NO ₂	HACH Method 8507, 08/2019 (Edition 11)	mg/L	Max 3.0	0.016
Sulphate	HACH Method 8051, 10/2019 (Edition 11)	mg/L	Max 250	<2
Chlorine Dioxide*	HACH Method 10126, 08/2019 Edition 11	mg/L	Min 0.1-Max 0.4	0.16
Remarks	The sample meets DoE Water Quality Regulations 2021 (Document no. DoE/PD/R01/003 Effective Date: 01/01/2021) for drinking water with respect to the above tests only. #Odor is unobjectionable *Non-Accredited Parameters			
Test Method Variation	None			
Keywords	pH: Potential Hydrogen, DoE: Department of Energy, APHA: American Public Health Association, NA: Not Applicable, NP: Not Provided			
Test Performed By (Emp ID)	04			
Report Prepared By (Emp ID)	04			

The above test results are only applicable to the sample(s) referred above.

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC


Prabakaran Ganesan M.Phil., Ph.D.

Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3055
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3055
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	12.10.2024
		Sample Certificate No	0351
Sample Description	Potable Water	Sampling Date / Time	10.10.2024/1.55 pm
Sampling Point	Tower C Level 17 Tank No 01	Sample Received Date / Time/ Temp °C	10.10.2024/ 5.40 pm/ 4 °C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	11.10.2024
Source of Sample	Tank	Sampling Method	ACE-CH-SOP-39
Onsite Treatment/Preservation of Sample	NA	Sample Collected By	ACE Rep
Sample Container	1×500 ml PB	Sample Onsite Temperature °C	34.3°C
Client Reference	NA	Sample Appearance	Clear

CHEMICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
pH @ 25°C	APHA 4500-H ⁺ B, (24 th Edition)2023	-	Min 7.0-Max 9.2	8.23
Total Intensity of Odor	ACE-CH-SOP-01 Issue 01 dated 28/11/2023 Rev 1 dated 05/03/2024 based on APHA 2150 C, (24 th Edition)2023	-	Unobjectionable	0 @ 25°C #
Apparent Colour	HACH Method 8025,10/2014 (Edition 10)	Pt-Co units	Max 15.0	<5
Turbidity	APHA 2130 B, (24 th Edition)2023	NTU	Max 4.0	0.15
Total Dissolved Solids dried at 180°C	APHA 2540 C, (24 th Edition)2023	mg/L	Min 100-Max 600	136
Total Hardness as CaCO ₃	APHA 2340 C, (24 th Edition)2023	mg/L	Max 300	49.3
Calcium Hardness as CaCO ₃	APHA 3500 Ca B, (24 th Edition)2023	mg/L	Max 200	39.4
Chloride	APHA 4500-Cl ⁻ B, (24 th Edition)2023	mg/L	Max 250	38.1

Sample No: ACE-24-S-3055


Report No : ACE-24-R-3055

Date Received : 10.10.2024

Date Reported : 12.10.2024

Nitrate as NO ₃ -N	HACH Method 8192, 01/2019 (Edition 11)	mg/L	Max 50.0	<0.01
Nitrite as NO ₂	HACH Method 8507, 08/2019 (Edition 11)	mg/L	Max 3.0	0.014
Sulphate	HACH Method 8051, 10/2019 (Edition 11)	mg/L	Max 250	<2
Chlorine Dioxide*	HACH Method 10126, 08/2019 Edition 11	mg/L	Min 0.1-Max 0.4	0.16
Remarks	The sample meets DoE Water Quality Regulations 2021 (Document no. DoE/PD/R01/003 Effective Date: 01/01/2021) for drinking water with respect to the above tests only. #Odor is unobjectionable *Non-Accredited Parameters			
Test Method Variation	None			
Keywords	pH: Potential Hydrogen, DoE: Department of Energy, APHA: American Public Health Association, NA: Not Applicable, NP: Not Provided			
Test Performed By (Emp ID)	04			
Report Prepared By (Emp ID)	04			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC


Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3056
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3056
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	12.10.2024
		Sample Certificate No	0351
Sample Description	Potable Water	Sampling Date / Time	10.10.2024/2.00 pm
Sampling Point	Tower C Level 17 Tank No 02	Sample Received Date / Time/ Temp °C	10.10.2024/ 5.40 pm/ 4 °C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	11.10.2024
Source of Sample	Tank	Sampling Method	ACE-CH-SOP-39
Onsite Treatment/Preservation of Sample	NA	Sample Collected By	ACE Rep
Sample Container	1×500 ml PB	Sample Onsite Temperature °C	33.9°C
Client Reference	NA	Sample Appearance	Clear

CHEMICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
pH @ 25°C	APHA 4500-H ⁺ B, (24 th Edition)2023	-	Min 7.0-Max 9.2	8.19
Total Intensity of Odor	ACE-CH-SOP-01 Issue 01 dated 28/11/2023 Rev 1 dated 05/03/2024 based on APHA 2150 C, (24 th Edition)2023	-	Unobjectionable	0 @ 25°C #
Apparent Colour	HACH Method 8025,10/2014 (Edition 10)	Pt-Co units	Max 15.0	<5
Turbidity	APHA 2130 B, (24 th Edition)2023	NTU	Max 4.0	0.15
Total Dissolved Solids dried at 180°C	APHA 2540 C, (24 th Edition)2023	mg/L	Min 100-Max 600	135
Total Hardness as CaCO ₃	APHA 2340 C, (24 th Edition)2023	mg/L	Max 300	49.3
Calcium Hardness as CaCO ₃	APHA 3500 Ca B, (24 th Edition)2023	mg/L	Max 200	35.5
Chloride	APHA 4500-Cl ⁻ B, (24 th Edition)2023	mg/L	Max 250	37.2

Sample No: ACE-24-S-3056


Date Received : 10.10.2024

Report No : ACE-24-R-3056

Date Reported : 12.10.2024

Nitrate as NO ₃ -N	HACH Method 8192, 01/2019 (Edition 11)	mg/L	Max 50.0	<0.01
Nitrite as NO ₂	HACH Method 8507, 08/2019 (Edition 11)	mg/L	Max 3.0	0.017
Sulphate	HACH Method 8051, 10/2019 (Edition 11)	mg/L	Max 250	<2
Chlorine Dioxide*	HACH Method 10126, 08/2019 Edition 11	mg/L	Min 0.1-Max 0.4	0.15
Remarks	The sample meets DoE Water Quality Regulations 2021 (Document no. DoE/PD/R01/003 Effective Date: 01/01/2021) for drinking water with respect to the above tests only. #Odor is unobjectionable *Non-Accredited Parameters			
Test Method Variation	None			
Keywords	pH: Potential Hydrogen, DoE: Department of Energy, APHA: American Public Health Association, NA: Not Applicable, NP: Not Provided			
Test Performed By (Emp ID)	04			
Report Prepared By (Emp ID)	04			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC


Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3057
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3057
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	12.10.2024
		Sample Certificate No	0351
Sample Description	Potable Water	Sampling Date / Time	10.10.2024/2.05 pm
Sampling Point	Tower C Level 17 Tank No 03	Sample Received Date / Time/ Temp °C	10.10.2024/ 5.40 pm/ 4 °C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	11.10.2024
Source of Sample	Tank	Sampling Method	ACE-CH-SOP-39
Onsite Treatment/Preservation of Sample	NA	Sample Collected By	ACE Rep
Sample Container	1×500 ml PB	Sample Onsite Temperature °C	36°C
Client Reference	NA	Sample Appearance	Clear

CHEMICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
pH @ 25°C	APHA 4500-H ⁺ B, (24 th Edition)2023	-	Min 7.0-Max 9.2	8.20
Total Intensity of Odor	ACE-CH-SOP-01 Issue 01 dated 28/11/2023 Rev 1 dated 05/03/2024 based on APHA 2150 C, (24 th Edition)2023	-	Unobjectionable	0 @ 25°C #
Apparent Colour	HACH Method 8025,10/2014 (Edition 10)	Pt-Co units	Max 15.0	<5
Turbidity	APHA 2130 B, (24 th Edition)2023	NTU	Max 4.0	0.10
Total Dissolved Solids dried at 180°C	APHA 2540 C, (24 th Edition)2023	mg/L	Min 100-Max 600	136
Total Hardness as CaCO ₃	APHA 2340 C, (24 th Edition)2023	mg/L	Max 300	51.2
Calcium Hardness as CaCO ₃	APHA 3500 Ca B, (24 th Edition)2023	mg/L	Max 200	39.4
Chloride	APHA 4500-Cl ⁻ B, (24 th Edition)2023	mg/L	Max 250	38.1

Sample No: ACE-24-S-3057
Report No : ACE-24-R-3057

Date Received : 10.10.2024
Date Reported : 12.10.2024

Nitrate as NO ₃ -N	HACH Method 8192, 01/2019 (Edition 11)	mg/L	Max 50.0	<0.01
Nitrite as NO ₂	HACH Method 8507, 08/2019 (Edition 11)	mg/L	Max 3.0	0.016
Sulphate	HACH Method 8051, 10/2019 (Edition 11)	mg/L	Max 250	<2
Chlorine Dioxide*	HACH Method 10126, 08/2019 Edition 11	mg/L	Min 0.1-Max 0.4	0.14
Remarks	The sample meets DoE Water Quality Regulations 2021 (Document no. DoE/PD/R01/003 Effective Date: 01/01/2021) for drinking water with respect to the above tests only. #Odor is unobjectionable *Non-Accredited Parameters			
Test Method Variation	None			
Keywords	pH: Potential Hydrogen, DoE: Department of Energy, APHA: American Public Health Association, NA: Not Applicable, NP: Not Provided			
Test Performed By (Emp ID)	04			
Report Prepared By (Emp ID)	04			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC


Prabakaran Ganesan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00

TEST REPORT

Client Name	Crystalline Cleaning and Environmental Services, Sole Proprietorship LLC	Report No	ACE-24-R-3058
Attention Person	Mr. Jasman Pinto	Sample No	ACE-24-S-3058
Address & Location	PO Box 131463, Abu Dhabi, United Arab Emirates	Date Reported	12.10.2024
		Sample Certificate No	0351
Sample Description	Potable Water	Sampling Date / Time	10.10.2024/2.15 pm
Sampling Point	Tower C Level 15 Waste Room	Sample Received Date / Time/ Temp °C	10.10.2024/ 5.40 pm/ 4 °C
Sample Location	Rihan Heights, Abu Dhabi	Date(s) Tested	11.10.2024
Source of Sample	Tap	Sampling Method	ACE-CH-SOP-39
Onsite Treatment/Preservation of Sample	NA	Sample Collected By	ACE Rep
Sample Container	1×500 ml PB	Sample Onsite Temperature °C	29.6°C
Client Reference	NA	Sample Appearance	Clear

CHEMICAL ANALYSIS OF WATER

PARAMETERS	METHODS	UNITS	LIMITS	RESULTS
pH @ 25°C	APHA 4500-H ⁺ B, (24 th Edition)2023	-	Min 7.0-Max 9.2	8.08
Total Intensity of Odor	ACE-CH-SOP-01 Issue 01 dated 28/11/2023 Rev 1 dated 05/03/2024 based on APHA 2150 C, (24 th Edition)2023	-	Unobjectionable	0 @ 25°C #
Apparent Colour	HACH Method 8025,10/2014 (Edition 10)	Pt-Co units	Max 15.0	<5
Turbidity	APHA 2130 B, (24 th Edition)2023	NTU	Max 4.0	0.15
Total Dissolved Solids dried at 180°C	APHA 2540 C, (24 th Edition)2023	mg/L	Min 100-Max 600	137
Total Hardness as CaCO ₃	APHA 2340 C, (24 th Edition)2023	mg/L	Max 300	51.2
Calcium Hardness as CaCO ₃	APHA 3500 Ca B, (24 th Edition)2023	mg/L	Max 200	35.5
Chloride	APHA 4500-Cl ⁻ B, (24 th Edition)2023	mg/L	Max 250	37.2

Sample No: ACE-24-S-3058

Report No : ACE-24-R-3058

Date Received : 10.10.2024

Date Reported : 12.10.2024

Nitrate as NO ₃ -N	HACH Method 8192, 01/2019 (Edition 11)	mg/L	Max 50.0	<0.01
Nitrite as NO ₂	HACH Method 8507, 08/2019 (Edition 11)	mg/L	Max 3.0	0.016
Sulphate	HACH Method 8051, 10/2019 (Edition 11)	mg/L	Max 250	<2
Chlorine Dioxide*	HACH Method 10126, 08/2019 Edition 11	mg/L	Min 0.1-Max 0.4	0.14
Remarks	The sample meets DoE Water Quality Regulations 2021 (Document no. DoE/PD/R01/003 Effective Date: 01/01/2021) for drinking water with respect to the above tests only. #Odor is unobjectionable *Non-Accredited Parameters			
Test Method Variation	None			
Keywords	pH: Potential Hydrogen, DoE: Department of Energy, APHA: American Public Health Association, NA: Not Applicable, NP: Not Provided			
Test Performed By (Emp ID)	04			
Report Prepared By (Emp ID)	04			
The above test results are only applicable to the sample(s) referred above.				

Signed for and on behalf of ACE Laboratories Sole proprietorship LLC


Prabakaran Ganeshan M.Phil., Ph.D.
Laboratory Manager

Results relate only to the item tested.

This report shall not be produced in full, without the written approval of the laboratory.



-End of Report-

R-W-O1 Issue: 1; 05-11-2023 Rev:00