

TEST REPORT


Report No: QMTL/R-128155/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-128155
		Date Received	12 Oct 2020
		Date(s) Tested	12 Oct 2020 - 14 Oct 2020
		Date Reported	17 Oct 2020
Sample Description	P-1, Hydrotherapy Pool		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	12.10.2020 / 02:50 PM
Sample Container	1x500ml PB	Sampling Point	Pool
Sample Receipt Temp	4°C	Sample Onsite Temp	36°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total bacterial count(Dip slide)	Kit Method	CFU/ml	1000	<1
Remarks	The sample meets DM Public swimming pool safety guidelines(2019,Doc Ref.:DM-PH&SD-GU81-PSPS2) specifications for Pool Water with respect to the above tests only.			
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, Doc Ref.: Document Reference			
Test method deviation	None			
Test performed by Emp#	14 & 74			
Report prepared by Emp#	72			
The above test results are only applicable to the sample(s) referred above.				

Reported By


ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128158/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-128158
		Date Received	12 Oct 2020
		Date(s) Tested	12 Oct 2020 - 14 Oct 2020
		Date Reported	17 Oct 2020
Sample Description	L-4, Cooling Tower - 1		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	12.10.2020 / 03:25 PM
Sample Container	1x500ml PB	Sampling Point	Cooling Tower Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	27°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10,000	3
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	14 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By


ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128159/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-128159
		Date Received	12 Oct 2020
		Date(s) Tested	12 Oct 2020 - 14 Oct 2020
		Date Reported	17 Oct 2020
Sample Description	L-4, Cooling Tower - 2		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	12.10.2020 / 03:30 PM
Sample Container	1x500ml PB	Sampling Point	Cooling Tower Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	28°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10,000	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--


Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.	
---	--

Reported By


ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128160/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-128160
		Date Received	12 Oct 2020
		Date(s) Tested	12 Oct 2020 - 14 Oct 2020
		Date Reported	17 Oct 2020
Sample Description	L-4, Cooling Tower - 3		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	12.10.2020 / 03:35 PM
Sample Container	1x500ml PB	Sampling Point	Cooling Tower Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	28°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10,000	2
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.	
---	--

Reported By


ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128161/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-128161
		Date Received	12 Oct 2020
		Date(s) Tested	12 Oct 2020 - 14 Oct 2020
		Date Reported	17 Oct 2020
Sample Description	L-4, Cooling Tower - 4		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	12.10.2020 / 03:45 PM
Sample Container	1x500ml PB	Sampling Point	Cooling Tower Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	31°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10,000	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--


Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.	
---	--

Reported By


ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128156/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID		QMTL/S-128156
	Date Received		12 Oct 2020
	Date(s) Tested		12 Oct 2020 - 15 Oct 2020
	Date Reported		17 Oct 2020
ATTN : MR. JASMAN PINTO			
Sample Description	Copper - Silver Ionisation – P2 Water Tank # 05		
Sample Type	Water	Sampling Method	QMTL-SOP-128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	12.10.2020 / 03:00 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	18°C	Sample Onsite Temp	36°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
CHEMICAL PARAMETERS				
Calcium Hardness	APHA 3500-Ca B (23rd Edition)	mg/L	Max 200	60.2
Chloride	APHA 4500 Cl ⁻ B (23rd Edition)	mg/L	Max 250	48.8
Conductivity	APHA 2510 B (23rd Edition)	µs/cm	-	209.2@24.1°C
pH	APHA 4500 H+B (23rd Edition)	-	Min 7.0-Max 9.2	7.52@24.1°C
Total Dissolved Solids	APHA 2540-C (23rd Edition)	mg/L	Min 100-Max 1000	134
Total Hardness as (CaCO ₃)	APHA 2340-C (23rd Edition)	mg/L	Max 300	62.1
METALS				
Copper	APHA 3120 B (23rd Edition)	mg/L	Max 1.0	<0.05
Iron	APHA 3120 B (23rd Edition)	mg/L	Max 0.20	<0.05
Silver	APHA 3120 B (23rd Edition)	mg/L	-	<0.05
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
----------	--

Test method deviation	None
Test performed by Emp#	13
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-128157/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-128157
		Date Received	12 Oct 2020
		Date(s) Tested	12 Oct 2020 - 15 Oct 2020
ATTN : MR. JASMAN PINTO		Date Reported	17 Oct 2020
Sample Description	Copper - Silver Ionisation – P2 Water Tank # 06		
Sample Type	Water	Sampling Method	QMTL-SOP-128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	12.10.2020 / 03:10 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	18°C	Sample Onsite Temp	20°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
CHEMICAL PARAMETERS				
Calcium Hardness	APHA 3500-Ca B (23rd Edition)	mg/L	Max 200	56.3
Chloride	APHA 4500 Cl ⁻ B (23rd Edition)	mg/L	Max 250	49.3
Conductivity	APHA 2510 B (23rd Edition)	µs/cm	-	207.4@24.1°C
pH	APHA 4500 H+B (23rd Edition)	-	Min 7.0-Max 9.2	7.67@24.1°C
Total Dissolved Solids	APHA 2540-C (23rd Edition)	mg/L	Min 100-Max 1000	135
Total Hardness as (CaCO ₃)	APHA 2340-C (23rd Edition)	mg/L	Max 300	60.2
METALS				
Copper	APHA 3120 B (23rd Edition)	mg/L	Max 1.0	<0.05
Iron	APHA 3120 B (23rd Edition)	mg/L	Max 0.20	<0.05
Silver	APHA 3120 B (23rd Edition)	mg/L	-	<0.05
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
----------	--

Test method deviation	None
Test performed by Emp#	13
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT