

## TEST REPORT

Report No: QMTL/R-101563/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-101563
ATTN : MR. JASMAN PINTO		Date Received	22 Apr 2020
		Date(s) Tested	22 Apr 2020 - 24 Apr 2020
		Date Reported	03 May 2020
Sample Description	L-4 Cooling Tower-01		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital-AUH	Sampling Date/Time	22.04.2020/ 2:55 PM
Sample Container	1X500ml PB	Sampling Point	Tower
Sample Receipt Temp	5°C	Sample Onsite Temp	20.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10,000	120
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, WI: Work Instruction, NA: Not Applicable, NP :Not Provided.
----------	---


Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-101565/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>		Sample ID	QMTL/S-101565
		Date Received	22 Apr 2020
		Date(s) Tested	22 Apr 2020 - 24 Apr 2020
		Date Reported	03 May 2020
Sample Description	L-4 Cooling Tower-02		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital-AUH	Sampling Date/Time	22.04.2020/ 3:05 PM
Sample Container	1X500ml PB	Sampling Point	Tower
Sample Receipt Temp	5°C	Sample Onsite Temp	22.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10,000	110
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-101567/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-101567
ATTN : MR. JASMAN PINTO		Date Received	22 Apr 2020
		Date(s) Tested	22 Apr 2020 - 24 Apr 2020
		Date Reported	03 May 2020
Sample Description	L-4 Cooling Tower-03		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital-AUH	Sampling Date/Time	22.04.2020/ 3:15 PM
Sample Container	1X500ml PB	Sampling Point	Tower
Sample Receipt Temp	5°C	Sample Onsite Temp	22.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10,000	56
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-101569/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-101569
ATTN : MR. JASMAN PINTO		Date Received	22 Apr 2020
		Date(s) Tested	22 Apr 2020 - 24 Apr 2020
		Date Reported	03 May 2020
Sample Description	L-4 Cooling Tower-04		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital-AUH	Sampling Date/Time	22.04.2020/ 3:25 PM
Sample Container	1X500ml PB	Sampling Point	Tower
Sample Receipt Temp	5°C	Sample Onsite Temp	22.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10,000	130
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-101546/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-101546
ATTN : MR. JASMAN PINTO		Date Received	22 Apr 2020
		Date(s) Tested	22 Apr 2020 - 24 Apr 2020
		Date Reported	03 May 2020
Sample Description	P1-Hydrotherapy Pool		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital-AUH	Sampling Date/Time	22.04.2020/ 1:35 PM
Sample Container	1X500ml PB	Sampling Point	Pool
Sample Receipt Temp	5°C	Sample Onsite Temp	23.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
Total Bacterial Count	Dip Slide	CFU/ml	1000	<1

Remarks	The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above test only.
---------	---

Keywords	CFU: Colony Forming Unit, DM: Dubai Municipality, NP: Not Provided, WI : Work Instruction, NA: Not Applicable.
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

**ANILA GEORGE**  
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-101542/2020

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b> P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017  <b>ATTN: Mr. JASMAN PINTO</b>	Sample ID	QMTL/S-101542	
	Date Received	22 Apr 2020	
	Date(s) Tested	22 Apr 2020-27 Apr 2020	
	Date Reported	06 May 2020	
Sample Description	P2 GRP Tank 5		
Sample Type	Water	Sampling Method	QMTL-SOP- 128
Client Name/Project	HEALTH POINT HOSPITAL	Sampled By	QMTL Representative
Location	Abu Dhabi	Sampling Date/Time	22.04.2020/12:30-3:30 PM
Sample Container	1x500mL PB	Sampling Point	Tank
Sample Receipt Temp	5°C	Sample On-site Temp	28.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	LIMITS	RESULTS
<b>CHEMICAL ANALYSIS</b>				
pH @23.5°C	APHA 4500-H <sup>+</sup> B	--	7.0 - 9.2	7.54
Conductivity @23.9°C	APHA 2510	µs/cm	-	222
Total Dissolved Solids@180°C	APHA 2540-C	mg/L	Min100 – Max 1000	145
Chloride (Cl)	APHA 4500-Cl <sup>-</sup> B	mg/L	Max 250	32.5
Calcium Hardness as CaCO <sub>3</sub>	APHA 3500-Ca B	mg/L	Max 200	58.6
Total Hardness as (CaCO <sub>3</sub> )	APHA 2340-C	mg/L	Max 300	62.6
Iron (Fe)	APHA 3120 B	mg/L	Max 0.2	<0.05
Copper (Cu)	APHA 3120 B	mg/L	Max 1.0	<0.05
Silver (Ag)	APHA 3120 B	mg/L	Max 5.0	<0.05

Remarks	The sample meets RSB Water Quality Regulations (4 <sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable, NP: Not Provided
----------	--

Test Method Deviation	None
Test performed by Emp#	13
Report prepared by Emp#	75
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**  
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-101544/2020

<b>CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES</b>		Sample ID	QMTL/S-101544
P.O.Box.131463, Abu Dhabi, U.A.E		Date Received	22 Apr 2020
Ph:02-6508930/0557167017		Date(s) Tested	22 Apr 2020-27 Apr 2020
<b>ATTN: Mr. JASMAN PINTO</b>		Date Reported	06 May 2020
Sample Description	P2 GRP Tank 6		
Sample Type	Water	Sampling Method	QMTL-SOP- 128
Client Name/Project	HEALTH POINT HOSPITAL	Sampled By	QMTL Representative
Location	Abu Dhabi	Sampling Date/Time	22.04.2020/12:30-3:30 PM
Sample Container	1x500mL PB	Sampling Point	Tank
Sample Receipt Temp	5.0°C	Sample On-site Temp	14°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 <sup>RD</sup> EDITION)	UNITS	LIMITS	RESULTS
<b>CHEMICAL ANALYSIS</b>				
pH @23.9°C	APHA 4500-H <sup>+</sup> B	--	7.0 - 9.2	7.56
Conductivity @23.7°C	APHA 2510	µs/cm	-	221
Total Dissolved Solids@180°C	APHA 2540-C	mg/L	Min100 – Max 1000	144
Chloride (Cl)	APHA 4500-Cl B	mg/L	Max 250	33.0
Calcium Hardness as CaCO <sub>3</sub>	APHA 3500-Ca B	mg/L	Max 200	57.0
Total Hardness as (CaCO <sub>3</sub> )	APHA 2340-C	mg/L	Max 300	62.6
Iron (Fe)	APHA 3120 B	mg/L	Max 0.2	<0.05
Copper (Cu)	APHA 3120 B	mg/L	Max 1.0	<0.05
Silver (Ag)	APHA 3120 B	mg/L	Max 5.0	<0.05

Remarks	The sample meets RSB Water Quality Regulations (4 <sup>th</sup> Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable, NP: Not Provided
----------	---

Test Method Deviation	None
Test performed by Emp#	13
Report prepared by Emp#	75
The above test results are only applicable to the sample(s) referred above.	

**Reported By**

**ANILA GEORGE**  
**LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

**END OF REPORT**