

TEST REPORT

Report No: QMTL/R-145942/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-145942
		Date Received	30 Jan 2021
		Date(s) Tested	30 Jan 2021 - 01 Feb 2021
		Date Reported	03 Feb 2021
Sample Description	L4, Cooling Tower -1		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	30.01.2021 / 10:10 AM
Sample Container	1x500ml PB	Sampling Point	Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	14.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	10,000	210
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	-	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	-	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	-	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	-	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-145943/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-145943
		Date Received	30 Jan 2021
		Date(s) Tested	30 Jan 2021 - 01 Feb 2021
		Date Reported	03 Feb 2021
Sample Description	L4, Cooling Tower -2		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	30.01.2021 / 10:20 AM
Sample Container	1x500ml PB	Sampling Point	Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	21.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	10,000	240
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	-	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	-	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	-	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	-	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-145944/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-145944
		Date Received	30 Jan 2021
		Date(s) Tested	30 Jan 2021 - 01 Feb 2021
		Date Reported	03 Feb 2021
Sample Description	L4, Cooling Tower -3		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	30.01.2021 / 10:30 AM
Sample Container	1x500ml PB	Sampling Point	Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	22°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	10,000	160
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	-	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	-	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	-	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	-	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-145945/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-145945
		Date Received	30 Jan 2021
		Date(s) Tested	30 Jan 2021 - 01 Feb 2021
ATTN : MR. JASMAN PINTO		Date Reported	03 Feb 2021
Sample Description	L4, Cooling Tower -4		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	30.01.2021 / 10:40 AM
Sample Container	1x500ml PB	Sampling Point	Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	24°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	10,000	180
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	-	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	-	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	-	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	-	Zero

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-145941/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-145941
		Date Received	30 Jan 2021
		Date(s) Tested	30 Jan 2021 - 01 Feb 2021
		Date Reported	03 Feb 2021
Sample Description	P1, Hydrotherapy Pool		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	30.01.2021 / 10:00 AM
Sample Container	Dipslide	Sampling Point	Pool
Sample Receipt Temp	4°C	Sample Onsite Temp	24°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL PARAMETERS				
Total bacterial count(Dip slide)	Kit Method	CFU/ml	1000	<1
Remarks	The sample meets DM Public swimming pool safety guidelines(2019,Doc Ref.:DM-PH&SD-GU81-PSPS2) specifications for Pool Water with respect to the above tests only.			
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, Doc Ref.: Document Reference			
Test method deviation	None			
Test performed by Emp#	103 & 14			
Report prepared by Emp#	72			
The above test results are only applicable to the sample(s) referred above.				

Reported By
ANILA GEORGE
LABORATORY MANAGER

This report is system generated,signature,stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-145946/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-145946
		Date Received	30 Jan 2021
		Date(s) Tested	30 Jan 2021 - 02 Feb 2021
ATTN : MR. JASMAN PINTO		Date Reported	07 Feb 2021
Sample Description	Copper - Silver Ionisation – P2 Water Tank # 06		
Sample Type	Water	Sampling Method	QMTL-SOP-128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	30.01.2021/ 10:40 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	18°C	Sample Onsite Temp	16°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
PHYSICAL PARAMETERS				
Conductivity*	APHA 2510 B-23rd Edition	µs/cm	-	208.5@24.2°C
pH*	APHA 4500 H+B-23rd Edition	-	Min 7.0-Max 9.2	7.55@24.2°C
Total Dissolved Solids*	APHA 2540-C-23rd Edition	mg/L	Min 100-Max 600	135
CHEMICAL PARAMETERS				
Calcium Hardness*	APHA 3500 Ca B-23rd Edition	mg/L	Max 200	56.5
Chloride*	APHA 4500 Cl ⁻ B-23rd Edition	mg/L	Max 250	42.0
Total Hardness as (CaCO ₃)*	APHA 2340-C-23rd Edition	mg/L	Max 300	62.5
METALS				
Copper*	APHA 3120 B-23rd Edition	mg/L	Max 1.0	<0.05
Iron*	APHA 3120 B-23rd Edition	mg/L	Max 0.20	<0.05
Silver*	APHA 3120 B-23rd Edition	mg/L	-	<0.05

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	--

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, DoE: Department of Energy, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
----------	---

Test method deviation	None
Test performed by Emp#	13
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-145947/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID		QMTL/S-145947
	Date Received		30 Jan 2021
	Date(s) Tested		30 Jan 2021 - 02 Feb 2021
	Date Reported		07 Feb 2021
ATTN : MR. JASMAN PINTO			
Sample Description	Copper - Silver Ionisation – P2 Water Tank # 05		
Sample Type	Water	Sampling Method	QMTL-SOP-128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	30.01.2021/ 10:45 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	18°C	Sample Onsite Temp	25°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
PHYSICAL PARAMETERS				
Conductivity*	APHA 2510 B-23rd Edition	µs/cm	-	209.1@24.2°C
pH*	APHA 4500 H+B-23rd Edition	-	Min 7.0-Max 9.2	7.68@24.2°C
Total Dissolved Solids*	APHA 2540-C-23rd Edition	mg/L	Min 100-Max 600	136
CHEMICAL PARAMETERS				
Calcium Hardness*	APHA 3500 Ca B-23rd Edition	mg/L	Max 200	58.1
Chloride*	APHA 4500 Cl ⁻ B-23rd Edition	mg/L	Max 250	43.0
Total Hardness as (CaCO ₃)*	APHA 2340-C-23rd Edition	mg/L	Max 300	66.0
METALS				
Copper*	APHA 3120 B-23rd Edition	mg/L	Max 1.0	<0.05
Iron*	APHA 3120 B-23rd Edition	mg/L	Max 0.20	<0.05
Silver*	APHA 3120 B-23rd Edition	mg/L	-	<0.05

The Analysis results denoted by (*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, DoE: Department of Energy, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
Test method deviation	None
Test performed by Emp#	13
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT