

TEST REPORT

Report No: QMTL/R-132428/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-132428
ATTN : MR. JASMAN PINTO		Date Received	04 Nov 2020
		Date(s) Tested	04 Nov 2020 - 06 Nov 2020
		Date Reported	09 Nov 2020
Sample Description	P1, Hydrotherapy Pool		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	04.11.2020 / 11:00 AM
Sample Container	Dipslide	Sampling Point	Pool
Sample Receipt Temp	4°C	Sample Onsite Temp	31.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total bacterial count(Dip slide)	Kit Method	CFU/ml	1000	<1
Remarks	The sample meets DM Public swimming pool safety guidelines(2019,Doc Ref.:DM-PH&SD-GU81-PSPS2) specifications for Pool Water with respect to the above tests only.			
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, Doc Ref.: Document Reference			
Test method deviation	None			
Test performed by Emp#	103 & 74			
Report prepared by Emp#	72			
The above test results are only applicable to the sample(s) referred above.				

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-132429/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-132429	
	Date Received	04 Nov 2020	
	Date(s) Tested	04 Nov 2020 - 06 Nov 2020	
	Date Reported	09 Nov 2020	
Sample Description	L4, Cooling Tower - 1		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	04.11.2020 / 11:30 AM
Sample Container	1x500ml PB	Sampling Point	Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	25°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10,000	70
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 74
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-132430/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-132430	
	Date Received	04 Nov 2020	
	Date(s) Tested	04 Nov 2020 - 06 Nov 2020	
	Date Reported	09 Nov 2020	
Sample Description	L4, Cooling Tower - 2		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	04.11.2020 / 11:40 AM
Sample Container	1x500ml PB	Sampling Point	Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	25.6°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10,000	110
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 74
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-132431/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-132431
		Date Received	04 Nov 2020
		Date(s) Tested	04 Nov 2020 - 06 Nov 2020
		Date Reported	09 Nov 2020
ATTN : MR. JASMAN PINTO			
Sample Description	L4, Cooling Tower - 3		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	04.11.2020 / 11:50 AM
Sample Container	1x500ml PB	Sampling Point	Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	28.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10,000	80
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 74
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-132432/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-132432
ATTN : MR. JASMAN PINTO		Date Received	04 Nov 2020
		Date(s) Tested	04 Nov 2020 - 06 Nov 2020
		Date Reported	09 Nov 2020
Sample Description	L4, Cooling Tower - 4		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	04.11.2020 / 12:00 PM
Sample Container	1x500ml PB	Sampling Point	Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	30°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10,000	30
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero
Fecal coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero

Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 74
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-132433/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-132433	
	Date Received	04 Nov 2020	
	Date(s) Tested	04 Nov 2020 - 07 Nov 2020	
	Date Reported	10 Nov 2020	
ATTN : MR. JASMAN PINTO			
Sample Description	Copper - Silver Ionisation – P2 Water Tank # 05		
Sample Type	Water	Sampling Method	QMTL-SOP-128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	04.11.2020 / 11:10 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	18°C	Sample Onsite Temp	32.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
CHEMICAL PARAMETERS				
Calcium Hardness	APHA 3500-Ca B (23rd Edition)	mg/L	Max 200	56.8
Chloride	APHA 4500 Cl ⁻ B (23rd Edition)	mg/L	Max 250	47.8
Conductivity	APHA 2510 B (23rd Edition)	µs/cm	-	210@24.1°C
pH	APHA 4500 H+B (23rd Edition)	-	Min 7.0-Max 9.2	7.52@24.1°C
Total Dissolved Solids	APHA 2540-C (23rd Edition)	mg/L	Min 100-Max 1000	136
Total Hardness as (CaCO ₃)	APHA 2340-C (23rd Edition)	mg/L	Max 300	62.7
METALS				
Copper	APHA 3120 B (23rd Edition)	mg/L	Max 1.0	<0.05
Iron	APHA 3120 B (23rd Edition)	mg/L	Max 0.20	<0.05
Silver	APHA 3120 B (23rd Edition)	mg/L	-	<0.05
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			
Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.			
Test method deviation	None			
Test performed by Emp#	13			
Report prepared by Emp#	22			
The above test results are only applicable to the sample(s) referred above.				

Reported By


ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-132434/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-132434	
	Date Received	04 Nov 2020	
	Date(s) Tested	04 Nov 2020 - 07 Nov 2020	
	Date Reported	10 Nov 2020	
ATTN : MR. JASMAN PINTO			
Sample Description	Copper - Silver Ionisation – P2 Water Tank # 06		
Sample Type	Water	Sampling Method	QMTL-SOP-128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	04.11.2020 / 11:20 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	18°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
CHEMICAL PARAMETERS				
Calcium Hardness	APHA 3500-Ca B (23rd Edition)	mg/L	Max 200	54.88
Chloride	APHA 4500 Cl ⁻ B (23rd Edition)	mg/L	Max 250	48.3
Conductivity	APHA 2510 B (23rd Edition)	µs/cm	-	211@24.1°C
pH	APHA 4500 H+B (23rd Edition)	-	Min 7.0-Max 9.2	7.42@24.1°C
Total Dissolved Solids	APHA 2540-C (23rd Edition)	mg/L	Min 100-Max 1000	137
Total Hardness as (CaCO ₃)	APHA 2340-C (23rd Edition)	mg/L	Max 300	60.7
METALS				
Copper	APHA 3120 B (23rd Edition)	mg/L	Max 1.0	<0.05
Iron	APHA 3120 B (23rd Edition)	mg/L	Max 0.20	<0.05
Silver	APHA 3120 B (23rd Edition)	mg/L	-	<0.05
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			
Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.			
Test method deviation	None			
Test performed by Emp#	13			
Report prepared by Emp#	22			
The above test results are only applicable to the sample(s) referred above.				

Reported By

ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT