



Microbiology Test Report

Customer Details

Report No. WA-R-L-2007-13499

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No.	: WA-Q-L-2007-02031	Sample No.	: WA-S-L-2007-13035
Sampling Date	: 06/07/2020	Report Date.	: 11/07/2020
Analysis Start Date.	: 06/07/2020	Analysis End Date.	: 09/07/2020
Sample Location.	: Rihan Heights Tower A - Zayed Sports City Abu Dhabi	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Certificate No	: 1237
Sampling Method	: APHA 9060 A & B	Temperature °C	: 27.1
Site Observation	: Clear	Sampling Container	: Sterile Plastic Bottle
Source of Sample	: 5th Floor Waste Room	Sampling Point	: Domestic Tap Water
Preservation	: 4-8°C	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.





Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2007-13498



Request No.	: WA-Q-L-2007-02031	Sample No.	: WA-S-L-2007-13034
Sampling Date	: 06/07/2020	Report Date.	: 11/07/2020
Analysis Start Date.	: 06/07/2020	Analysis End Date.	: 09/07/2020
Sample Location.	: Rihan Heights Tower A - Zayed Sports City Abu Dhabi	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Certificate No	: 1237
Sampling Method	: APHA 9060 A & B	Temperature °C	: 28.4
Site Observation	: Clear	Sampling Container	: Sterile Plastic Bottle
Source of Sample	: 4th Floor Waste Room	Sampling Point	: Domestic Tap Water
Preservation	: 4-8°C	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.





مختبرات ويمبي ذم م
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2007-13498

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2007-13497



Request No.	: WA-Q-L-2007-02031	Sample No.	: WA-S-L-2007-13033
Sampling Date	: 06/07/2020	Report Date.	: 11/07/2020
Analysis Start Date.	: 06/07/2020	Analysis End Date.	: 09/07/2020
Sample Location.	: Rihan Heights Tower A - Zayed Sports City Abu Dhabi	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Certificate No	: 1237
Sampling Method	: APHA 9060 A & B	Temperature °C	: 29.3
Site Observation	: Clear	Sampling Container	: Sterile Plastic Bottle
Source of Sample	: 3rd Floor Waste Room	Sampling Point	: Domestic Tap Water
Preservation	: 4-8°C	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100mi	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.





Microbiology Test Report

Report No. : WA-R-L-2007-13497

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -




Microbiology Test Report

Customer Details

Report No. WA-R-L-2007-13496

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No.	: WA-Q-L-2007-02031	Sample No.	: WA-S-L-2007-13032
Sampling Date	: 06/07/2020	Report Date.	: 11/07/2020
Analysis Start Date.	: 06/07/2020	Analysis End Date.	: 09/07/2020
Sample Location.	: Rihan Heights Tower A - Zayed Sports City Abu Dhabi	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Certificate No	: 1237
Sampling Method	: APHA 9060 A & B	Temperature °C	: 29.8
Site Observation	: Clear	Sampling Container	: Sterile Plastic Bottle
Source of Sample	: 2nd Floor Waste Room	Sampling Point	: Domestic Tap Water
Preservation	: 4-8°C	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H&I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.





Microbiology Test Report

Report No. : WA-R-L-2007-13496

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2007-13495

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No.	: WA-Q-L-2007-02031	Sample No.	: WA-S-L-2007-13031
Sampling Date	: 06/07/2020	Report Date.	: 11/07/2020
Analysis Start Date.	: 06/07/2020	Analysis End Date.	: 09/07/2020
Sample Location.	: Rihan Heights Tower A - Zayed Sports City Abu Dhabi	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Certificate No	: 1237
Sampling Method	: APHA 9060 A & B	Temperature °C	: 28.4
Site Observation	: Clear	Sampling Container	: Sterile Plastic Bottle
Source of Sample	: 1st Floor Waste Room	Sampling Point	: Domestic Tap Water
Preservation	: 4-8°C	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected= \leq 1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.





Microbiology Test Report

Report No. : WA-R-L-2007-13495

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2007-13506



Request No.	: WA-Q-L-2007-02031	Sample No.	: WA-S-L-2007-13042
Sampling Date	: 06/07/2020	Report Date.	: 16/07/2020
Analysis Start Date.	: 06/07/2020	Analysis End Date.	: 16/07/2020
Sample Location.	: Rihan Heights Tower A - Zayed Sports City Abu Dhabi	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Certificate No	: 1237
Sampling Method	: BS 7592	Temperature °C	: 27.1
Site Observation	: Clear	Sampling Container	: Sterile Plastic Bottle
Source of Sample	: 5th Floor Waste Room	Sampling Point	: Domestic Tap Water
Preservation	: 10°C	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection= \leq 1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2007-13505



Request No.	: WA-Q-L-2007-02031	Sample No.	: WA-S-L-2007-13041
Sampling Date	: 06/07/2020	Report Date.	: 16/07/2020
Analysis Start Date.	: 06/07/2020	Analysis End Date.	: 16/07/2020
Sample Location.	: Rihan Heights Tower A - Zayed Sports City Abu Dhabi	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Certificate No	: 1237
Sampling Method	: BS 7592	Temperature °C	: 28.4
Site Observation	: Clear	Sampling Container	: Sterile Plastic Bottle
Source of Sample	: 4th Floor Waste Room	Sampling Point	: Domestic Tap Water
Preservation	: 10°C	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2007-13504

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No.	: WA-Q-L-2007-02031	Sample No.	: WA-S-L-2007-13040
Sampling Date	: 06/07/2020	Report Date.	: 16/07/2020
Analysis Start Date.	: 06/07/2020	Analysis End Date.	: 16/07/2020
Sample Location.	: Rihan Heights Tower A - Zayed Sports City Abu Dhabi	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Certificate No	: 1237
Sampling Method	: BS 7592	Temperature °C	: 29.3
Site Observation	: Clear	Sampling Container	: Sterile Plastic Bottle
Source of Sample	: 3rd Floor Waste Room	Sampling Point	: Domestic Tap Water
Preservation	: 10°C	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2007-13503



Request No.	: WA-Q-L-2007-02031	Sample No.	: WA-S-L-2007-13039
Sampling Date	: 06/07/2020	Report Date.	: 16/07/2020
Analysis Start Date.	: 06/07/2020	Analysis End Date.	: 16/07/2020
Sample Location.	: Rihan Heights Tower A - Zayed Sports City Abu Dhabi	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Certificate No	: 1237
Sampling Method	: BS 7592	Temperature °C	: 29.8
Site Observation	: Clear	Sampling Container	: Sterile Plastic Bottle
Source of Sample	: 2nd Floor Waste Room	Sampling Point	: Domestic Tap Water
Preservation	: 10°C	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2007-13502



Request No.	: WA-Q-L-2007-02031	Sample No.	: WA-S-L-2007-13038
Sampling Date	: 06/07/2020	Report Date.	: 16/07/2020
Analysis Start Date.	: 06/07/2020	Analysis End Date.	: 16/07/2020
Sample Location.	: Rihan Heights Tower A - Zayed Sports City Abu Dhabi	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Certificate No	: 1237
Sampling Method	: BS 7592	Temperature °C	: 28.4
Site Observation	: Clear	Sampling Container	: Sterile Plastic Bottle
Source of Sample	: 1st Floor Waste Room	Sampling Point	: Domestic Tap Water
Preservation	: 10°C	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -