



**Customer Details**

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463

Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Request No. : WA-Q-O-2006-00197 Sample No. : WA-S-O-2006-00804

Sampling Date/time : 14/6/2020 , 16:15 Report Date. : 17/6/2020

Analysis Start Date. : 14/6/2020 Analysis End Date. : 14/6/2020

Sample Location. : ADIA - Headquarters, AUH Sampled By : Jyothish Krishnan

Sample Identification : Level 34 Wing A Office Area

Parameters	Test Methods	Units	Results	Specification
CARBON DIOXIDE	OTM: SECTION III-CHAPTER-02	ppm	510	30000 (STEL)
CARBON MONOXIDE	OTM: SECTION III-CHAPTER-02	ppm	1.90	25 (TWA)
FORMALDEHYDE	OTM: SECTION III-CHAPTER-02	ppm	ND	0.3 (STEL)
Humidity	BSEN 60079 - 29 - 2-2015	%	59.6	NA
OZONE	BSEN 60079-29-2:2015	ppm	ND	0.2 (TWA)
PARTICULATE MATTER (PM1.0))	ISO-21501-4:2018	µg/m3	2.24	NA
PARTICULATE MATTER (PM2.5).	ISO-21501-4:2018	ppm	4.72	NA
RSPM [PARTICULATE MATTER (PM10)]	ISO-21501-4:2018	ppm	13.26	NA
Temperature	BSEN 60079 - 29 - 2-2015	°C	21.8	NA
TOTAL SUSPENDED PARTICLES	ISO-21501-4:2018	µg/m3	25.38	NA
TVOC	OTM: SECTION III-CHAPTER-02	µg/m3	239	NA

Note : AD-OSHAD – Abu Dhabi Occupational Safety and Health System Framework Guideline version 3.0, July 2016

**Remarks :As per the above observation we have found that there is no gaseous contamination exceeding the limit in all monitoring areas, everything under the prescribed limit as per the given standard guideline of AD-OSHAD. The Dust concentration is also under the limit as per the guidelines of given standards limit.**

Analyst	Reviewed By	Method Variation
AK	NKS	None

Key Words :NA – Not Available in the OSHAD Guideline, ND-Not Detected, STEL- Short Term Exposure Limit,TWA-Time Weighted Average





مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387 **Test Report**



Testing - NAL 034

Report No. : WA-R-O-2006-00802

**Signed for and on behalf of Wimpey Laboratories**

*Nishi Kumar Shukla*



**Nishi Kumar Shukla**

Senior Environmental Chemist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-EN-02 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



# مختبرات ويمبي ذ م م Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387

Test Report



Testing - NAL 034

Report No. WA-R-O-2006-00803



## Customer Details

### CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463

Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Request No. : WA-Q-O-2006-00197

Sample No. : WA-S-O-2006-00805

Sampling Date/time : 14/6/2020 , 16:40

Report Date. : 17/6/2020

Analysis Start Date. : 14/6/2020

Analysis End Date. : 14/6/2020

Sample Location. : ADIA - Headquarters, AUH

Sampled By : Jyothish Krishnan

Sample Identification : Level 27 Wing A Office Area

Parameters	Test Methods	Units	Results	Specification
CARBON DIOXIDE	OTM: SECTION III-CHAPTER-02	ppm	518	30000 (STEL)
CARBON MONOXIDE	OTM: SECTION III-CHAPTER-02	ppm	2.80	25 (TWA)
FORMALDEHYDE	OTM: SECTION III-CHAPTER-02	ppm	ND	0.3 (STEL)
Humidity	BSEN 60079 - 29 - 2-2015	%	56.0	NA
OZONE	BSEN 60079-29-2:2015	ppm	ND	0.2 (TWA)
PARTICULATE MATTER (PM1.0))	ISO-21501-4:2018	µg/m3	3.30	NA
PARTICULATE MATTER (PM2.5).	ISO-21501-4:2018	ppm	8.80	NA
RSPM [PARTICULATE MATTER (PM10)]	ISO-21501-4:2018	ppm	21.66	NA
Temperature	BSEN 60079 - 29 - 2-2015	°C	24.4	NA
TOTAL SUSPENDED PARTICLES	ISO-21501-4:2018	µg/m3	28.81	NA
TVOC	OTM: SECTION III-CHAPTER-02	µg/m3	289	NA

Note : AD-OSHAD – Abu Dhabi Occupational Safety and Health System Framework Guideline version 3.0, July 2016

**Remarks :As per the above observation we have found that there is no gaseous contamination exceeding the limit in all monitoring areas, everything under the prescribed limit as per the given standard guideline of AD-OSHAD. The Dust concentration is also under the limit as per the guidelines of given standards limit.**

Analyst	Reviewed By	Method Variation
AK	NKS	None

Key Words :NA – Not Available in the OSHAD Guideline, ND-Not Detected, STEL- Short Term Exposure Limit,TWA- Time Weighted Average





مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387 **Test Report**



Testing - NAL 034

Report No. : WA-R-O-2006-00803

**Signed for and on behalf of Wimpey Laboratories**

*Nishi Shukla*



**Nishi Kumar Shukla**

Senior Environmental Chemist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-EN-02 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Customer Details**

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463

Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Request No. : WA-Q-O-2006-00197

Sample No. : WA-S-O-2006-00806

Sampling Date/time : 14/6/2020 , 17:10

Report Date. : 17/6/2020

Analysis Start Date. : 14/6/2020

Analysis End Date. : 14/6/2020

Sample Location. : ADIA - Headquarters, AUH

Sampled By : Jyothish Krishnan

Sample Identification : Level 21 Wing B Office Area

Parameters	Test Methods	Units	Results	Specification
CARBON DIOXIDE	OTM: SECTION III-CHAPTER-02	ppm	588	30000 (STEL)
CARBON MONOXIDE	OTM: SECTION III-CHAPTER-02	ppm	1.80	25 (TWA)
FORMALDEHYDE	OTM: SECTION III-CHAPTER-02	ppm	ND	0.3 (STEL)
Humidity	BSEN 60079 - 29 - 2-2015	%	57.5	NA
OZONE	BSEN 60079-29-2:2015	ppm	ND	0.2 (TWA)
PARTICULATE MATTER (PM1.0))	ISO-21501-4:2018	µg/m3	2.82	NA
PARTICULATE MATTER (PM2.5).	ISO-21501-4:2018	ppm	5.67	NA
RSPM [PARTICULATE MATTER (PM10)]	ISO-21501-4:2018	ppm	22.46	NA
Temperature	BSEN 60079 - 29 - 2-2015	°C	23.8	NA
TOTAL SUSPENDED PARTICLES	ISO-21501-4:2018	µg/m3	38.23	NA
TVOC	OTM: SECTION III-CHAPTER-02	µg/m3	293	NA

Note : AD-OSHAD – Abu Dhabi Occupational Safety and Health System Framework Guideline version 3.0, July 2016

**Remarks :As per the above observation we have found that there is no gaseous contamination exceeding the limit in all monitoring areas, everything under the prescribed limit as per the given standard guideline of AD-OSHAD. The Dust concentration is also under the limit as per the guidelines of given standards limit.**

Analyst	Reviewed By	Method Variation
AK	NKS	None

Key Words :NA – Not Available in the OSHAD Guideline, ND-Not Detected, STEL- Short Term Exposure Limit,TWA- Time Weighted Average





مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387 **Test Report**



Testing - NAL 034

Report No. : WA-R-O-2006-00804

**Signed for and on behalf of Wimpey Laboratories**

*Nishi Kumar Shukla*



**Nishi Kumar Shukla**

Senior Environmental Chemist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-EN-02 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



# مختبرات ويمبي ذ.م.م Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.  
Tel: +971 2 5503324, Fax: +971 2 5503387

**Test Report**



Testing - NAL 034

Report No. WA-R-O-2006-00805



## Customer Details

### CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463

Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Request No. : WA-Q-O-2006-00197

Sample No. : WA-S-O-2006-00807

Sampling Date/time : 14/6/2020 , 17:30

Report Date. : 17/6/2020

Analysis Start Date. : 14/6/2020

Analysis End Date. : 14/6/2020

Sample Location. : ADIA - Headquarters, AUH

Sampled By : Jyothish Krishnan

Sample Identification : Level 20 Wing A Office Area

Parameters	Test Methods	Units	Results	Specification
CARBON DIOXIDE	OTM: SECTION III-CHAPTER-02	ppm	539	30000 (STEL)
CARBON MONOXIDE	OTM: SECTION III-CHAPTER-02	ppm	2.23	25 (TWA)
FORMALDEHYDE	OTM: SECTION III-CHAPTER-02	ppm	ND	0.3 (STEL)
Humidity	BSEN 60079 - 29 - 2-2015	%	56.8	NA
OZONE	BSEN 60079-29-2:2015	ppm	ND	0.2 (TWA)
PARTICULATE MATTER (PM1.0))	ISO-21501-4:2018	µg/m3	2.86	NA
PARTICULATE MATTER (PM2.5).	ISO-21501-4:2018	ppm	3.93	NA
RSPM [PARTICULATE MATTER (PM10)]	ISO-21501-4:2018	ppm	26.72	NA
Temperature	BSEN 60079 - 29 - 2-2015	°C	23.1	NA
TOTAL SUSPENDED PARTICLES	ISO-21501-4:2018	µg/m3	45.38	NA
TVOC	OTM: SECTION III-CHAPTER-02	µg/m3	256	NA

Note : AD-OSHAD – Abu Dhabi Occupational Safety and Health System Framework Guideline version 3.0, July 2016

**Remarks :As per the above observation we have found that there is no gaseous contamination exceeding the limit in all monitoring areas, everything under the prescribed limit as per the given standard guideline of AD-OSHAD. The Dust concentration is also under the limit as per the guidelines of given standards limit.**

Analyst	Reviewed By	Method Variation
AK	NKS	None

Key Words :NA – Not Available in the OSHAD Guideline, ND-Not Detected, STEL- Short Term Exposure Limit,TWA- Time Weighted Average





مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387 **Test Report**



Testing - NAL 034

Report No. : WA-R-O-2006-00805

**Signed for and on behalf of Wimpey Laboratories**

*Nishi Shukla*

**Nishi Kumar Shukla**

Senior Environmental Chemist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-EN-02 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Customer Details**

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463

Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Request No. : WA-Q-O-2006-00197

Sample No. : WA-S-O-2006-00808

Sampling Date/time : 14/6/2020 , 17:50

Report Date. : 17/6/2020

Analysis Start Date. : 14/6/2020

Analysis End Date. : 14/6/2020

Sample Location. : ADIA - Headquarters, AUH

Sampled By : Jyothish Krishnan

Sample Identification : Level 15 Wing B Office Area

Parameters	Test Methods	Units	Results	Specification
CARBON DIOXIDE	OTM: SECTION III-CHAPTER-02	ppm	602	30000 (STEL)
CARBON MONOXIDE	OTM: SECTION III-CHAPTER-02	ppm	2.13	25 (TWA)
FORMALDEHYDE	OTM: SECTION III-CHAPTER-02	ppm	ND	0.3 (STEL)
Humidity	BSEN 60079 - 29 - 2-2015	%	57.5	NA
OZONE	BSEN 60079-29-2:2015	ppm	ND	0.2 (TWA)
PARTICULATE MATTER (PM1.0))	ISO-21501-4:2018	µg/m3	2.26	NA
PARTICULATE MATTER (PM2.5).	ISO-21501-4:2018	ppm	6.72	NA
RSPM [PARTICULATE MATTER (PM10)]	ISO-21501-4:2018	ppm	23.72	NA
Temperature	BSEN 60079 - 29 - 2-2015	°C	23.8	NA
TOTAL SUSPENDED PARTICLES	ISO-21501-4:2018	µg/m3	47.43	NA
TVOC	OTM: SECTION III-CHAPTER-02	µg/m3	276	NA

Note : AD-OSHAD – Abu Dhabi Occupational Safety and Health System Framework Guideline version 3.0, July 2016

**Remarks :As per the above observation we have found that there is no gaseous contamination exceeding the limit in all monitoring areas, everything under the prescribed limit as per the given standard guideline of AD-OSHAD. The Dust concentration is also under the limit as per the guidelines of given standards limit.**

Analyst	Reviewed By	Method Variation
AK	NKS	None

Key Words :NA – Not Available in the OSHAD Guideline, ND-Not Detected, STEL- Short Term Exposure Limit,TWA- Time Weighted Average





مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387 **Test Report**



Testing - NAL 034

Report No. : WA-R-O-2006-00806

**Signed for and on behalf of Wimpey Laboratories**

*Nishi Shukla*

**Nishi Kumar Shukla**

Senior Environmental Chemist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-EN-02 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



# مختبرات ويمبي ذ م م Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.  
Tel: +971 2 5503324, Fax: +971 2 5503387

Test Report



Testing - NAL 034

Report No. WA-R-O-2006-00807



## Customer Details

### CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463

Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Request No. : WA-Q-O-2006-00197

Sample No. : WA-S-O-2006-00809

Sampling Date/time : 14/6/2020 , 18:10

Report Date. : 17/6/2020

Analysis Start Date. : 14/6/2020

Analysis End Date. : 14/6/2020

Sample Location. : ADIA - Headquarters, AUH

Sampled By : Jyothish Krishnan

Sample Identification : Level 14 Wing A Office Area

Parameters	Test Methods	Units	Results	Specification
CARBON DIOXIDE	OTM: SECTION III-CHAPTER-02	ppm	563	30000 (STEL)
CARBON MONOXIDE	OTM: SECTION III-CHAPTER-02	ppm	1.91	25 (TWA)
FORMALDEHYDE	OTM: SECTION III-CHAPTER-02	ppm	ND	0.3 (STEL)
Humidity	BSEN 60079 - 29 - 2-2015	%	58.3	NA
OZONE	BSEN 60079-29-2:2015	ppm	ND	0.2 (TWA)
PARTICULATE MATTER (PM1.0))	ISO-21501-4:2018	µg/m3	1.50	NA
PARTICULATE MATTER (PM2.5).	ISO-21501-4:2018	ppm	4.78	NA
RSPM [PARTICULATE MATTER (PM10)]	ISO-21501-4:2018	ppm	22.62	NA
Temperature	BSEN 60079 - 29 - 2-2015	°C	22.8	NA
TOTAL SUSPENDED PARTICLES	ISO-21501-4:2018	µg/m3	45.38	NA
TVOC	OTM: SECTION III-CHAPTER-02	µg/m3	281	NA

Note : AD-OSHAD – Abu Dhabi Occupational Safety and Health System Framework Guideline version 3.0, July 2016

**Remarks :As per the above observation we have found that there is no gaseous contamination exceeding the limit in all monitoring areas, everything under the prescribed limit as per the given standard guideline of AD-OSHAD. The Dust concentration is also under the limit as per the guidelines of given standards limit.**

Analyst	Reviewed By	Method Variation
AK	NKS	None

Key Words :NA – Not Available in the OSHAD Guideline, ND-Not Detected, STEL- Short Term Exposure Limit,TWA-Time Weighted Average





مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387 **Test Report**



Testing - NAL 034

Report No. : WA-R-O-2006-00807

**Signed for and on behalf of Wimpey Laboratories**

*Nishi Shukla*



**Nishi Kumar Shukla**

Senior Environmental Chemist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-EN-02 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Customer Details**

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463

Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Request No. : WA-Q-O-2006-00197

Sample No. : WA-S-O-2006-00810

Sampling Date/time : 14/6/2020 , 18:30

Report Date. : 17/6/2020

Analysis Start Date. : 14/6/2020

Analysis End Date. : 14/6/2020

Sample Location. : ADIA - Headquarters, AUH

Sampled By : Jyothish Krishnan

Sample Identification : Level 12 Wing B Office Area

Parameters	Test Methods	Units	Results	Specification
CARBON DIOXIDE	OTM: SECTION III-CHAPTER-02	ppm	610	30000 (STEL)
CARBON MONOXIDE	OTM: SECTION III-CHAPTER-02	ppm	3.18	25 (TWA)
FORMALDEHYDE	OTM: SECTION III-CHAPTER-02	ppm	ND	0.3 (STEL)
Humidity	BSEN 60079 - 29 - 2-2015	%	57.3	NA
OZONE	BSEN 60079-29-2:2015	ppm	ND	0.2 (TWA)
PARTICULATE MATTER (PM1.0))	ISO-21501-4:2018	µg/m3	4.26	NA
PARTICULATE MATTER (PM2.5).	ISO-21501-4:2018	ppm	9.82	NA
RSPM [PARTICULATE MATTER (PM10)]	ISO-21501-4:2018	ppm	33.72	NA
Temperature	BSEN 60079 - 29 - 2-2015	°C	22.8	NA
TOTAL SUSPENDED PARTICLES	ISO-21501-4:2018	µg/m3	51.83	NA
TVOC	OTM: SECTION III-CHAPTER-02	µg/m3	234	NA

Note : AD-OSHAD – Abu Dhabi Occupational Safety and Health System Framework Guideline version 3.0, July 2016

**Remarks :As per the above observation we have found that there is no gaseous contamination exceeding the limit in all monitoring areas, everything under the prescribed limit as per the given standard guideline of AD-OSHAD. The Dust concentration is also under the limit as per the guidelines of given standards limit.**

Analyst	Reviewed By	Method Variation
AK	NKS	None

Key Words :NA – Not Available in the OSHAD Guideline, ND-Not Detected, STEL- Short Term Exposure Limit,TWA- Time Weighted Average





مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387 **Test Report**



Testing - NAL 034

Report No. : WA-R-O-2006-00808

**Signed for and on behalf of Wimpey Laboratories**

*Nishi Kumar Shukla*



**Nishi Kumar Shukla**

Senior Environmental Chemist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-EN-02 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



# مختبرات ويمبي ذ م م Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.  
Tel: +971 2 5503324, Fax: +971 2 5503387

**Test Report**



Testing - NAL 034

Report No. WA-R-O-2006-00809



## Customer Details

### CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463

Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Request No. : WA-Q-O-2006-00197

Sample No. : WA-S-O-2006-00811

Sampling Date/time : 14/6/2020 , 18:50

Report Date. : 17/6/2020

Analysis Start Date. : 14/6/2020

Analysis End Date. : 14/6/2020

Sample Location. : ADIA - Headquarters, AUH

Sampled By : Jyothish Krishnan

Sample Identification : Level 09 Wing B Office Area

Parameters	Test Methods	Units	Results	Specification
CARBON DIOXIDE	OTM: SECTION III-CHAPTER-02	ppm	572	30000 (STEL)
CARBON MONOXIDE	OTM: SECTION III-CHAPTER-02	ppm	1.76	25 (TWA)
FORMALDEHYDE	OTM: SECTION III-CHAPTER-02	ppm	ND	0.3 (STEL)
Humidity	BSEN 60079 - 29 - 2-2015	%	57.3	NA
OZONE	BSEN 60079-29-2:2015	ppm	ND	0.2 (TWA)
PARTICULATE MATTER (PM1.0))	ISO-21501-4:2018	µg/m3	3.82	NA
PARTICULATE MATTER (PM2.5).	ISO-21501-4:2018	ppm	12.36	NA
RSPM [PARTICULATE MATTER (PM10)]	ISO-21501-4:2018	ppm	38.26	NA
Temperature	BSEN 60079 - 29 - 2-2015	°C	22.8	NA
TOTAL SUSPENDED PARTICLES	ISO-21501-4:2018	µg/m3	48.38	NA
TVOC	OTM: SECTION III-CHAPTER-02	µg/m3	269	NA

Note : AD-OSHAD – Abu Dhabi Occupational Safety and Health System Framework Guideline version 3.0, July 2016

**Remarks :As per the above observation we have found that there is no gaseous contamination exceeding the limit in all monitoring areas, everything under the prescribed limit as per the given standard guideline of AD-OSHAD. The Dust concentration is also under the limit as per the guidelines of given standards limit.**

Analyst	Reviewed By	Method Variation
AK	NKS	None

Key Words :NA – Not Available in the OSHAD Guideline, ND-Not Detected, STEL- Short Term Exposure Limit,TWA- Time Weighted Average





مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387 **Test Report**




Testing - NAL 034

Report No. : WA-R-O-2006-00809

**Signed for and on behalf of Wimpey Laboratories**

*Nishi Kumar Shukla*



**Nishi Kumar Shukla**

Senior Environmental Chemist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-EN-02 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



# مختبرات ويمبي ذ م م Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387

Test Report



Testing - NAL 034

Report No. WA-R-O-2006-00810



## Customer Details

### CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463

Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Request No. : WA-Q-O-2006-00197

Sample No. : WA-S-O-2006-00812

Sampling Date/time : 14/6/2020 , 19:10

Report Date. : 17/6/2020

Analysis Start Date. : 14/6/2020

Analysis End Date. : 14/6/2020

Sample Location. : ADIA - Headquarters, AUH

Sampled By : Jyothish Krishnan

Sample Identification : Level 07 Wing B Office Area

Parameters	Test Methods	Units	Results	Specification
CARBON DIOXIDE	OTM: SECTION III-CHAPTER-02	ppm	513	30000 (STEL)
CARBON MONOXIDE	OTM: SECTION III-CHAPTER-02	ppm	1.38	25 (TWA)
FORMALDEHYDE	OTM: SECTION III-CHAPTER-02	ppm	ND	0.3 (STEL)
Humidity	BSEN 60079 - 29 - 2-2015	%	55.6	NA
OZONE	BSEN 60079-29-2:2015	ppm	ND	0.2 (TWA)
PARTICULATE MATTER (PM1.0))	ISO-21501-4:2018	µg/m3	7.42	NA
PARTICULATE MATTER (PM2.5).	ISO-21501-4:2018	ppm	9.63	NA
RSPM [PARTICULATE MATTER (PM10)]	ISO-21501-4:2018	ppm	22.46	NA
Temperature	BSEN 60079 - 29 - 2-2015	°C	23.8	NA
TOTAL SUSPENDED PARTICLES	ISO-21501-4:2018	µg/m3	48.72	NA
TVOC	OTM: SECTION III-CHAPTER-02	µg/m3	189	NA

Note : AD-OSHAD – Abu Dhabi Occupational Safety and Health System Framework Guideline version 3.0, July 2016

**Remarks :As per the above observation we have found that there is no gaseous contamination exceeding the limit in all monitoring areas, everything under the prescribed limit as per the given standard guideline of AD-OSHAD. The Dust concentration is also under the limit as per the guidelines of given standards limit.**

Analyst	Reviewed By	Method Variation
AK	NKS	None

Key Words :NA – Not Available in the OSHAD Guideline, ND-Not Detected, STEL- Short Term Exposure Limit,TWA- Time Weighted Average





مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387

**Test Report**



Testing - NAL 034

Report No. : WA-R-O-2006-00810

**Signed for and on behalf of Wimpey Laboratories**

*Nishi Kumar Shukla*



**Nishi Kumar Shukla**

Senior Environmental Chemist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-EN-02 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Customer Details

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463

Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Request No.	: WA-Q-O-2006-00197	Sample No.	: WA-S-O-2006-00813
Sampling Date/time	: 14/6/2020 , 19:30	Report Date.	: 17/6/2020
Analysis Start Date.	: 14/6/2020	Analysis End Date.	: 14/6/2020
Sample Location.	: ADIA - Headquarters, AUH	Sampled By	: Jyothish Krishnan
Sample Identification	: Level 06 Wing A Office Area		

Parameters	Test Methods	Units	Results	Specification
CARBON DIOXIDE	OTM: SECTION III-CHAPTER-02	ppm	591	30000 (STEL)
CARBON MONOXIDE	OTM: SECTION III-CHAPTER-02	ppm	1.21	25 (TWA)
FORMALDEHYDE	OTM: SECTION III-CHAPTER-02	ppm	ND	0.3 (STEL)
Humidity	BSEN 60079 - 29 - 2-2015	%	57.8	NA
OZONE	BSEN 60079-29-2:2015	ppm	ND	0.2 (TWA)
PARTICULATE MATTER (PM1.0))	ISO-21501-4:2018	µg/m3	2.73	NA
PARTICULATE MATTER (PM2.5).	ISO-21501-4:2018	ppm	5.82	NA
RSPM [PARTICULATE MATTER (PM10)]	ISO-21501-4:2018	ppm	15.72	NA
Temperature	BSEN 60079 - 29 - 2-2015	°C	22.7	NA
TOTAL SUSPENDED PARTICLES	ISO-21501-4:2018	µg/m3	38.48	NA
TVOC	OTM: SECTION III-CHAPTER-02	µg/m3	289	NA

Note : AD-OSHAD – Abu Dhabi Occupational Safety and Health System Framework Guideline version 3.0, July 2016

**Remarks :As per the above observation we have found that there is no gaseous contamination exceeding the limit in all monitoring areas, everything under the prescribed limit as per the given standard guideline of AD-OSHAD. The Dust concentration is also under the limit as per the guidelines of given standards limit.**

Analyst	Reviewed By	Method Variation
AK	NKS	None

Key Words :NA – Not Available in the OSHAD Guideline, ND-Not Detected, STEL- Short Term Exposure Limit,TWA- Time Weighted Average





مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387

**Test Report**



Testing - NAL 034

Report No. : WA-R-O-2006-00811

**Signed for and on behalf of Wimpey Laboratories**

*Nishi Shukla*



**Nishi Kumar Shukla**

Senior Environmental Chemist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-EN-02 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Customer Details

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463

Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Request No. : WA-Q-O-2006-00197 Sample No. : WA-S-O-2006-00814

Sampling Date/time : 14/6/2020 , 19:50 Report Date. : 17/6/2020

Analysis Start Date. : 14/6/2020 Analysis End Date. : 14/6/2020

Sample Location. : ADIA - Headquarters, AUH Sampled By : Jyothish Krishnan

Sample Identification : Level 03 Wing A Office Area

Parameters	Test Methods	Units	Results	Specification
CARBON DIOXIDE	OTM: SECTION III-CHAPTER-02	ppm	519	30000 (STEL)
CARBON MONOXIDE	OTM: SECTION III-CHAPTER-02	ppm	1.13	25 (TWA)
FORMALDEHYDE	OTM: SECTION III-CHAPTER-02	ppm	ND	0.3 (STEL)
Humidity	BSEN 60079 - 29 - 2-2015	%	58.8	NA
OZONE	BSEN 60079-29-2:2015	ppm	ND	0.2 (TWA)
PARTICULATE MATTER (PM1.0))	ISO-21501-4:2018	µg/m3	3.68	NA
PARTICULATE MATTER (PM2.5).	ISO-21501-4:2018	ppm	6.72	NA
RSPM [PARTICULATE MATTER (PM10)]	ISO-21501-4:2018	ppm	32.75	NA
Temperature	BSEN 60079 - 29 - 2-2015	°C	22.8	NA
TOTAL SUSPENDED PARTICLES	ISO-21501-4:2018	µg/m3	48.34	NA
TVOC	OTM: SECTION III-CHAPTER-02	µg/m3	279	NA

Note : AD-OSHAD – Abu Dhabi Occupational Safety and Health System Framework Guideline version 3.0, July 2016

**Remarks :As per the above observation we have found that there is no gaseous contamination exceeding the limit in all monitoring areas, everything under the prescribed limit as per the given standard guideline of AD-OSHAD. The Dust concentration is also under the limit as per the guidelines of given standards limit.**

Analyst	Reviewed By	Method Variation
AK	NKS	None

Key Words :NA – Not Available in the OSHAD Guideline, ND-Not Detected, STEL- Short Term Exposure Limit,TWA-Time Weighted Average





مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387 **Test Report**



Testing - NAL 034

Report No. : WA-R-O-2006-00812

**Signed for and on behalf of Wimpey Laboratories**

*Nishi Shukla*



**Nishi Kumar Shukla**

Senior Environmental Chemist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-EN-02 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Customer Details

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463

Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Request No. : WA-Q-O-2006-00197 Sample No. : WA-S-O-2006-00815

Sampling Date/time : 14/6/2020 , 20:10 Report Date. : 17/6/2020

Analysis Start Date. : 14/6/2020 Analysis End Date. : 14/6/2020

Sample Location. : ADIA - Headquarters, AUH Sampled By : Jyothish Krishnan

Sample Identification : Level 02 Wing B Office Area

Parameters	Test Methods	Units	Results	Specification
CARBON DIOXIDE	OTM: SECTION III-CHAPTER-02	ppm	558	30000 (STEL)
CARBON MONOXIDE	OTM: SECTION III-CHAPTER-02	ppm	1.72	25 (TWA)
FORMALDEHYDE	OTM: SECTION III-CHAPTER-02	ppm	ND	0.3 (STEL)
Humidity	BSEN 60079 - 29 - 2-2015	%	57.8	NA
OZONE	BSEN 60079-29-2:2015	ppm	ND	0.2 (TWA)
PARTICULATE MATTER (PM1.0))	ISO-21501-4:2018	µg/m3	1.26	NA
PARTICULATE MATTER (PM2.5).	ISO-21501-4:2018	ppm	3.87	NA
RSPM [PARTICULATE MATTER (PM10)]	ISO-21501-4:2018	ppm	12.38	NA
Temperature	BSEN 60079 - 29 - 2-2015	°C	22.8	NA
TOTAL SUSPENDED PARTICLES	ISO-21501-4:2018	µg/m3	26.48	NA
TVOC	OTM: SECTION III-CHAPTER-02	µg/m3	266	NA

Note : AD-OSHAD – Abu Dhabi Occupational Safety and Health System Framework Guideline version 3.0, July 2016

**Remarks :As per the above observation we have found that there is no gaseous contamination exceeding the limit in all monitoring areas, everything under the prescribed limit as per the given standard guideline of AD-OSHAD. The Dust concentration is also under the limit as per the guidelines of given standards limit.**

Analyst	Reviewed By	Method Variation
AK	NKS	None

Key Words :NA – Not Available in the OSHAD Guideline, ND-Not Detected, STEL- Short Term Exposure Limit,TWA- Time Weighted Average





مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387 **Test Report**



Testing - NAL 034

Report No. : WA-R-O-2006-00813

**Signed for and on behalf of Wimpey Laboratories**

*Nishi Shukla*



**Nishi Kumar Shukla**

Senior Environmental Chemist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-EN-02 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Customer Details**

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463

Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Request No. : WA-Q-O-2006-00197 Sample No. : WA-S-O-2006-00816

Sampling Date/time : 14/6/2020 , 20:30 Report Date. : 17/6/2020

Analysis Start Date. : 14/6/2020 Analysis End Date. : 14/6/2020

Sample Location. : ADIA - Headquarters, AUH Sampled By : Jyothish Krishnan

Sample Identification : Ground Floor Lobby Area

Parameters	Test Methods	Units	Results	Specification
CARBON DIOXIDE	OTM: SECTION III-CHAPTER-02	ppm	613	30000 (STEL)
CARBON MONOXIDE	OTM: SECTION III-CHAPTER-02	ppm	1.76	25 (TWA)
FORMALDEHYDE	OTM: SECTION III-CHAPTER-02	ppm	ND	0.3 (STEL)
Humidity	BSEN 60079 - 29 - 2-2015	%	51.2	NA
OZONE	BSEN 60079-29-2:2015	ppm	ND	0.2 (TWA)
PARTICULATE MATTER (PM1.0))	ISO-21501-4:2018	µg/m3	2.46	NA
PARTICULATE MATTER (PM2.5).	ISO-21501-4:2018	ppm	7.28	NA
RSPM [PARTICULATE MATTER (PM10)]	ISO-21501-4:2018	ppm	28.32	NA
Temperature	BSEN 60079 - 29 - 2-2015	°C	23.2	NA
TOTAL SUSPENDED PARTICLES	ISO-21501-4:2018	µg/m3	56.72	NA
TVOC	OTM: SECTION III-CHAPTER-02	µg/m3	248	NA

Note : AD-OSHAD – Abu Dhabi Occupational Safety and Health System Framework Guideline version 3.0, July 2016

**Remarks :As per the above observation we have found that there is no gaseous contamination exceeding the limit in all monitoring areas, everything under the prescribed limit as per the given standard guideline of AD-OSHAD. The Dust concentration is also under the limit as per the guidelines of given standards limit.**

Analyst	Reviewed By	Method Variation
AK	NKS	None

Key Words :NA – Not Available in the OSHAD Guideline, ND-Not Detected, STEL- Short Term Exposure Limit,TWA- Time Weighted Average





مختبرات ويمبي ذ م م  
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.

Tel: +971 2 5503324, Fax: +971 2 5503387

**Test Report**




Testing - NAL 034

Report No. : WA-R-O-2006-00814

**Signed for and on behalf of Wimpey Laboratories**

*Nishi Kumar Shukla*



**Nishi Kumar Shukla**

Senior Environmental Chemist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-EN-02 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**MICROBIOLOGY AIR MONITORING TEST REPORT**

**Customer Details**

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942

Report No. WA-R-O-2006-00822



Request No.	: WA-Q-O-2006-00198	Sample No.	: WA-S-O-2006-00824
Sampling Date	: 14/06/2020	Report Date.	: 20/6/2020
Analysis Start Date.	: 14/06/2020	Analysis End Date.	: 19/6/2020
Sample Location.	: ADIA - Headquarters, AUH	Sampled By	: Jyothish Krishnan
Sample Identification	: Ground Floor Lobby Area	Sample Certificate No	: 0615
Client Reference	: N/A		

Parameters	Test Methods	Units	Results	Specification
TBC	CCFRA 1.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	06	1000CFU/M <sup>3</sup>
Yeast and Mould	CCFRA 2.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	Not Detected	1000CFU/M <sup>3</sup>

Note : Not Detected= $\leq$ 1CFU/M<sup>3</sup>

Limit based on: ADNOC-COPV3-07 Technical Guidelines note on indoor air quality & indoor environments for airborne biological agents.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-19 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**MICROBIOLOGY AIR MONITORING TEST REPORT**

**Customer Details**

Report No. WA-R-O-2006-00821

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942



Request No.	: WA-Q-O-2006-00198	Sample No.	: WA-S-O-2006-00823
Sampling Date	: 14/06/2020	Report Date.	: 20/6/2020
Analysis Start Date.	: 14/06/2020	Analysis End Date.	: 19/6/2020
Sample Location.	: ADIA - Headquarters, AUH	Sampled By	: Jyothish Krishnan
Sample Identification	: Level 07 Wing B Office Area	Sample Certificate No	: 0615
Client Reference	: N/A		

Parameters	Test Methods	Units	Results	Specification
TBC	CCFRA 1.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	25	1000CFU/M <sup>3</sup>
Yeast and Mould	CCFRA 2.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	Not Detected	1000CFU/M <sup>3</sup>

Note : Not Detected= $<1$ CFU/M<sup>3</sup>

Limit based on: ADNOC-COPV3-07 Technical Guidelines note on indoor air quality & indoor environments for airborne biological agents.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-19 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**MICROBIOLOGY AIR MONITORING TEST REPORT**

**Customer Details**

Report No. WA-R-O-2006-00820

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942



Request No.	: WA-Q-O-2006-00198	Sample No.	: WA-S-O-2006-00822
Sampling Date	: 14/06/2020	Report Date.	: 20/6/2020
Analysis Start Date.	: 14/06/2020	Analysis End Date.	: 19/6/2020
Sample Location.	: ADIA - Headquarters, AUH	Sampled By	: Jyothish Krishnan
Sample Identification	: Level 09 Wing A Office Area	Sample Certificate No	: 0615
Client Reference	: N/A		

Parameters	Test Methods	Units	Results	Specification
TBC	CCFRA 1.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	29	1000CFU/M <sup>3</sup>
Yeast and Mould	CCFRA 2.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	Not Detected	1000CFU/M <sup>3</sup>

Note : Not Detected= $\leq$ 1CFU/CFU/M<sup>3</sup>

Limit based on: ADNOC-COPV3-07 Technical Guidelines note on indoor air quality & indoor environments for airborne biological agents.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-19 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**MICROBIOLOGY AIR MONITORING TEST REPORT**

**Customer Details**

Report No. WA-R-O-2006-00819

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942



Request No. : WA-Q-O-2006-00198 Sample No. : WA-S-O-2006-00821

Sampling Date : 14/06/2020 Report Date. : 20/6/2020

Analysis Start Date. : 14/06/2020 Analysis End Date. : 19/6/2020

Sample Location. : ADIA - Headquarters, AUH Sampled By : Jyothish Krishnan

Sample Identification : Level 20 Wing B Office Area Sample Certificate No : 0615

Client Reference : N/A

Parameters	Test Methods	Units	Results	Specification
TBC	CCFRA 1.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	30	1000CFU/M <sup>3</sup>
Yeast and Mould	CCFRA 2.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	Not Detected	1000CFU/M <sup>3</sup>

Note : Not Detected= $<1$ CFU/M<sup>3</sup>

Limit based on: ADNOC-COPV3-07 Technical Guidelines note on indoor air quality & indoor environments for airborne biological agents.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-19 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**MICROBIOLOGY AIR MONITORING TEST REPORT**

**Customer Details**

Report No. WA-R-O-2006-00818

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942



Request No.	: WA-Q-O-2006-00198	Sample No.	: WA-S-O-2006-00820
Sampling Date	: 14/06/2020	Report Date.	: 20/6/2020
Analysis Start Date.	: 14/06/2020	Analysis End Date.	: 19/6/2020
Sample Location.	: ADIA - Headquarters, AUH	Sampled By	: Jyothish Krishnan
Sample Identification	: Level 21 Wing A Office Area	Sample Certificate No	: 0615
Client Reference	: N/A		

Parameters	Test Methods	Units	Results	Specification
TBC	CCFRA 1.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	37	1000CFU/M <sup>3</sup>
Yeast and Mould	CCFRA 2.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	03	1000CFU/M <sup>3</sup>

Note : Limit based on: ADNOC-COPV3-07 Technical Guidelines note on indoor air quality & indoor environments for airborne biological agents.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-19 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



MICROBIOLOGY AIR MONITORING TEST REPORT

Customer Details

Report No. WA-R-O-2006-00817

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942



Request No. : WA-Q-O-2006-00198

Sample No. : WA-S-O-2006-00819

Sampling Date : 14/06/2020

Report Date. : 20/6/2020

Analysis Start Date. : 14/06/2020

Analysis End Date. : 19/6/2020

Sample Location. : ADIA - Headquarters, AUH

Sampled By : Jyothish Krishnan

Sample Identification : Level 27 Wing A Office Area

Sample Certificate No : 0615

Client Reference : N/A

Parameters	Test Methods	Units	Results	Specification
TBC	CCFRA 1.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	44	1000CFU/M <sup>3</sup>
Yeast and Mould	CCFRA 2.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	05	1000CFU/M <sup>3</sup>

Note : Limit based on: ADNOC-COPV3-07 Technical Guidelines note on indoor air quality & indoor environments for airborne biological agents.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-19 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



MICROBIOLOGY AIR MONITORING TEST REPORT

Customer Details

Report No. WA-R-O-2006-00816

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971  
265 08930; Fax: 971 265 8942



Request No. : WA-Q-O-2006-00198 Sample No. : WA-S-O-2006-00818

Sampling Date : 14/06/2020 Report Date. : 20/6/2020

Analysis Start Date. : 14/06/2020 Analysis End Date. : 19/6/2020

Sample Location. : ADIA - Headquarters, AUH Sampled By : Jyothish Krishnan

Sample Identification : Level 33 Wing A Office Area Sample Certificate No : 0615

Client Reference : N/A

Parameters	Test Methods	Units	Results	Specification
TBC	CCFRA 1.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	Not Detected	1000CFU/M <sup>3</sup>
Yeast and Mould	CCFRA 2.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	05	1000CFU/M <sup>3</sup>

Note : Not Detected= $\leq$ 1CFU/M<sup>3</sup>

Limit based on: ADNOC-COPV3-07 Technical Guidelines note on indoor air quality & indoor environments for airborne biological agents.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-19 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**MICROBIOLOGY AIR MONITORING TEST REPORT**

**Customer Details**

Report No. WA-R-O-2006-00815

**CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax: 971 265 8942



Request No.	: WA-Q-O-2006-00198	Sample No.	: WA-S-O-2006-00817
Sampling Date	: 14/06/2020	Report Date.	: 20/6/2020
Analysis Start Date.	: 14/06/2020	Analysis End Date.	: 19/6/2020
Sample Location.	: ADIA - Headquarters, AUH	Sampled By	: Jyothish Krishnan
Sample Identification	: Level 34 Wing A Office Area	Sample Certificate No	: 0615
Client Reference	: N/A		

Parameters	Test Methods	Units	Results	Specification
TBC	CCFRA 1.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	36	1000CFU/M <sup>3</sup>
Yeast and Mould	CCFRA 2.1.1 5th Ed. 2007	CFU/M <sup>3</sup>	10	1000CFU/M <sup>3</sup>

Note : Limit based on: ADNOC-COPV3-07 Technical Guidelines note on indoor air quality & indoor environments for airborne biological agents.

**Remarks :The tested results of the sample are found to be satisfactory within the specified limits.**

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

**Dr. Suresh Murugan Ph.D**

Senior Microbiologist



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-19 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -