

SWIMMING POOL - WATER ANALYSIS REPORT

Client Name: TAFAWUQ FACILITY MANAGEMENT, ABU DHABI			
Site Name:	AL BATEEN PARK	Visit Date:	03.05.2020
Sampled By:	Crystalline Rep.	Last Visit:	08.04.2020
Source of Sample	Swimming Pool	Sample Point	Main Swimming Pool

TEST RESULT

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.48
2	Conductivity at 25°C, µs/cm	---	276
3	TDS, ppm	Max 1500	179
4	Alkalinity	80 - 120	67
5	Calcium Hardness	200 - 500	152
6	Residual Chlorine	1.0 - 3.0	1.06
7	Cyanuric Acid	20 - 60	24
8	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

- Parameters are within control limit – No action Recommended.
- Calcium Hardness & alkalinity levels are low.

Reported By,

P. Murugan
Murugan
Service Engineer

