



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31263



Request No. : WA-Q-L-2101-04421

Sample No. : WA-S-L-2101-30618

Sampling Date	: 02/01/2021	Report Date.	: 04/01/2021
Analysis Start Date.	: 02/01/2021	Analysis End Date.	: 04/01/2021
Sample Location.	: Al Noor Tower	Sampled By	: Client
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Applicable
Site Observation	: Not Given	Sampling Container	: Plastic Bottle
Source of Sample	: Main Pool	Sampling Point	: Not Given
Intended Use	: Not Applicable	Sample Description	: Pool Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H&I 23rd Ed. 2017	CFU/100ml	Not Detected	--
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	1000CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limit based on: Guide to the Executive Regulations of Law No.(2) for the year of 2012 (Swimming Pool), Issued by the Head of Urban Planning and Municipalities No.(3) for the year 2018, Page No.3.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2101-31264

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2101-04421

Sample No. : WA-S-L-2101-30618

Sampling Date	: 02/01/2021	Report Date.	: 12/01/2021
Analysis Start Date.	: 02/01/2021	Analysis End Date.	: 12/01/2021
Sample Location.	: Al Noor Tower	Sampled By	: Client
Sample Identification	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: Not Given	Sampling Method	: Not Applicable
Site Observation	: Not Given	Sampling Container	: Plastic Bottle
Source of Sample	: Main Pool	Sampling Point	: Not Given
Intended Use	: Not Applicable	Sample Description	: Pool Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	<1CFU/L

Note : Not Detected=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter followed by Washing Procedure in Funnel.

Limit based on DM.Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SN	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D.

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



CRYSTALLINE ENVIRONMENTAL SERVICES

Water Analysis Report

Client Name: Tafawuq Facility Management, Abu Dhabi			
Site Name:	Al Noor Tower	Visit Date:	02-01-2021
Source Of Sample	Swimming Pool	Sample Point	Main Swimming Pool

SWIMMING POOL ANALYSIS

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.53
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	---	574
3	TDS, ppm	Max 1500	373
4	Alkalinity	80 - 120	89
5	Calcium Hardness	200 - 500	212
6	Residual Chlorine	1.0 - 3.0	1.17
7	Cyanuric Acid	20 - 60	26
8	Dip slide	$<10^3$	ND

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

- All Parameters are within control limit - No action recommended

Reported By,

Murugara
Service Engineer

