

TEST REPORT

Report No: QMTL/R-97338/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-97338
		Date Received	12 Mar 2020
		Date(s) Tested	12 Mar 2020 - 22 Mar 2020
		Date Reported	23 Mar 2020
Sample Description	Zone 5, Ground Floor, C6-1-TA-3, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	12.03.2020/11:00 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	20°C	Sample Onsite Temp	29.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media:- BCYE Agar.
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 55
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97339/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-97339
		Date Received	12 Mar 2020
		Date(s) Tested	12 Mar 2020 - 22 Mar 2020
		Date Reported	23 Mar 2020
Sample Description	Zone 5, Ground Floor, C7-1-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	12.03.2020/11:07 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	20°C	Sample Onsite Temp	31°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media:- BCYE Agar.
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97340/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97340	
	Date Received	12 Mar 2020	
	Date(s) Tested	12 Mar 2020 - 22 Mar 2020	
	Date Reported	23 Mar 2020	
Sample Description	Zone 5, Ground Floor, C8-1-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	12.03.2020/11:15 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	20°C	Sample Onsite Temp	25.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media:- BCYE Agar.
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 55
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97341/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97341	
	Date Received	12 Mar 2020	
	Date(s) Tested	12 Mar 2020 - 22 Mar 2020	
	Date Reported	23 Mar 2020	
Sample Description	Zone 5, Ground Floor, C9-1-TA2 & C9.25-TA.2 RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	12.03.2020/11:25 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	20°C	Sample Onsite Temp	27.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media:- BCYE Agar.
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 55
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97342/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97342	
	Date Received	12 Mar 2020	
	Date(s) Tested	12 Mar 2020 - 22 Mar 2020	
	Date Reported	23 Mar 2020	
Sample Description	Zone 5, Ground Floor,C10-1-TA-1 & C10-2-TA-1 RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	12.03.2020/11:40 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	20°C	Sample Onsite Temp	29°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media:- BCYE Agar.
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97343/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97343	
	Date Received	12 Mar 2020	
	Date(s) Tested	12 Mar 2020 - 22 Mar 2020	
	Date Reported	23 Mar 2020	
Sample Description	Zone 5, Ground Floor,C11-1-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	12.03.2020/11:50 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	20°C	Sample Onsite Temp	25.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media:- BCYE Agar.
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 55
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97344/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97344	
	Date Received	12 Mar 2020	
	Date(s) Tested	12 Mar 2020 - 22 Mar 2020	
	Date Reported	23 Mar 2020	
Sample Description	Zone 5, Ground Floor,C12-1-TA-1 & C12-2-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	12.03.2020/12:00 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	20°C	Sample Onsite Temp	24.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media:- BCYE Agar.
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 55
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97345/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97345	
	Date Received	12 Mar 2020	
	Date(s) Tested	12 Mar 2020 - 22 Mar 2020	
	Date Reported	23 Mar 2020	
Sample Description	Zone 5, Ground Floor, C13-1-TA-1 & C13-2-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	12.03.2020/12:15 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	20°C	Sample Onsite Temp	28.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media:- BCYE Agar.
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 55
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97346/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97346	
	Date Received	12 Mar 2020	
	Date(s) Tested	12 Mar 2020 - 22 Mar 2020	
	Date Reported	23 Mar 2020	
Sample Description	Zone 5, Ground Floor, C14-1-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	12.03.2020/12:25 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	20°C	Sample Onsite Temp	24.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media:- BCYE Agar.
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 55
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97347/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97347	
	Date Received	12 Mar 2020	
	Date(s) Tested	12 Mar 2020 - 22 Mar 2020	
	Date Reported	23 Mar 2020	
Sample Description	Zone 5, Ground Floor, C15-1-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	12.03.2020/12:35 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	20°C	Sample Onsite Temp	25.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent


Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media:- BCYE Agar.
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97348/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97348	
	Date Received	12 Mar 2020	
	Date(s) Tested	12 Mar 2020 - 22 Mar 2020	
	Date Reported	23 Mar 2020	
Sample Description	Zone 5, Ground Floor, C16-1-TA-3, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	12.03.2020/12:45 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	20°C	Sample Onsite Temp	27.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media:- BCYE Agar.
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 55
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97349/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97349	
	Date Received	12 Mar 2020	
	Date(s) Tested	12 Mar 2020 - 22 Mar 2020	
	Date Reported	23 Mar 2020	
Sample Description	Pumping Station, BSM Main Entrance Opposite, RCC Tank, Part 01		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	12.03.2020/2:20 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	20°C	Sample Onsite Temp	24.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media:- BCYE Agar.
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 55
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97350/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97350	
	Date Received	12 Mar 2020	
	Date(s) Tested	12 Mar 2020 - 22 Mar 2020	
	Date Reported	23 Mar 2020	
Sample Description	Pumping Station, BSM Main Entrance Opposite, RCC Tank, Part 02		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	12.03.2020/2:35 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	20°C	Sample Onsite Temp	24.6°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media:- BCYE Agar.
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 55
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97351/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97351	
	Date Received	12 Mar 2020	
	Date(s) Tested	12 Mar 2020 - 22 Mar 2020	
	Date Reported	23 Mar 2020	
Sample Description	Al Ghadeer Mosque, Ground Floor, GRP Tank No:01		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	12.03.2020/3:00 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	20°C	Sample Onsite Temp	25.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media:- BCYE Agar.
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 55
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97210/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97210	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-6A, Sabil Tower Tank-2		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/11:10 AM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	24.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97211/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97211	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-6A, Sabil Tower Tank-1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/11:25 AM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	26.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97212/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97212	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-6A, Sabil 4-Tank-1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/11:35 AM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	26.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97213/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97213	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-6A, Sabil 4-Tank-2		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/11:55 AM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	25.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97214/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97214	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-6A, Sabil-3-Tank-1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/12:10 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	27.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97215/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97215	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-6A, Sabil 3-Tank-2		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/12:30 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	28.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97216/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97216	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-6A, Sabil 2-Tank-1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/12:45 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	28.6°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97217/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97217	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-6A, Sabil 2-Tank-2		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/1:10 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	28°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS


PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97218/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97218	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-7A, Waha Tower Tank-1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/1:25 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	26.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97219/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97219	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-7A, Waha Tower Tank-2		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/1:35 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	24.6°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97220/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97220	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-7A, Waha Tower-4 Tank-1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/1:48 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	28.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97221/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-97221
		Date Received	11 Mar 2020
		Date(s) Tested	11 Mar 2020 - 21 Mar 2020
		Date Reported	24 Mar 2020
Sample Description	Zone-7A,Waha-4, Tank-2		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/2:00 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	25°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS


PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT