

## TEST REPORT

Report No: QMTL/R-97222/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97222	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-7A, Waha-3, Tank-1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/2:20 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	28.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97223/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97223	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-7A,Waha-3, Tank-2		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/2:30 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	27.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97224/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97224	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-7A,Waha-2, Tank-1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/2:45 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	25.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS


PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By




**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97225/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97225	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-7A,Waha-2, Tank-2		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/3:10 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	26.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By

  
**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-97226/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>		Sample ID	QMTL/S-97226
		Date Received	11 Mar 2020
		Date(s) Tested	11 Mar 2020 - 21 Mar 2020
		Date Reported	24 Mar 2020
Sample Description	<b>Zone-5-C1-1-TA-3</b>		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/3:25 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Ground Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	28.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97227/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97227
		Date Received	11 Mar 2020
		Date(s) Tested	11 Mar 2020 - 21 Mar 2020
<b>ATTN : MR. JASMAN PINTO</b>		Date Reported	24 Mar 2020
Sample Description	Zone-5-C2-1-TA-1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/3:40 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Ground Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	26.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97228/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97228	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 21 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Zone-5-C3-1-TA-2		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/4:00 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Ground Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	26.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS


PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By




**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97229/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97229
		Date Received	11 Mar 2020
		Date(s) Tested	11 Mar 2020 - 21 Mar 2020
		Date Reported	24 Mar 2020
<b>ATTN : MR. JASMAN PINTO</b>			
Sample Description	Zone-5-C4-1-TA-1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/4:15 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Ground Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	26.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97230/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97230
ATTN : MR. JASMAN PINTO		Date Received	11 Mar 2020
		Date(s) Tested	11 Mar 2020 - 21 Mar 2020
		Date Reported	24 Mar 2020
Sample Description	Zone-5-C5-1-TA-1		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/4:27 PM
Sample Container	1x1L PB	Sampling Point	RCC Tank (Ground Floor)
Sample Receipt Temp	24°C	Sample Onsite Temp	27.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 78
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97096/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97096	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Domestic Water,Zone-7B,C6-2-TA-2, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/12:20 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	28.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97097/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97097
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 20 Mar 2020
<b>ATTN : MR. JASMAN PINTO</b>		Date Reported	24 Mar 2020
Sample Description	Domestic Water,Zone-7B,C5-1-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/12:28 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	28.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97098/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97098
	Date Received	10 Mar 2020
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020
	Date Reported	24 Mar 2020
Sample Description	<b>Domestic Water,Zone-7B,C7-1-TA-2,C7-2-TA-2, RCC Tank</b>	
Sample Type	Water	Sampling Method QMTL-WI-16
Client Name/Project	NP	Sampled By QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time 10.03.2020/12:35 PM
Sample Container	1x1L PB	Sampling Point Tank
Sample Receipt Temp	21°C	Sample Onsite Temp 26.7°C
Sample Appearance	Clear	On-site Treatment NA
Reference	NP	

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97099/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97099	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Domestic Water,Zone-7B,C4-1-TA-1,C4-2-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/12:40 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	26.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RCFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97100/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97100
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 20 Mar 2020
<b>ATTN : MR. JASMAN PINTO</b>		Date Reported	24 Mar 2020
Sample Description	Domestic Water,Zone-7B,C3-1-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/12:50pm
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	28°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97101/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97101	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	<b>Domestic Water,Zone-7B,C2-2-TA-2, RCC Tank</b>		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/1:02 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	27.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97102/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97102
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 20 Mar 2020
<b>ATTN : MR. JASMAN PINTO</b>		Date Reported	24 Mar 2020
Sample Description	Domestic Water,Zone-3,C3-1-TA-3, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/1:12 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	27.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97103/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97103	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Domestic Water,Zone-3,C2-1-TA-1,C2-2-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/1:26 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	26.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97104/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97104
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 20 Mar 2020
<b>ATTN : MR. JASMAN PINTO</b>		Date Reported	24 Mar 2020
Sample Description	Domestic Water,Zone-3,C1-1-TA-3, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/1:40 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	28.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By




**ANILA GEORGE**  
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97105/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97105
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 20 Mar 2020
<b>ATTN : MR. JASMAN PINTO</b>		Date Reported	24 Mar 2020
Sample Description	Domestic Water,Zone-4, C21-1-TA-3, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/2:00 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	28.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

  
**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-97106/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97106	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Domestic Water,Zone-4, C20-1-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/2:20 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	27.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97107/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97107	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	<b>Domestic Water,Zone-4, C19-1-TA,C19-2-TA-1, RCC Tank</b>		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/2:32 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	28.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97108/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>		Sample ID	QMTL/S-97108
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 20 Mar 2020
		Date Reported	24 Mar 2020
Sample Description	<b>Domestic Water,Zone-4, C18-1-TA-1,C18-2-TA-1, RCC Tank</b>		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/2:49 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	28.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97109/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97109
	Date Received	10 Mar 2020
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020
	Date Reported	24 Mar 2020
Sample Description	<b>Domestic Water,Zone-4, C17-1-TA-3, RCC Tank</b>	
Sample Type	Water	Sampling Method
Client Name/Project	NP	Sampled By
Location	Al Ghadeer Project	Sampling Date/Time
Sample Container	1x1L PB	Sampling Point
Sample Receipt Temp	21°C	Sample Onsite Temp
Sample Appearance	Clear	On-site Treatment
Reference	NP	

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97110/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97110	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Domestic Water,Zone-6B , C3-1-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/3:20 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	28.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By

  
**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97111/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97111	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Domestic Water,Zone-6B, C4-1-TA-1,C4-2-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/3:42 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	28.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By

  
**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97112/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>		Sample ID	QMTL/S-97112
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 20 Mar 2020
		Date Reported	24 Mar 2020
Sample Description	<b>Domestic Water, Zone-6B, C2-2-TA-2, RCC Tank</b>		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/4:21 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	28.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: CoCFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97113/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97113	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Domestic Water,Zone-6B, C7-1-TA-2,C7-2-TA-2, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/4:58 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	28.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent


Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97114/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-97114	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	24 Mar 2020	
Sample Description	Domestic Water,Zone-6B, C6-1-TA-2, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/5:15 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	26.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-97115/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>		Sample ID	QMTL/S-97115
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 20 Mar 2020
		Date Reported	24 Mar 2020
Sample Description	<b>Domestic Water,Zone-6B, C5-1-TA-1, RCC Tank</b>		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/5:30 PM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	27.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA:Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




**ANILA GEORGE**  
**LABORATORY MANAGER**

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**