

TEST REPORT

Report No: QMTL/R-97201/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97201
ATTN : MR. JASMAN PINTO		Date Received	11 Mar 2020
		Date(s) Tested	11 Mar 2020 - 13 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Waha-3-Tank-1		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/ 2:20 PM
Sample Container	1x500ml PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	4.5°C	Sample Onsite Temp	28.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97202/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97202	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 13 Mar 2020	
	Date Reported	17 Mar 2020	
Sample Description	Waha-3-Tank-2		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/ 2:30 PM
Sample Container	1x500ml PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	4.5°C	Sample Onsite Temp	27.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	4
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97203/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97203	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 13 Mar 2020	
	Date Reported	17 Mar 2020	
Sample Description	Waha-2-Tank-1		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/ 2:45 PM
Sample Container	1x500ml PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	4.5°C	Sample Onsite Temp	25.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	4
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By


ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97204/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97204	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 13 Mar 2020	
	Date Reported	17 Mar 2020	
Sample Description	Waha-2-Tank-2		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/ 3:10 PM
Sample Container	1x500ml PB	Sampling Point	RCC Tank (Upper Floor)
Sample Receipt Temp	4.5°C	Sample Onsite Temp	26.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97205/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97205
ATTN : MR. JASMAN PINTO		Date Received	11 Mar 2020
		Date(s) Tested	11 Mar 2020 - 13 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Zone-5-C1-1-TA-3		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/ 3:25 PM
Sample Container	1x500ml PB	Sampling Point	RCC Tank (Ground Floor)
Sample Receipt Temp	4.5°C	Sample Onsite Temp	28.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97206/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97206	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 13 Mar 2020	
	Date Reported	17 Mar 2020	
Sample Description	Zone-5-C2-1-TA-1		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/ 3:40 PM
Sample Container	1x500ml PB	Sampling Point	RCC Tank (Ground Floor)
Sample Receipt Temp	4.5°C	Sample Onsite Temp	26.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.	
---	--

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97207/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97207	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 13 Mar 2020	
	Date Reported	17 Mar 2020	
Sample Description	Zone-5-C3-1-TA-2		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/ 4:00 PM
Sample Container	1x500ml PB	Sampling Point	RCC Tank (Ground Floor)
Sample Receipt Temp	4.5°C	Sample Onsite Temp	26.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	7
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97208/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97208
ATTN : MR. JASMAN PINTO		Date Received	11 Mar 2020
		Date(s) Tested	11 Mar 2020 - 13 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Zone-5-C4-1-TA-1		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/ 4:15 PM
Sample Container	1x500ml PB	Sampling Point	RCC Tank (Ground Floor)
Sample Receipt Temp	4.5°C	Sample Onsite Temp	26.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97209/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97209	
	Date Received	11 Mar 2020	
	Date(s) Tested	11 Mar 2020 - 13 Mar 2020	
	Date Reported	17 Mar 2020	
Sample Description	Zone-5-C5-1-TA-1		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	11.03.2020/ 4:27 PM
Sample Container	1x500ml PB	Sampling Point	RCC Tank (Ground Floor)
Sample Receipt Temp	4.5°C	Sample Onsite Temp	27.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.	
---	--

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97076/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-97076
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Zone-7B,C6-2-TA-2,RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/12:20 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	28.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97077/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97077
ATTN : MR. JASMAN PINTO		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Zone-7B,C5-1-TA-1,RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/12:28 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	28.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97078/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-97078
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Zone-7B,C7-2-TA-2,RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/12:35PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	26.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97079/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97079	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 12 Mar 2020	
	Date Reported	17 Mar 2020	
Sample Description	Zone-7B,C4-1-TA-1,C4-2-TA-1,RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/12:40 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	26.26°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---


Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97080/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97080
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
ATTN : MR. JASMAN PINTO		Date Reported	17 Mar 2020
Sample Description	Zone-7B,C3-1-TA-1,RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/12:50 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	28°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97081/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97081	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 12 Mar 2020	
	Date Reported	17 Mar 2020	
Sample Description	Zone-7B,C2-2-TA-2,RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/1:02 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	27.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97082/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97082
ATTN : MR. JASMAN PINTO		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Zone-3-C3-1-TA-3,RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/1:12 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	27.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---


Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97083/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97083
ATTN : MR. JASMAN PINTO		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Zone-3-C2-1-TA-1, C2-2-TA-1,RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/1:26 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	26.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---


Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97084/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-97084
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Zone-3,C1-1-TA-3,RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/1:40 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	28.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	7
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97085/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97085	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 12 Mar 2020	
	Date Reported	17 Mar 2020	
Sample Description	Zone-4,C21-1-TA-3, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/2:00 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	28.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97086/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97086
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
ATTN : MR. JASMAN PINTO		Date Reported	17 Mar 2020
Sample Description	Zone-4,C20-1-TA-1,C20-2-TA-1,RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/2:00 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	27.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	7
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97087/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-97087
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Zone-4,C19-1-TA-1,C19-2-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/2:32 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	28.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	6
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97088/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Sample ID</td> <td>QMTL/S-97088</td> </tr> <tr> <td>Date Received</td> <td>10 Mar 2020</td> </tr> <tr> <td>Date(s) Tested</td> <td>10 Mar 2020 - 12 Mar 2020</td> </tr> <tr> <td>Date Reported</td> <td>17 Mar 2020</td> </tr> </table>	Sample ID	QMTL/S-97088	Date Received	10 Mar 2020	Date(s) Tested	10 Mar 2020 - 12 Mar 2020	Date Reported	17 Mar 2020
Sample ID	QMTL/S-97088								
Date Received	10 Mar 2020								
Date(s) Tested	10 Mar 2020 - 12 Mar 2020								
Date Reported	17 Mar 2020								
Sample Description	Zone-4,C18-1-TA-1,C18-2-TA-1, RCC Tank								
Sample Type	Water	Sampling Method	QMTL-WI-15						
Client Name/Project	NP	Sampled By	QMTL Representative						
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/2:49 PM						
Sample Container	1x500ml PB	Sampling Point	Tank						
Sample Receipt Temp	4.6°C	Sample Onsite Temp	28.7°C						
Sample Appearance	Clear	On-site Treatment	NA						
Reference	NP								

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97089/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97089
ATTN : MR. JASMAN PINTO		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Zone-4,C17-1-TA-3, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/3:00 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	25.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.	
---	--

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97090/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97090	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 12 Mar 2020	
	Date Reported	17 Mar 2020	
Sample Description	Zone-6B,C3-1-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/3:20 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	28.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.	
---	--

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97091/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97091
ATTN : MR. JASMAN PINTO		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Zone-6B,C4-1-TA-1,C4-2-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/3:42 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	28.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97092/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97092
ATTN : MR. JASMAN PINTO		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Zone-6B,C2-2-TA-2, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/4:21 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	28.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.	
---	--

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97093/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97093
ATTN : MR. JASMAN PINTO		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Zone-6B,C7-1-TA-2,C7-2-TA-2, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/4:58 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	28.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97094/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97094	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 12 Mar 2020	
	Date Reported	17 Mar 2020	
Sample Description	Zone-6B,C6-1-TA-2, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/5:15 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	26.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97095/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-97095
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	17 Mar 2020
Sample Description	Zone-6B,C5-1-TA-1, RCC Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Al Ghadeer Project	Sampling Date/Time	10.03.2020/5:30 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4.6°C	Sample Onsite Temp	27.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided, WI: Work Instruction, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT