

TEST REPORT

Report No: QMTL/R-95177/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-95177
ATTN : MR. JASMAN PINTO		Date Received	25 Feb 2020
		Date(s) Tested	25 Feb 2020 - 27 Feb 2020
		Date Reported	01 Mar 2020
Sample Description	GF Floor, Swimming Pool		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	25.02.2020/06:30 PM
Sample Container	1x500ml PB	Sampling Point	Pool
Sample Receipt Temp	4°C	Sample Onsite Temp	34.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	AL NAHEEL TOWER		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	1000	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, NA: Not Applicable WI-Work Instruction, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 55
------------------------	---------

Report prepared by Emp#	22
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-95178/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-95178	
	Date Received	25 Feb 2020	
	Date(s) Tested	25 Feb 2020 - 06 Mar 2020	
	Date Reported	09 Mar 2020	
Sample Description	GF Floor, Swimming Pool		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	25.02.2020/06:32 PM
Sample Container	1x1L PB	Sampling Point	Pool
Sample Receipt Temp	18°C	Sample Onsite Temp	34.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	AL NAHEEL TOWER		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality, WI: Work Instruction, NP: Not Provided, NA: Not Applicable
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT