



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1087

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: APHA 9060 A&B
Temperature °C	: 34.4	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Laundry Outside Water Tank 1-3000 USG
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American Public Health Association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

fo

SREEJITH M.I

Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1088

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: APHA 9060 A&B
Temperature °C	: 35.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Laundry Outside Water Tank 2-3000 USG
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American Public Health Association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Pos

SREEJITH M.I

Laboratory Manager

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1089

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: APHA 9060 A&B
Temperature °C	: 35.3	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Laundry Outside Water Tank 1-5000 USG
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected\$	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American Public Health Association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

for

SREEJITH M.I

Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1090

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:00	Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: APHA 9060 A&B
Temperature °C	: 34.9	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Laundry Outside Water Tank 2-5000 USG
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American Public Health Association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

for
SREEJITH M.I
Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1091

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:0	Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: APHA 9060 A&B
Temperature °C	: 39.9	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: W3 Cluster Water tank
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American Public Health Association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

For

SREEJITH M.I

Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1092

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: APHA 9060 A&B
Temperature °C	: 38.9	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: W2 Cluster Water tank
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected\$	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American Public Health Association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

for

SREEJITH M.I

Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1093

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:0	Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: APHA 9060 A&B
Temperature °C	: 36.4	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Plumbing Store Water Tank 1
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American public health association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

for

SREEJITH M.I

Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1094

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:	Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: APHA 9060 A&B
Temperature °C	: 37.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Plumbing Store Water Tank 2
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected\$	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American public health association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

for

SREEJITH M.I

Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1095

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:00	Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: APHA 9060 A&B
Temperature °C	: 37.5	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Civil Store Water Tank 1
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American public health association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

SREEJITH M.I
Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1096

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: APHA 9060 A&B
Temperature °C	: 37.4	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Civil Store Water Tank 2
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected\$	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American public health association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

(Handwritten signature)



SREEJITH M.I

Laboratory Manager

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1097

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: APHA 9060 A&B
Temperature °C	: 38.2	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Near Admin Building Water Tank 1
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American public health association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

for



SREEJITH M.I

Laboratory Manager

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.




TEST REPORT

Customer Details

Report No. WA-R-L-1911-1098

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:00	Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: APHA 9060 A&B
Temperature °C	: 37.9	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Near Admin Building Water Tank 2
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American public health association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

foo

SREEJITH M.I

Laboratory Manager

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.





TEST REPORT

Customer Details

Report No. WA-R-L-1911-1099

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:00	Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: APHA 9060 A&B
Temperature °C	: 39.8	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Near Admin Building Water Tank 3
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American Public Health Association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

(Handwritten signature)



SREEJITH M.I

Laboratory Manager

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1100

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: APHA 9060 A&B
Temperature °C	: 38.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Near Admin Building Water Tank 4
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected\$	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American Public Health Association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

For



SREEJITH M.I

Laboratory Manager

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1101

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8588	Sampling Method	: APHA 9060 A&B
Temperature °C	: 34.2	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Kitchen 1 Outside Water Tank 1
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American Public Health Association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

(Handwritten signature)

SREEJITH M.I

Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1102

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:0	Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8588	Sampling Method	: APHA 9060 A&B
Temperature °C	: 35.3	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Kitchen 1 Outside Water Tank 2
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American Public Health Association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

for

SREEJITH M.I

Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1103

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8588	Sampling Method	: APHA 9060 A&B
Temperature °C	: 34.9	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Kitchen 2 Outside Water Tank 1
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected\$	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American Public Health Association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

(Handwritten signature)

SREEJITH M.I

Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1104

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 13/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 8/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8588	Sampling Method	: APHA 9060 A&B
Temperature °C	: 35.8	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Kitchen 2 Outside Water Tank 2
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 4-8 °C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H and I	CFU/100ml	Not Detected	Zero/100ml
Pseudomonas aeruginosa	CCFRA 2.5.2	CFU/100ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B	CFU/ml	Not Detected	100CFU/ml
Faecal Coliforms	APHA 9222 D	CFU/100ml	Not Detected	Zero/100ml

Note : \$Not Detected=<1CFU/ml

Not Detected=<1CFU/100ml

Limit based on: The Water quality regulation 4th edition/2014 RSB Abu Dhabi, schedule 1, Table F for Potable Water.

Remarks :The tested results of the sample are found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
GS	SS	None

Key Words :CFU- Colony Forming Units; APHA- American Public Health Association; CCFRA- Camden & Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

P.O. Box: 115086
Tel: 02-5503324
Fax: 02-5503387
Abu Dhabi
U.A.E.
WIMPEY LABORATORIES LLC

SREEJITH M.I

Laboratory Manager

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.




TEST REPORT

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-1911-1105



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: BS 7592
Temperature °C	: 34.4	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Laundry Outside Water Tank 1-3000 USG
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	CFU/ltr	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Paramaeters..

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU- Colony Forming Units, ISO- International Organization for Standardization Bs- British Standard .

Signed for and on behalf of Wimpey Laboratories

(Signature)

SREEJITH M.I
 Laboratory Manager

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.




TEST REPORT

Customer Details

Report No. WA-R-L-1911-1106

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:0	Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: BS 7592
Temperature °C	: 35.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Laundry Outside Water Tank 2-3000 USG
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	CFU/ltr	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters..

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU- Colony Forming Units, ISO- International Organization for Standardization Bs- British Standard .

Signed for and on behalf of Wimpey Laboratories

for
SREEJITH M.I
Laboratory Manager

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1107

Crystalline Environmental Services



Sampling Date/time : 6/11/2019 , 10:00:0	Report Date. : 16/11/2019
Analysis Start Date. : 6/11/2019	Analysis End Date. : 16/11/2019
Sample Location. : Al Raha Village	Sampled By : Pasha
Client Sample ID : Not Applicable	Sample Submitted as : Water
Sample Certificate No : 8587	Sampling Method : BS 7592
Temperature °C : 35.3	Site Observation : Clear
Sampling Container : Sterile Plastic Bottle	Source of Sample : Laundry Outside Water Tank 1-5000 USG
Sampling Point : Not Applicable	Intended Use : Not Applicable
Preservation : 10°C	Expiry Date : Not Applicable
Sample Description : Water	

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	CFU/ltr	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters..

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU- Colony Forming Units, ISO- International Organization for Standardization Bs- British Standard .

Signed for and on behalf of Wimpey Laboratories

Sreejith M.I
SREEJITH M.I
Laboratory Manager

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.




TEST REPORT

Customer Details

Report No. WA-R-L-1911-1108

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: BS 7592
Temperature °C	: 34.9	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Laundry Outside Water Tank 2-5000 USG
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

for

SREEJITH M.I
Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.




TEST REPORT

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-1911-1109



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: BS 7592
Temperature °C	: 39.9	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: W3 Cluster Water tank
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

For
SREEJITH M.I
Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1110

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: BS 7592
Temperature °C	: 38.9	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: W2 Cluster Water tank
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection= \leq 1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

For
SREEJITH M.I
Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1111

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:0	Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: BS 7592
Temperature °C	: 36.4	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Plumbing Store Water Tank 1
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

Fos

SREEJITH M.I

Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1112

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: BS 7592
Temperature °C	: 37.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Plumbing Store Water Tank 2
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

Sreejith M.I.
SREEJITH M.I
Laboratory Manager

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1113

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: BS 7592
Temperature °C	: 37.5	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Civil Store Water Tank 1
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

SREEJITH M.I

Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.




TEST REPORT

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-1911-1114



Sampling Date/time	: 6/11/2019 , 10:00:00	Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: BS 7592
Temperature °C	: 37.4	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Civil Store Water Tank 2
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

for

SREEJITH M.I

Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1115

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:00	Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: BS 7592
Temperature °C	: 38.2	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Near Admin Building Water Tank 1
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

for
SREEJITH M.I
Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.




TEST REPORT

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-1911-1116



Sampling Date/time	: 6/11/2019 , 10:00:00	Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: BS 7592
Temperature °C	: 37.9	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Near Admin Building Water Tank 2
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

for

SREEJITH M.I.
Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1117

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:00	Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: BS 7592
Temperature °C	: 39.8	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Near Admin Building Water Tank 3
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

SREEJITH M.I
Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-1911-1118



Sampling Date/time	: 6/11/2019 , 10:00:00	Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8587	Sampling Method	: BS 7592
Temperature °C	: 38.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Near Admin Building Water Tank 4
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

Fos

SREEJITH M.I

Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1119

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8588	Sampling Method	: BS 7592
Temperature °C	: 34.2	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Kitchen 1 Outside Water Tank 1
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

For

SREEJITH M.I
Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-1911-1120



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8588	Sampling Method	: BS 7592
Temperature °C	: 35.3	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Kitchen 1 Outside Water Tank 2
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

Fos

SREEJITH M.I
Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1121

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8588	Sampling Method	: BS 7592
Temperature °C	: 34.9	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Kitchen 2 Outside Water Tank 1
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.


Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

Fos



SREEJITH M.I

Laboratory Manager

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.



TEST REPORT

Customer Details

Report No. WA-R-L-1911-1122

Crystalline Environmental Services



Sampling Date/time	: 6/11/2019 , 10:00:(Report Date.	: 16/11/2019
Analysis Start Date.	: 6/11/2019	Analysis End Date.	: 16/11/2019
Sample Location.	: Al Raha Village	Sampled By	: Pasha
Client Sample ID	: Not Applicable	Sample Submitted as	: Water
Sample Certificate No	: 8588	Sampling Method	: BS 7592
Temperature °C	: 35.8	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Kitchen 2 Outside Water Tank 2
Sampling Point	: Not Applicable	Intended Use	: Not Applicable
Preservation	: 10°C	Expiry Date	: Not Applicable
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731	cfu/L	Not Detected	Zero/L

Note : Limit of Detection=<1cfu/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SS	SS	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards

Signed for and on behalf of Wimpey Laboratories

for

SREEJITH M.I

Laboratory Manager



Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.