



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26636



Request No. : WA-Q-L-2011-03829

Sample No. : WA-S-L-2011-25930

Sampling Date	: 17/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 17/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Abu Dhabi Investment Authorities (ADIA) -Business Recovery Center	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 4743	Sampling Method	: APHA 9060 A&B
Temperature °C	: 33	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Ground Floor – Main Water Tank
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26637



Request No. : WA-Q-L-2011-03829

Sample No. : WA-S-L-2011-25931

Sampling Date	: 17/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 17/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Abu Dhabi Investment Authorities (ADIA) -Business Recovery Center	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 4743	Sampling Method	: APHA 9060 A&B
Temperature °C	: 34	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Ground Floor – Filter Water tank # 01
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26638



Request No. : WA-Q-L-2011-03829

Sample No. : WA-S-L-2011-25932

Sampling Date	: 17/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 17/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Abu Dhabi Investment Authorities (ADIA) -Business Recovery Center	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 4743	Sampling Method	: APHA 9060 A&B
Temperature °C	: 33	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Ground Floor – Filter Water tank # 02
Sampling Point	: Tank	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26625



Request No. : WA-Q-L-2011-03829

Sample No. : WA-S-L-2011-25919

Sampling Date	: 17/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 17/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Abu Dhabi Investment Authorities (ADIA) -Business Recovery Center	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 4743	Sampling Method	: APHA 9060 A&B
Temperature °C	: 23	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Ground Floor Pantry - Cold Water
Sampling Point	: Water Tap	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26627



Request No. : WA-Q-L-2011-03829

Sample No. : WA-S-L-2011-25921

Sampling Date	: 17/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 17/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Abu Dhabi Investment Authorities (ADIA) -Business Recovery Center	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 4743	Sampling Method	: APHA 9060 A&B
Temperature °C	: 23	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Ground Floor Kitchen - Cold Water
Sampling Point	: Water Tap	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2011-26629

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2011-03829

Sample No. : WA-S-L-2011-25923

Sampling Date	: 17/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 17/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Abu Dhabi Investment Authorities (ADIA) -Business Recovery Center	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 4743	Sampling Method	: APHA 9060 A&B
Temperature °C	: 22	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Ground Floor- Male Washroom – Cold Water
Sampling Point	: Water Tap	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2011-26631

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2011-03829

Sample No. : WA-S-L-2011-25925

Sampling Date	: 17/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 17/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Abu Dhabi Investment Authorities (ADIA) -Business Recovery Center	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 4743	Sampling Method	: APHA 9060 A&B
Temperature °C	: 23	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Mezzanine Floor -Male Washroom - Cold Water
Sampling Point	: Water Tap	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26626



Request No. : WA-Q-L-2011-03829

Sample No. : WA-S-L-2011-25920

Sampling Date	: 17/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 17/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Abu Dhabi Investment Authorities (ADIA) -Business Recovery Center	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 4743	Sampling Method	: APHA 9060 A&B
Temperature °C	: 34	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Ground Floor Pantry - Hot Water
Sampling Point	: Water Tap	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2011-26628

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2011-03829

Sample No. : WA-S-L-2011-25922

Sampling Date	: 17/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 17/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Abu Dhabi Investment Authorities (ADIA) -Business Recovery Center	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 4743	Sampling Method	: APHA 9060 A&B
Temperature °C	: 35	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Ground Floor Kitchen – Hot Water
Sampling Point	: Water Tap	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2011-26630

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2011-03829

Sample No. : WA-S-L-2011-25924

Sampling Date	: 17/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 17/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Abu Dhabi Investment Authorities (ADIA) -Business Recovery Center	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 4743	Sampling Method	: APHA 9060 A&B
Temperature °C	: 34	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Ground Floor- Male Washroom – Hot Water
Sampling Point	: Water Tap	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26632



Request No. : WA-Q-L-2011-03829

Sample No. : WA-S-L-2011-25926

Sampling Date	: 17/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 17/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Abu Dhabi Investment Authorities (ADIA) -Business Recovery Center	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 4743	Sampling Method	: APHA 9060 A&B
Temperature °C	: 37	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Mezzanine Floor -Male Washroom - Hot Water
Sampling Point	: Water Tap	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



CRYSTALLINE ENVIRONMENTAL SERVICES

WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	17-11-2020
Sampled By	Crystalline Rep	Location	ADIA - BRC
Sample Type	Potable Water (Cold Outlet)	Sample Point	Ground Floor Kitchen

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.40
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	----	235
3	Total Dissolved Solids (TDS)	Max 1000	152
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	71
7	Total Hardness at 25°C	300	79


Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	67
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Calcium hardness and Total Hardness levels are satisfactory.
3	All inorganic parameters are within the control limit.

Reported By,

Murugaraaj
Service Engineer



CLEANER WATER GREENER TOMORROW



CRYSTALLINE ENVIRONMENTAL SERVICES

WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	17-11-2020
Sampled By	Crystalline Rep	Location	ADIA - BRC
Sample Type	Potable Water (Cold Outlet)	Sample Point	Ground Floor Wash Room

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.55
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	----	229
3	Total Dissolved Solids (TDS)	Max 1000	148
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	65
7	Total Hardness at 25°C	300	76


Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	59
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Calcium hardness and Total Hardness levels are satisfactory.
3	All inorganic parameters are within the control limit.

Reported By,

Murugaraaj
Service Engineer



CLEANER WATER GREENER TOMORROW



CRYSTALLINE ENVIRONMENTAL SERVICES

WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	17-11-2020
Sampled By	Crystalline Rep	Location	ADIA - BRC
Sample Type	Potable Water (Cold Outlet)	Sample Point	Mezzanine Floor Washroom

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.50
2	Conductivity at 25°C, $\mu\text{s/cm}$	----	244
3	Total Dissolved Solids (TDS)	Max 1000	158
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
7	Calcium Hardness at 25°C	200	78
8	Total Hardness at 25°C	300	85
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	73
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal.
2	Calcium hardness and Total Hardness levels are satisfactory.
3	All inorganic parameters are within the control limit.

Reported By,

Murugaraaj
Service Engineer



CLEANER WATER GREENER TOMORROW



CRYSTALLINE ENVIRONMENTAL SERVICES

WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	17-11-2020
Sampled By	Crystalline Rep	Location	ADIA - BRC
Sample Type	Potable Water (Hot Outlet)	Sample Point	Ground Floor Pantry

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.01
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	----	199
3	Total Dissolved Solids (TDS)	Max 1000	129
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	69
7	Total Hardness at 25°C	300	73

Inorganic Chemical Parameters


1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	65
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Calcium hardness and Total Hardness levels are satisfactory
3	All inorganic parameters are within the control limit

Reported By,


Murugaraaj
Service Engineer



CLEANER WATER GREENER TOMORROW



CRYSTALLINE ENVIRONMENTAL SERVICES

WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	17-11-2020
Sampled By	Crystalline Rep	Location	ADIA -BRC
Sample Type	Potable Water (Hot Outlet)	Sample Point	Ground Floor Kitchen

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	7.94
2	Conductivity at 25°C, $\mu\text{S}/\text{cm}$	----	229
3	Total Dissolved Solids (TDS)	Max 1000	148
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	67
7	Total Hardness at 25°C	300	72

Inorganic Chemical Parameter

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	59
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,


Murugaraaj
Service Engineer



CLEANER WATER GREENER TOMORROW



CRYSTALLINE ENVIRONMENTAL SERVICES

WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	17-11-2020
Sampled By	Crystalline Rep	Location	ADIA - BRC
Sample Type	Potable Water (Hot Outlet)	Sample Point	Ground Floor Washroom

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.55
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	----	238
3	Total Dissolved Solids (TDS)	Max 1000	154
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	60
7	Total Hardness at 25°C	300	67
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	57
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Calcium hardness and Total Hardness levels are satisfactory
3	All inorganic parameters are within the control limit

Reported By,


Murugaraaj
Service Engineer



CLEANER WATER GREENER TOMORROW



CRYSTALLINE ENVIRONMENTAL SERVICES

WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	17-11-2020
Sampled By	Crystalline Rep	Location	ADIA - BRC
Sample Type	Potable Water (Hot Outlet)	Sample Point	Mezzanine Floor Washroom

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	7.93
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	----	208
3	Total Dissolved Solids (TDS)	Max 1000	135
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Calcium Hardness at 25°C	200	70
7	Total Hardness at 25°C	300	78
Inorganic Chemical Parameters			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	61
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	Potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Calcium hardness and Total Hardness levels are satisfactory
3	All inorganic parameters are within the control limit

Reported By,

Murugaraaj
Service Engineer



CLEANER WATER GREENER TOMORROW



Microbiology Test Report

Customer Details

Report No. WA-R-L-2011-26633

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2011-03829

Sample No. : WA-S-L-2011-25927

Sampling Date	: 17/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 17/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Abu Dhabi Investment Authorities (ADIA) -Business Recovery Center	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 4743	Sampling Method	: APHA 9060 A&B
Temperature °C	: 17	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Ground Floor – Chiller Yard
Sampling Point	: Valve	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	--
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	--
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	10000CFU/ml
Pseudomonas aeroginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	--
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	--

Note : Not Detected=<1CFU

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26634



Request No. : WA-Q-L-2011-03829

Sample No. : WA-S-L-2011-25928

Sampling Date	: 17/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 17/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Abu Dhabi Investment Authorities (ADIA) -Business Recovery Center	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 4743	Sampling Method	: APHA 9060 A&B
Temperature °C	: 14	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Ground Floor Chilled Water
Sampling Point	: Valve	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	-
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	-
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	10000CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	-
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	-

Note : Not Detected=<1CFU

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26635



Request No. : WA-Q-L-2011-03829

Sample No. : WA-S-L-2011-25929

Sampling Date	: 17/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 17/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Abu Dhabi Investment Authorities (ADIA) -Business Recovery Center	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 4743	Sampling Method	: APHA 9060 A&B
Temperature °C	: 14	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Mezzanine Floor -Chilled Water
Sampling Point	: Valve	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	-
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	-
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	10000CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	-
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	-

Note : Not Detected=<1CFU

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



CRYSTALLINE ENVIRONMENTAL SERVICES

WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	17-11-2020
Sampled By	Crystalline Rep	Sample Location	ADIA -BRC
Sample Type	Chilled Water	Sample Point	G-Floor Chiller Yard

CHILLED WATER

No	PARAMETER	CONTROL LIMITS	TEST RESULTS
1	pH at 25°C	9.0 - 10.5	10.06
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	Max 3500	2985
3	TDS, ppm	---	1940
4	Iron, ppm as Fe	0 - 2.0	0.20
5	Nitrite, ppm.	>800	1010
6	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

- pH Levels are satisfactory - No action recommended.
- Nitrite Levels are satisfactory - No action recommended.

Reported By,

Murugan
Service Engineer



CLEANER WATER GREENER TOMORROW



CRYSTALLINE ENVIRONMENTAL SERVICES

WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	17-11-2020
Sampled By	Crystalline Rep	Sample Location	ADIA -BRC
Sample Type	Chilled Water	Sample Point	G-Floor Chilled Water

CHILLED WATER

No	PARAMETER	CONTROL LIMITS	TEST RESULTS
1	pH at 25°C	9.0 - 10.5	9.77
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	Max 3500	2643
3	TDS, ppm	---	1718
4	Iron, ppm as Fe	0 - 2.0	0.08
5	Nitrite, ppm.	>800	1130
6	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

- pH Levels are satisfactory - No action recommended.
- Nitrite Levels are satisfactory - No action recommended.

Reported By,


Murugaraj
Service Engineer



CLEANER WATER GREENER TOMORROW



CRYSTALLINE ENVIRONMENTAL SERVICES

WATER ANALYSIS REPORT

Client Name: SERCO, MIDDLE EAST

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	17-11-2020
Sampled By	Crystalline Rep	Sample Location	ADIA -BRC
Sample Type	Chilled Water	Sample Point	M-Floor Chilled Water

CHILLED WATER

No	PARAMETER	CONTROL LIMITS	TEST RESULTS
1	pH at 25°C	9.0 - 10.5	10.44
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	Max 3500	2551
3	TDS, ppm	---	1658
4	Iron, ppm as Fe	0 - 2.0	0.22
5	Nitrite, ppm.	>800	1160
6	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

- pH Levels are satisfactory - No action recommended.
- Nitrite Levels are satisfactory - No action recommended.

Reported By,

Murugaraj
Service Engineer



CLEANER WATER GREENER TOMORROW