



**Legionella Test Report**

**Customer Details**

**Crystalline Cleaning & Environmental Services**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31429



Request No. : WA-Q-L-2101-04443

Sample No. : WA-S-L-2101-30780

|                       |                     |                     |                  |
|-----------------------|---------------------|---------------------|------------------|
| Sampling Date         | : 04/01/2021        | Report Date.        | : 14/01/2021     |
| Analysis Start Date.  | : 04/01/2021        | Analysis End Date.  | : 14/01/2021     |
| Sample Location.      | : Al Bandar Village | Sampled By          | : Client         |
| Sample Identification | : Not Given         | Sample Submitted as | : Water          |
| Sample Certificate No | : 3359              | Sampling Method     | : Not Applicable |
| Temperature °C        | : Not Given         | Site Observation    | : Not Given      |
| Sampling Container    | : Plastic Bottle    | Source of Sample    | : Family Pool    |
| Sampling Point        | : Not Given         | Preservation        | : Not Applicable |
| Sample Description    | : Pool Water        |                     |                  |

| Parameters | Test Methods    | Units | Results      | Specification |
|------------|-----------------|-------|--------------|---------------|
| Legionella | ISO 11731: 2017 | CFU/L | Not Detected | <1CFU/L       |

Note : Not Detected=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter followed by Washing Procedure in Funnel.

Limit based on DM.Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

**Remarks :The tested result of the sample is found to be satisfactory within the specified limits.**

| Analyst | Reviewed By | Method Variation |
|---------|-------------|------------------|
| SN      | SM          | None             |

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Legionella Test Report**

**Customer Details**

**Crystalline Cleaning & Environmental Services**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31432



Request No. : WA-Q-L-2101-04443

Sample No. : WA-S-L-2101-30783

|                       |                     |                     |                  |
|-----------------------|---------------------|---------------------|------------------|
| Sampling Date         | : 04/01/2021        | Report Date.        | : 14/01/2021     |
| Analysis Start Date.  | : 04/01/2021        | Analysis End Date.  | : 14/01/2021     |
| Sample Location.      | : Al Bandar Village | Sampled By          | : Client         |
| Sample Identification | : Not Given         | Sample Submitted as | : Water          |
| Sample Certificate No | : 3359              | Sampling Method     | : Not Applicable |
| Temperature °C        | : Not Given         | Site Observation    | : Not Given      |
| Sampling Container    | : Plastic Bottle    | Source of Sample    | : Lap Pool 2     |
| Sampling Point        | : Not Given         | Preservation        | : Not Applicable |
| Sample Description    | : Pool Water        |                     |                  |

| Parameters | Test Methods    | Units | Results      | Specification |
|------------|-----------------|-------|--------------|---------------|
| Legionella | ISO 11731: 2017 | CFU/L | Not Detected | <1CFU/L       |

Note : Not Detected=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter followed by Washing Procedure in Funnel.

Limit based on DM.Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

**Remarks :The tested result of the sample is found to be satisfactory within the specified limits.**

| Analyst | Reviewed By | Method Variation |
|---------|-------------|------------------|
| SN      | SM          | None             |

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Legionella Test Report**

**Customer Details**

**Crystalline Cleaning & Environmental Services**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31431



Request No. : WA-Q-L-2101-04443

Sample No. : WA-S-L-2101-30782

|                       |                             |                     |                  |
|-----------------------|-----------------------------|---------------------|------------------|
| Sampling Date         | : 04/01/2021                | Report Date.        | : 14/01/2021     |
| Analysis Start Date.  | : 04/01/2021                | Analysis End Date.  | : 14/01/2021     |
| Sample Location.      | : Al Bandar Village         | Sampled By          | : Client         |
| Sample Identification | : Not Given                 | Sample Submitted as | : Water          |
| Sample Certificate No | : 3359                      | Sampling Method     | : Not Applicable |
| Temperature °C        | : Not Given                 | Site Observation    | : Not Given      |
| Sampling Container    | : Plastic Bottle            | Source of Sample    | : Lap Pool 1     |
| Sampling Point        | : Near Al Naseem Building C | Preservation        | : Not Applicable |
| Sample Description    | : Pool Water                |                     |                  |

| Parameters | Test Methods    | Units | Results      | Specification |
|------------|-----------------|-------|--------------|---------------|
| Legionella | ISO 11731: 2017 | CFU/L | Not Detected | <1CFU/L       |

Note : Not Detected=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter followed by Washing Procedure in Funnel.

Limit based on DM.Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

**Remarks :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.**

| Analyst | Reviewed By | Method Variation |
|---------|-------------|------------------|
| SN      | SM          | None             |

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

**Signed for and on behalf of Wimpey Laboratories**



**Dr. Suresh Murugan Ph.D**

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



**Legionella Test Report**

**Customer Details**

**Crystalline Cleaning & Environmental Services**

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31430



Request No. : WA-Q-L-2101-04443

Sample No. : WA-S-L-2101-30781

|                       |                     |                     |                  |
|-----------------------|---------------------|---------------------|------------------|
| Sampling Date         | : 04/01/2021        | Report Date.        | : 14/01/2021     |
| Analysis Start Date.  | : 04/01/2021        | Analysis End Date.  | : 14/01/2021     |
| Sample Location.      | : Al Bandar Village | Sampled By          | : Client         |
| Sample Identification | : Not Given         | Sample Submitted as | : Water          |
| Sample Certificate No | : 3359              | Sampling Method     | : Not Applicable |
| Temperature °C        | : Not Given         | Site Observation    | : Not Given      |
| Sampling Container    | : Plastic Bottle    | Source of Sample    | : Kids Pool      |
| Sampling Point        | : Not Given         | Preservation        | : Not Applicable |
| Sample Description    | : Pool Water        |                     |                  |

| Parameters | Test Methods    | Units | Results      | Specification |
|------------|-----------------|-------|--------------|---------------|
| Legionella | ISO 11731: 2017 | CFU/L | Not Detected | <1CFU/L       |

Note : Not Detected=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter followed by Washing Procedure in Funnel.

Limit based on DM.Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

**Remarks :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.**

| Analyst | Reviewed By | Method Variation |
|---------|-------------|------------------|
| SN      | SM          | None             |

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

**Signed for and on behalf of Wimpey Laboratories**

**Dr. Suresh Murugan Ph.D**

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -