

## TEST REPORT

Report No: QMTL/R-94090/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-94090	
	Date Received	19 Feb 2020	
	Date(s) Tested	19 Feb 2020 - 21 Feb 2020	
	Date Reported	27 Feb 2020	
Sample Description	P-1 - Chiller Plant Room		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	19.02.2020/10:42 AM
Sample Container	1x500ml PB	Sampling Point	Valve
Sample Receipt Temp	5°C	Sample Onsite Temp	11°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10,000	56x10 <sup>4</sup>
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero
Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided;NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**