

## TEST REPORT

Report No: QMTL/R-148568/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148568
ATTN : MR. JASMAN PINTO		Date Received	15 Feb 2021
		Date(s) Tested	15 Feb 2021 - 18 Feb 2021
		Date Reported	23 Feb 2021
Sample Description	Level-1 CSSD Decontamination Room Sink		
Sample Type	Water	Sampling Method	QMTL-SOP-128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	15.02.2021/ 11:15 AM
Sample Container	1x500ml PB	Sampling Point	Sink
Sample Receipt Temp	18°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>PHYSICAL PARAMETERS</b>				
Conductivity*	APHA 2510 B-23rd Edition	µs/cm	-	274@25.1°C
pH*	APHA 4500 H+B-23rd Edition	-	Min 7.0-Max 9.2	8.19@25.1°C
Total Suspended Solids*	APHA 2540 D -23rd Edition	mg/L	-	<3
<b>CHEMICAL PARAMETERS</b>				
Chloride*	APHA 4500 Cl <sup>-</sup> B-23rd Edition	mg/L	Max 250	50.7
Total Hardness as (CaCO <sub>3</sub> )*	APHA 2340-C-23rd Edition	mg/L	Max 300	56.04
<b>METALS</b>				
Calcium *	APHA 3500-Ca B-23rd Edition	mg/L	-	20.9
Iron*	APHA 3120 B-23rd Edition	mg/L	Max 0.20	<0.05

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, DoE: Department of Energy, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
----------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	13
------------------------	----

Report prepared by Emp#	22
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-148569/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-148569	
	Date Received	15 Feb 2021	
	Date(s) Tested	15 Feb 2021 - 18 Feb 2021	
	Date Reported	23 Feb 2021	
ATTN : MR. JASMAN PINTO			
Sample Description	Level-1 CSSD RO Water Tank		
Sample Type	Water	Sampling Method	QMTL-SOP-128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	15.02.2021/ 11:15 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	18°C	Sample Onsite Temp	16°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>PHYSICAL PARAMETERS</b>				
Conductivity*	APHA 2510 B-23rd Edition	µs/cm	-	38.1@25.1°C
pH*	APHA 4500 H+B-23rd Edition	-	Min 7.0-Max 9.2	8.12@25.1°C
Total Suspended Solids*	APHA 2540 D -23rd Edition	mg/L	-	<3
Total Dissolved Solids*	APHA 2540-C-23rd Edition	mg/L	Min 100-Max 600	24**
<b>CHEMICAL PARAMETERS</b>				
Chloride*	APHA 4500 Cl <sup>-</sup> B-23rd Edition	mg/L	Max 250	4.05
Total Hardness as (CaCO <sub>3</sub> )*	APHA 2340-C-23rd Edition	mg/L	Max 300	<3
<b>METALS</b>				
Calcium *	APHA 3500-Ca B-23rd Edition	mg/L	-	<3
Iron*	APHA 3120 B-23rd Edition	mg/L	Max 0.20	<0.05

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	**The sample does not meet Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above test only.
Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, DoE: Department of Energy, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
Test method deviation	None
Test performed by Emp#	13
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-148570/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-148570	
	Date Received	15 Feb 2021	
	Date(s) Tested	15 Feb 2021 - 18 Feb 2021	
	Date Reported	23 Feb 2021	
ATTN : MR. JASMAN PINTO			
Sample Description	Level-1 DSU Wash Basin		
Sample Type	Water	Sampling Method	QMTL-SOP-128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	15.02.2021/ 11:15 AM
Sample Container	1x500ml PB	Sampling Point	Wash Basin
Sample Receipt Temp	18°C	Sample Onsite Temp	43°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>PHYSICAL PARAMETERS</b>				
Conductivity*	APHA 2510 B-23rd Edition	µs/cm	-	285@25.1°C
pH*	APHA 4500 H+B-23rd Edition	-	Min 7.0-Max 9.2	8.22@25.1°C
Total Suspended Solids*	APHA 2540 D -23rd Edition	mg/L	-	<3
<b>CHEMICAL PARAMETERS</b>				
Chloride*	APHA 4500 Cl <sup>-</sup> B-23rd Edition	mg/L	Max 250	52.9
Total Hardness as (CaCO <sub>3</sub> )*	APHA 2340-C-23rd Edition	mg/L	Max 300	52.3
<b>METALS</b>				
Calcium *	APHA 3500-Ca B-23rd Edition	mg/L	-	17.9
Iron*	APHA 3120 B-23rd Edition	mg/L	Max 0.20	<0.05

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, DoE: Department of Energy, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
----------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	13
------------------------	----

Report prepared by Emp#	22
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-148571/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-148571	
	Date Received	15 Feb 2021	
	Date(s) Tested	15 Feb 2021 - 18 Feb 2021	
	Date Reported	23 Feb 2021	
ATTN : MR. JASMAN PINTO			
Sample Description	Level-1 Operation Theatre Scrub Sink		
Sample Type	Water	Sampling Method	QMTL-SOP-128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	15.02.2021/ 11:15 AM
Sample Container	1x500ml PB	Sampling Point	Sink
Sample Receipt Temp	18°C	Sample Onsite Temp	22°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>PHYSICAL PARAMETERS</b>				
Conductivity*	APHA 2510 B-23rd Edition	µs/cm	-	285@25.1°C
pH*	APHA 4500 H+B-23rd Edition	-	Min 7.0-Max 9.2	8.11@25.1°C
Total Suspended Solids*	APHA 2540 D -23rd Edition	mg/L	-	<3
<b>CHEMICAL PARAMETERS</b>				
Chloride*	APHA 4500 Cl <sup>-</sup> B-23rd Edition	mg/L	Max 250	50.8
Total Hardness as (CaCO <sub>3</sub> )*	APHA 2340-C-23rd Edition	mg/L	Max 300	56.5
<b>METALS</b>				
Calcium *	APHA 3500-Ca B-23rd Edition	mg/L	-	16.5
Iron*	APHA 3120 B-23rd Edition	mg/L	Max 0.20	<0.05

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, DoE: Department of Energy, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
----------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	13
------------------------	----

Report prepared by Emp#	22
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-148554/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-148554	
	Date Received	15 Feb 2021	
	Date(s) Tested	15 Feb 2021 - 17 Feb 2021	
	Date Reported	23 Feb 2021	
ATTN : MR. JASMAN PINTO			
Sample Description	Level -I, CSSD, Decontamination Room Sink		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	15.02.2021 / 11:10 AM
Sample Container	1x500ml PB	Sampling Point	Tap ( Sink )
Sample Receipt Temp	4°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	10
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSM Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSM ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
---------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, HAAD: The Health –Authority- Abu Dhabi, EHSM: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 14
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

**ANILA GEORGE**

**LABORATORY MANAGER**

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-148555/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-148555	
	Date Received	15 Feb 2021	
	Date(s) Tested	15 Feb 2021 - 17 Feb 2021	
	Date Reported	23 Feb 2021	
ATTN : MR. JASMAN PINTO			
Sample Description	Level -I, CSSD RO Water Tank		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	15.02.2021 / 11:20 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	16°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	2
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSMS ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
---------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 14
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-148556/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148556
ATTN : MR. JASMAN PINTO		Date Received	15 Feb 2021
		Date(s) Tested	15 Feb 2021 - 17 Feb 2021
		Date Reported	23 Feb 2021
Sample Description	Level 1, DSU Wash Basin		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	15.02.2021 / 11:30 AM
Sample Container	1x500ml PB	Sampling Point	Tap ( Wash Basin )
Sample Receipt Temp	4°C	Sample Onsite Temp	43°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	1
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMs Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSMs ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
---------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, HAAD: The Health –Authority- Abu Dhabi, EHSMs: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 14
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

**ANILA GEORGE**

**LABORATORY MANAGER**

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-148557/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-148557	
	Date Received	15 Feb 2021	
	Date(s) Tested	15 Feb 2021 - 17 Feb 2021	
	Date Reported	23 Feb 2021	
ATTN : MR. JASMAN PINTO			
Sample Description	Level 1, Operation Theater Scrub Sink		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	15.02.2021 / 12:00 PM
Sample Container	1x500ml PB	Sampling Point	Scrub Sink
Sample Receipt Temp	4°C	Sample Onsite Temp	22°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	1
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSMS ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
---------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-148563/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148563
ATTN : MR. JASMAN PINTO		Date Received	15 Feb 2021
		Date(s) Tested	15 Feb 2021 - 25 Feb 2021
		Date Reported	01 Mar 2021
Sample Description	Level -1, CSSD Decontamination Room Sink		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	15.02.2021 / 11:10 AM
Sample Container	1x1L PB	Sampling Point	Tap ( Sink )
Sample Receipt Temp	21°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (\*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSMS ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-148564/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148564
ATTN : MR. JASMAN PINTO		Date Received	15 Feb 2021
		Date(s) Tested	15 Feb 2021 - 25 Feb 2021
		Date Reported	01 Mar 2021
Sample Description	Level -1, CSSD RO Water Tank		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	15.02.2021 / 11:20 AM
Sample Container	1x1L PB	Sampling Point	Tank
Sample Receipt Temp	21°C	Sample Onsite Temp	16°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (\*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSMS ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-148565/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148565
ATTN : MR. JASMAN PINTO		Date Received	15 Feb 2021
		Date(s) Tested	15 Feb 2021 - 25 Feb 2021
		Date Reported	01 Mar 2021
Sample Description	Level 1, DSU Wash Basin		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	15.02.2021 / 11:30 AM
Sample Container	1x1L PB	Sampling Point	Tap (Wash Basin)
Sample Receipt Temp	21°C	Sample Onsite Temp	43°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (\*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSMS ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-148566/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148566
ATTN : MR. JASMAN PINTO		Date Received	15 Feb 2021
		Date(s) Tested	15 Feb 2021 - 25 Feb 2021
		Date Reported	01 Mar 2021
Sample Description	Level 1, Operation Theater Scrub Sink		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	15.02.2021 / 12:00 PM
Sample Container	1x1L PB	Sampling Point	Scrub Sink
Sample Receipt Temp	21°C	Sample Onsite Temp	22°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (\*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSMS ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT