



Microbiology Test Report

Customer Details

Report No. WA-R-L-2011-26522

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25816

Sampling Date	: 16/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: APHA 9060 A&B
Temperature °C	: 26.7	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Swimming Pool
Sampling Point	: Level 02	Preservation	: 4-8°C
Sample Description	: Pool Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	--
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	1000CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limit based on: Guide to the Executive Regulations of Law No.(2) for the year of 2012 (Swimming Pool),
Issued by the head of urban planning and municipalities No.(3) for the year 2018, Page No.3.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26523



Request No. : WA-Q-L-2011-03816

Sample No.: WA-S-L-2011-25817

Sampling Date	: 16/11/2020	Report Date.	: 26/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 26/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: BS 7592
Temperature °C	: 26.7	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Swimming Pool
Sampling Point	: Level 02	Preservation	: 10°C
Sample Description	: Pool Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	<1CFU/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2011-26520

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25814

Sampling Date	: 16/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: APHA 9060 A&B
Temperature °C	: 33.4	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Basement 1
Sampling Point	: Water Tank	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2011-26521

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25815

Sampling Date	: 16/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: APHA 9060 A&B
Temperature °C	: 32.8	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Basement 2
Sampling Point	: Water Tank	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2011-26517

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25811

Sampling Date	: 16/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: APHA 9060 A&B
Temperature °C	: 34.3	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Upper Rooftop
Sampling Point	: Water Tank # 1	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2011-26518

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25812

Sampling Date	: 16/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: APHA 9060 A&B
Temperature °C	: 34.4	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Upper Rooftop
Sampling Point	: Water Tank # 2	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020



- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2011-26519

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25813

Sampling Date	: 16/11/2020	Report Date.	: 19/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 19/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: APHA 9060 A&B
Temperature °C	: 34.7	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Upper Rooftop
Sampling Point	: Water Tank # 3	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Camden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26532



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25826

Sampling Date	: 16/11/2020	Report Date.	: 26/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 26/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: BS 7592
Temperature °C	: 25.7	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Groundfloor Cold Outlet
Sampling Point	: Washroom Tap Water	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26531



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25825

Sampling Date	: 16/11/2020	Report Date.	: 26/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 26/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: BS 7592
Temperature °C	: 25.5	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Groundfloor Garbage Room
Sampling Point	: Tap Water	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020



- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2011-26530

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25824

Sampling Date	: 16/11/2020	Report Date.	: 26/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 26/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: BS 7592
Temperature °C	: 23.7	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Groundfloor Cold Outlet
Sampling Point	: Kitchen Tap Water	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020



- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26529



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25823

Sampling Date	: 16/11/2020	Report Date.	: 26/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 26/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: BS 7592
Temperature °C	: 25.4	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Parking Lot
Sampling Point	: Water Tap	Preservation	: 10°C
Sample Description	: Potable Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26528



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25822

Sampling Date	: 16/11/2020	Report Date.	: 26/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 26/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: BS 7592
Temperature °C	: 22.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Plant Room
Sampling Point	: Water Tap	Preservation	: 10°C
Sample Description	: Potable Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020



- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2011-26527

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25821

Sampling Date	: 16/11/2020	Report Date.	: 26/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 26/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: BS 7592
Temperature °C	: 23.3	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Apartment # 506 Cold Outlet
Sampling Point	: Washroom Tap Water	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. : WA-R-L-2011-26526



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25820

Sampling Date	: 16/11/2020	Report Date.	: 26/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 26/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: BS 7592
Temperature °C	: 23.2	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Apartment # 506 Cold Outlet
Sampling Point	: Kitchen Tap Water	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2011-26525

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25819

Sampling Date	: 16/11/2020	Report Date.	: 26/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 26/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: BS 7592
Temperature °C	: 24.4	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Apartment # 507 Cold Outlet
Sampling Point	: Washroom Tap Water	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2011-26524



Request No. : WA-Q-L-2011-03816

Sample No. : WA-S-L-2011-25818

Sampling Date	: 16/11/2020	Report Date.	: 26/11/2020
Analysis Start Date.	: 16/11/2020	Analysis End Date.	: 26/11/2020
Sample Location.	: Capital House, Abu Dhabi	Sampled By	: Pasha
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2722	Sampling Method	: BS 7592
Temperature °C	: 24.3	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Apartment # 507 Cold Outlet
Sampling Point	: Kitchen Tap Water	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	Zero/L

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limit.

Analyst	Reviewed By	Method Variation
SM	SM	None

Key Words :CFU-Colony Forming Units, ISO-International Organization for Standardization, BS-British Standards.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -