

## SWIMMING POOL - WATER ANALYSIS REPORT

<b>Client Name:</b> TAFAWUQ FACILITY MANAGEMENT, ABU DHABI			
<b>Site Name:</b>	SAS AL NAKHEEL VILLAGE	<b>Visit Date:</b>	08-10-2019
<b>Sampled By:</b>	Crystalline Rep.	<b>Last Visit:</b>	17-09-2019
<b>Source of Sample</b>	Swimming Pool	<b>Sample Point</b>	Main Swimming Pool


### TEST RESULT

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.49
2	Conductivity at 25°C, µs/cm	---	373
3	TDS, ppm	Max 1500	242
4	Alkalinity	80 - 120	87
5	Calcium Hardness	200 - 500	84
6	Residual Chlorine	1.0 - 3.0	1.15
7	Cyanuric Acid	20 - 60	23
8	Dip slide	<10 <sup>3</sup>	ND

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

### COMMENTS AND RECOMMENDATIONS

- All Parameters are within control limit – No action Recommended.
- Please install an automatic swimming pool controller to maintain the desired control parameter

Reported By:  
  
 Murugara  
 Service Engineer  


## SWIMMING POOL - WATER ANALYSIS REPORT

<b>Client Name:</b> TAFAWUQ FACILITY MANAGEMENT, ABU DHABI			
<b>Site Name:</b>	SAS AL NAKHEEL VILLAGE	<b>Visit Date:</b>	08-10-2019
<b>Sampled By:</b>	Crystalline Rep.	<b>Last Visit:</b>	17-09-2019
<b>Source of Sample</b>	Swimming Pool	<b>Sample Point</b>	Kids Swimming Pool

### TEST RESULT

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.38
2	Conductivity at 25°C, µs/cm	---	1904
3	TDS, ppm	Max 1500	1237
4	Alkalinity	80 - 120	94
5	Calcium Hardness	200 - 500	486
6	Residual Chlorine	1.0 - 3.0	1.41
7	Cyanuric Acid	20 - 60	31
8	Dip slide	<10 <sup>3</sup>	ND

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µhos).

### COMMENTS AND RECOMMENDATIONS

- All Parameters are within control limit – No action Recommended.
- Please install an automatic swimming pool controller to maintain the desired control parameter

Reported By,

P. Murugan  
Service Engineer

