

SWIMMING POOL - WATER ANALYSIS REPORT

Client Name: TAFAWUQ FACILITY MANAGEMENT, ABU DHABI			
Site Name:	Al Bateen Park Villa	Visit Date:	06-02-2020
Sampled By:	Crystalline Rep.	Last Visit:	04-01-2020
Source of Sample	Swimming Pool	Sample Point	Main Swimming Pool

TEST RESULT

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.56
2	Conductivity at 25°C, µs/cm	---	374
3	TDS, ppm	Max 1500	243
4	Alkalinity	80 - 120	114
5	Calcium Hardness	200 - 500	204
6	Residual Chlorine	1.0 - 3.0	1.03
7	Cyanuric Acid	20 - 60	31
8	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

- All parameters are within control limit - No action recommended.

Reported By:

Murugaraj

Service Engineer

