

## TEST REPORT

Report No: QMTL/R-140195/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140195
ATTN : MR. JASMAN PINTO		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 02 Jan 2021
		Date Reported	05 Jan 2021
Sample Description	Dental Chair, Dental Treatment Room #01		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020 / 10:55 AM
Sample Container	1x1L PB	Sampling Point	Cup Filler
Sample Receipt Temp	21°C	Sample Onsite Temp	21.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species*	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1*	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15*	ISO 11731:2017 E	-	-	Absent

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
Test method deviation	None
Test performed by Emp#	14 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-140196/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140196
ATTN : MR. JASMAN PINTO		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 02 Jan 2021
		Date Reported	05 Jan 2021
Sample Description	Dental Chair, Dental Treatment Room #02		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020 / 11:00 AM
Sample Container	1x1L PB	Sampling Point	Cup Filler
Sample Receipt Temp	21°C	Sample Onsite Temp	14.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species*	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1*	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15*	ISO 11731:2017 E	-	-	Absent

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	14 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-140197/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140197
ATTN : MR. JASMAN PINTO		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 02 Jan 2021
		Date Reported	05 Jan 2021
Sample Description	Dental Chair, Dental Treatment Room #03		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020 / 11:05 AM
Sample Container	1x1L PB	Sampling Point	Cup Filler
Sample Receipt Temp	21°C	Sample Onsite Temp	15.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species*	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1*	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15*	ISO 11731:2017 E	-	-	Absent

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	14 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By  
**ANILA GEORGE**  
**LABORATORY MANAGER**

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-140198/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140198
<b>ATTN : MR. JASMAN PINTO</b>		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 02 Jan 2021
		Date Reported	05 Jan 2021
Sample Description	<b>Dental Chair, Dental Treatment Room #04</b>		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020 / 11:10 AM
Sample Container	1x1L PB	Sampling Point	Cup Filler
Sample Receipt Temp	21°C	Sample Onsite Temp	21.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species*	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1*	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15*	ISO 11731:2017 E	-	-	Absent

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By  
**ANILA GEORGE**  
**LABORATORY MANAGER**

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-140199/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140199
ATTN : MR. JASMAN PINTO		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 02 Jan 2021
		Date Reported	05 Jan 2021
Sample Description	Dental Chair, Dental Treatment Room #05		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020 / 11:20AM
Sample Container	1x1L PB	Sampling Point	Cup Filler
Sample Receipt Temp	21°C	Sample Onsite Temp	22.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species*	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1*	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15*	ISO 11731:2017 E	-	-	Absent

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	14 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-140200/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140200
ATTN : MR. JASMAN PINTO		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 02 Jan 2021
		Date Reported	05 Jan 2021
Sample Description	Dental Chair, Dental Treatment Room #06		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020 / 11:25 AM
Sample Container	1x1L PB	Sampling Point	Cup Filler
Sample Receipt Temp	21°C	Sample Onsite Temp	21.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species*	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1*	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15*	ISO 11731:2017 E	-	-	Absent

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-140188/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140188
ATTN : MR. JASMAN PINTO		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 25 Dec 2020
		Date Reported	27 Dec 2020
Sample Description	Dental Treatment Room #07		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020 / 11:25 AM
Sample Container	1x500ml PB	Sampling Point	Cup Filler
Sample Receipt Temp	4°C	Sample Onsite Temp	20.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	10@37°C	5
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 H & I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-140189/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140189
<b>ATTN : MR. JASMAN PINTO</b>		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 25 Dec 2020
		Date Reported	27 Dec 2020
Sample Description	<b>Dental Treatment Room #08</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020 / 11:35 AM
Sample Container	1x500ml PB	Sampling Point	Cup Filler
Sample Receipt Temp	4°C	Sample Onsite Temp	15.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	10@37°C	<b>2</b>
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>
E.coli*	APHA 9222 H & I -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By  
**ANILA GEORGE**  
**LABORATORY MANAGER**

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-140190/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140190
ATTN : MR. JASMAN PINTO		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 25 Dec 2020
		Date Reported	27 Dec 2020
Sample Description	Dental Treatment Room #09		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020 / 11:40 AM
Sample Container	1x500ml PB	Sampling Point	Cup Filler
Sample Receipt Temp	4°C	Sample Onsite Temp	24.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	10@37°C	<1
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 H & I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-140191/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140191
ATTN : MR. JASMAN PINTO		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 25 Dec 2020
		Date Reported	27 Dec 2020
Sample Description	Dental Treatment Room #10		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020 / 11:45 AM
Sample Container	1x500ml PB	Sampling Point	Cup Filler
Sample Receipt Temp	4°C	Sample Onsite Temp	15.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	10@37°C	<1
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 H & I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-140192/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140192
ATTN : MR. JASMAN PINTO		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 25 Dec 2020
		Date Reported	27 Dec 2020
Sample Description	Dental Treatment Room #10A		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020 / 10:1:50 AM
Sample Container	1x500ml PB	Sampling Point	Cup Filler
Sample Receipt Temp	4°C	Sample Onsite Temp	15.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	10@37°C	1
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 H & I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-140193/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140193
ATTN : MR. JASMAN PINTO		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 25 Dec 2020
		Date Reported	27 Dec 2020
Sample Description	Dental Treatment Room #11		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020 / 11:55 AM
Sample Container	1x500ml PB	Sampling Point	Cup Filler
Sample Receipt Temp	4°C	Sample Onsite Temp	21.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	10@37°C	9
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 H & I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-140194/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-140194
ATTN : MR. JASMAN PINTO		Date Received	23 Dec 2020
		Date(s) Tested	23 Dec 2020 - 25 Dec 2020
		Date Reported	27 Dec 2020
Sample Description	Dental Treatment Room #12		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	23.12.2020 / 12:00 PM
Sample Container	1x500ml PB	Sampling Point	Cup Filler
Sample Receipt Temp	4°C	Sample Onsite Temp	21.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	10@37°C	5
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 H & I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	14 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT