

## TEST REPORT

Report No: QMTL/R-148323/2021

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148323
		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
<b>ATTN : MR. JASMAN PINTO</b>		Date Reported	28 Feb 2021
Sample Description	<b>Drinking Water Fountain - Level - 1 - ICU</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 2:40 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	<b>6</b>
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSMS ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-148322/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148322
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
		Date Reported	28 Feb 2021
Sample Description	Drinking Water Fountain - P-2 - Opposite MRT		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 2:30 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4°C	Sample Onsite Temp	15°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	5
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSMS ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-148308/2021

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148308
<b>ATTN : MR. JASMAN PINTO</b>		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
		Date Reported	28 Feb 2021
Sample Description	<b>Drinking Water Fountain - Level -2, Hospital</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 12:35 PM
Sample Container	1x500ml PB	Sampling Point	Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	20°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	<b>6</b>
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSMS ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-148309/2021

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148309
<b>ATTN : MR. JASMAN PINTO</b>		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
		Date Reported	28 Feb 2021
Sample Description	<b>Drinking Water Fountain - Level -2, Clinic</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 12:40 PM
Sample Container	1x500ml PB	Sampling Point	Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	16.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	<b>6</b>
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	<b>Zero</b>

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSMS ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By  
**ANILA GEORGE**  
**LABORATORY MANAGER**

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-148310/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148310
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
		Date Reported	28 Feb 2021
Sample Description	Drinking Water Fountain - Ground Floor - Near Conference Room		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 12:45 PM
Sample Container	1x500ml PB	Sampling Point	Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	4
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSMS ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 14
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

**ANILA GEORGE**  
**LABORATORY MANAGER**

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-148311/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148311
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
		Date Reported	28 Feb 2021
Sample Description	Drinking Water Fountain -Ground Floor - Near Prayer Room		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 12:50 PM
Sample Container	1x500ml PB	Sampling Point	Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	<1
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSMS ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-148312/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148312
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 16 Feb 2021
		Date Reported	28 Feb 2021
Sample Description	Drinking Water Fountain -Level-P2- Near Linen Room		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 12:55 PM
Sample Container	1x500ml PB	Sampling Point	Basin
Sample Receipt Temp	4°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL PARAMETERS</b>				
Total Bacterial Count*	APHA 9215 B -23rd Edition	CFU/ml	100	<1
Total Coliforms*	APHA 9222 B -23rd Edition	CFU/100 ml	Zero	Zero
Fecal Coliforms*	APHA 9222 D -23rd Edition	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa*	APHA 9213 E -23rd Edition	CFU/100 ml	Zero	Zero
E.coli*	APHA 9222 I -23rd Edition	CFU/100 ml	Zero	Zero

The Analysis results denoted by (\*) are part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers ( HAAD/HSED/ST/0012/HS_EHSMS ) Water Quality Regulations 2011 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	103 & 14
------------------------	----------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By  
**ANILA GEORGE**  
LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-148373/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148373
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 24 Feb 2021
		Date Reported	03 Mar 2021
Sample Description	Drinking Water Fountain-P-2, Opposite MRT		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 1:30 PM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	15°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (\*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-148374/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148374
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 24 Feb 2021
		Date Reported	03 Mar 2021
Sample Description	Drinking Water Fountain, Level 1, ICU		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 1:40 PM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (\*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**

**LABORATORY MANAGER**

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-148363/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148363
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 24 Feb 2021
		Date Reported	03 Mar 2021
Sample Description	Drinking Water Fountain-Level - P2, Near Linen Room		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 12:55 PM
Sample Container	1x1L PB	Sampling Point	Basin
Sample Receipt Temp	21°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (\*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**

**LABORATORY MANAGER**

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-148362/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148362
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 24 Feb 2021
		Date Reported	03 Mar 2021
Sample Description	Drinking Water Fountain-Ground Floor-Near Prayer Room		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 12:50 PM
Sample Container	1x1L PB	Sampling Point	Basin
Sample Receipt Temp	21°C	Sample Onsite Temp	18°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (\*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**

**LABORATORY MANAGER**

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-148361/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148361
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 24 Feb 2021
		Date Reported	03 Mar 2021
Sample Description	Drinking Water Fountain-Ground Floor-Near Conference Room		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 12:45 PM
Sample Container	1x1L PB	Sampling Point	Basin
Sample Receipt Temp	21°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (\*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE

LABORATORY MANAGER

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-148360/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148360
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 24 Feb 2021
		Date Reported	03 Mar 2021
Sample Description	Drinking Water Fountain, Level-2 Clinic		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 12:40 PM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	16.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (\*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**

**LABORATORY MANAGER**

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-148359/2021

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-148359
ATTN : MR. JASMAN PINTO		Date Received	14 Feb 2021
		Date(s) Tested	14 Feb 2021 - 24 Feb 2021
		Date Reported	03 Mar 2021
Sample Description	Drinking Water Fountain, Level-2 Hospital		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital, Abu Dhabi	Sampling Date/Time	14.02.2021 / 12:35 PM
Sample Container	1x1L PB	Sampling Point	Basin
Sample Receipt Temp	21°C	Sample Onsite Temp	20°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella*	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella Species	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent

The Analysis result denoted by (\*) is part of the laboratory ENAS Accreditation to ISO/IEC 17025 : 2017.

Remarks	The sample meets Department of Energy Water Quality Regulations (5th Edition/Document No-DoE/PD/R01/003)Jan- 2021 requirements for potable water with respect to the above tests only.
Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, DoE: Department of Energy, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar

Test method deviation	None
Test performed by Emp#	103 & 14
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

**ANILA GEORGE**

**LABORATORY MANAGER**

This report is system generated, signature, stamp/ seal are not required.

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**