

TEST REPORT

REPORT NO:-QMTL/R-76389

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-76389
Reference: ADIA - BRC	Sampled By: Client Representative	Date Received: 16.10.2019
Sample Description : BRC- Ground Floor- Main Water Tank Sample Onsite Temp: 31°C Sample Receipt Temp: 26.5°C	Source: GRP Tank	Date(s) Tested: 16-18.10.2019
	Sample Container: 1X 500 ml PB	Date Reported: 22.10.2019
	Sample Appearance: Clear	Date of Sampling: NA
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-76390

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-76390
Reference: ADIA - BRC	Sampled By: Client Representative	Date Received: 16.10.2019
Sample Description : BRC- Ground Floor- Filter Water Tank- 01 Sample Onsite Temp: 30°C Sample Receipt Temp: 26.5°C	Source: GRP Tank	Date(s) Tested: 16-18.10.2019
	Sample Container: 1X 500 ml PB	Date Reported: 22.10.2019
	Sample Appearance: Clear	Date of Sampling: NA
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-76391

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-76391
Reference: ADIA - BRC	Sampled By: Client Representative	Date Received: 16.10.2019
Sample Description : BRC- Ground Floor- Filter Water Tank- 02 Sample Onsite Temp: 31°C Sample Receipt Temp: 26.5°C	Source: GRP Tank	Date(s) Tested: 16-18.10.2019
	Sample Container: 1X 500 ml PB	Date Reported: 22.10.2019
	Sample Appearance: Clear	Date of Sampling: NA
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-76392

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-76392
Reference: ADIA - BRC	Sampled By: Client Representative	Date Received: 16.10.2019
Sample Description : BRC- GF- Pantry- Cold Sample Onsite Temp: 26°C Sample Receipt Temp: 26.5°C	Source: Tap	Date(s) Tested: 16-18.10.2019
	Sample Container: 1X 500 ml PB	Date Reported: 22.10.2019
	Sample Appearance: Clear	Date of Sampling: NA
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-76394

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-76394
Reference: ADIA - BRC	Sampled By: Client Representative	Date Received: 16.10.2019
Sample Description : BRC- GF- Kitchen- Cold Sample Onsite Temp: 28°C Sample Receipt Temp: 26.5°C	Source: Tap	Date(s) Tested: 16-18.10.2019
	Sample Container: 1X 500 ml PB	Date Reported: 22.10.2019
	Sample Appearance: Clear	Date of Sampling: NA
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-76396

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-76396
Reference: ADIA - BRC	Sampled By: Client Representative	Date Received: 16.10.2019
Sample Description : BRC- GF- Female Toilet- Cold Sample Onsite Temp: 24°C Sample Receipt Temp: 26.5°C	Source: Tap	Date(s) Tested: 16-18.10.2019
	Sample Container: 1X 500 ml PB	Date Reported: 22.10.2019
	Sample Appearance: Clear	Date of Sampling: NA
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-76398

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-76398
Reference: ADIA - BRC	Sampled By: Client Representative	Date Received: 16.10.2019
Sample Description : BRC- Mezzanine Male Wash Room, Cold Sample Onsite Temp: 23°C Sample Receipt Temp: 26.5°C	Source: Tap	Date(s) Tested: 16-18.10.2019
	Sample Container: 1X 500 ml PB	Date Reported: 22.10.2019
	Sample Appearance: Clear	Date of Sampling: NA
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-76393

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-76393
Reference: ADIA - BRC	Sampled By: Client Representative	Date Received: 16.10.2019
Sample Description : BRC- GF- Pantry- Hot Sample Onsite Temp: 48°C Sample Receipt Temp: 26.5°C	Source: Tap	Date(s) Tested: 16-18.10.2019
	Sample Container: 1X 500 ml PB	Date Reported: 22.10.2019
	Sample Appearance: Clear	Date of Sampling: NA
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-76395

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-76395
Reference: ADIA - BRC	Sampled By: Client Representative	Date Received: 16.10.2019
Sample Description : BRC- GF- Kitchen- Hot Sample Onsite Temp: 46°C Sample Receipt Temp: 26.5°C	Source: Tap	Date(s) Tested: 16-18.10.2019
	Sample Container: 1X 500 ml PB	Date Reported: 22.10.2019
	Sample Appearance: Clear	Date of Sampling: NA
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-76397

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-76397
Reference: ADIA - BRC	Sampled By: Client Representative	Date Received: 16.10.2019
Sample Description : BRC- GF- Female Toilet- Hot Sample Onsite Temp: 43°C Sample Receipt Temp: 26.5°C	Source: Tap	Date(s) Tested: 16-18.10.2019
	Sample Container: 1X 500 ml PB	Date Reported: 22.10.2019
	Sample Appearance: Clear	Date of Sampling: NA
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-76399

CLIENT: CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-76399
Reference: ADIA - BRC	Sampled By: Client Representative	Date Received: 16.10.2019
Sample Description : BRC- Mezzanine Male Wash Room, Hot Sample Onsite Temp: 46°C Sample Receipt Temp: 26.5°C	Source: Tap	Date(s) Tested: 16-18.10.2019
	Sample Container: 1X 500 ml PB	Date Reported: 22.10.2019
	Sample Appearance: Clear	Date of Sampling: NA
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets with RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT