

TEST REPORT

REPORT NO: - QMTL/R-77473

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 77473
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 26.10.2019
Sample Description : Club House- Pump Room, Filter Tank UG Sample Onsite Temp: 38.1°C Sample Receipt Temp: 8°C	Source: Tank	Date(s) Tested : 26-28.10.2019
	Sample Container: 1 X 500ml PB	Date Reported : 29.10.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-77474

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 77474
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 26.10.2019
Sample Description : Club House- Pump Room, Raw Tank UG Sample Onsite Temp: 37.4°C Sample Receipt Temp: 8°C	Source: Tank	Date(s) Tested : 26-28.10.2019
	Sample Container: 1 X 500ml PB	Date Reported : 29.10.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-77475

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S-77475
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 26.10.2019
Sample Description : Club House- Pump Room, Fire Tank UG Sample Onsite Temp: 35.8°C Sample Receipt Temp: 8°C	Source: Tank	Date(s) Tested : 26-28.10.2019
	Sample Container: 1X 500ml PB	Date Reported : 29.10.2019
	Sample Appearance: Clear	Date of Sampling: NA
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	500	5
Total Coliforms	APHA 9222 B	CFU/100ml	-	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	-	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	-	Zero

REMARKS: The sample meets DM Water Systems quality (2010) specifications for evaporative air coolers, misters, airwashers & humidifiers with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NA: Not Applicable

Report prepared by Emp#: 75
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

TEST REPORT

REPORT NO: - QMTL/R-77477

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 77477
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 26.10.2019
Sample Description : Comfort Station 14, GRP Tank, UG Sample Onsite Temp: 33.2°C Sample Receipt Temp: 8°C	Source: Tank	Date(s) Tested : 26-28.10.2019
	Sample Container: 1 X 500ml PB	Date Reported : 29.10.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-77478

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 77478
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 26.10.2019
Sample Description : Comfort Station 15, GRP Tank 1 Sample Onsite Temp: 29.4°C Sample Receipt Temp: 8°C	Source: Tank	Date(s) Tested : 26-28.10.2019
	Sample Container: 1 X 500ml PB	Date Reported : 29.10.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-77479

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 77479
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 26.10.2019
Sample Description : Comfort Station 15, GRP Tank 2 Sample Onsite Temp: 29.1°C Sample Receipt Temp: 8°C	Source: Tank	Date(s) Tested : 26-28.10.2019
	Sample Container: 1 X 500ml PB	Date Reported : 29.10.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-77480

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 77480
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 26.10.2019
Sample Description : Comfort Station 06, GRP Tank UG Sample Onsite Temp: 31.2°C Sample Receipt Temp: 8°C	Source: Tank	Date(s) Tested : 26-28.10.2019
	Sample Container: 1 X 500ml PB	Date Reported : 29.10.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-77481

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 77481
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 26.10.2019
Sample Description : Tennis Accademy, GRP Tank 1 Sample Onsite Temp: 32.1°C Sample Receipt Temp: 8°C	Source: Tank	Date(s) Tested : 26-28.10.2019
	Sample Container: 1 X 500ml PB	Date Reported : 29.10.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-77482

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 77482
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 26.10.2019
Sample Description : Tennis Accademy, GRP Tank 2 Sample Onsite Temp: 33.9°C Sample Receipt Temp: 8°C	Source: Tank	Date(s) Tested : 26-28.10.2019
	Sample Container: 1 X 500ml PB	Date Reported : 29.10.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-77483

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 77483
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 26.10.2019
Sample Description : Tennis Accademy, GRP Tank 3, Roof Sample Onsite Temp: 35.2°C Sample Receipt Temp: 8°C	Source: Tank	Date(s) Tested : 26-28.10.2019
	Sample Container: 1 X 500ml PB	Date Reported : 29.10.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-77484

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 77484
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 26.10.2019
Sample Description : ETP 1, GRP Tank 1, Roof Sample Onsite Temp: 34.6°C Sample Receipt Temp: 8°C	Source: Tank	Date(s) Tested : 26-28.10.2019
	Sample Container: 1 X 500ml PB	Date Reported : 29.10.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-77485

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 77485
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 26.10.2019
Sample Description : ETP 1, GRP Tank 2, Roof Sample Onsite Temp: 34.2°C Sample Receipt Temp: 8°C	Source: Tank	Date(s) Tested : 26-28.10.2019
	Sample Container: 1 X 500ml PB	Date Reported : 29.10.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-77486

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 77486
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 26.10.2019
Sample Description : ETP 1, GRP Tank 3, Roof Sample Onsite Temp: 34.5°C Sample Receipt Temp: 8°C	Source: Tank	Date(s) Tested : 26-28.10.2019
	Sample Container: 1 X 500ml PB	Date Reported : 29.10.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO: - QMTL/R-77487

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: APHA 9060 A	Sample ID : QMTL/S- 77487
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received : 26.10.2019
Sample Description : Agronomy, UG Tank Sample Onsite Temp: 35.7°C Sample Receipt Temp: 8°C	Source: Tank	Date(s) Tested : 26-28.10.2019
	Sample Container: 1 X 500ml PB	Date Reported : 29.10.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 74 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-77488

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-77488
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received: 26.10.2019
Sample Description : Club House- Pump Room, Filter Tank UG Sample Onsite Temp: 38.1°C Sample Receipt Temp: 17°C	Source: RCC Tank	Date(s) Tested: 26.10-05.11.2019
	Sample Container: 1X 1L PB	Date Reported: 07.11.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent


REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

TEST REPORT

REPORT NO:-QMTL/R-77489

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-77489
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received: 26.10.2019
Sample Description : Club House- Pump Room, Raw Tank UG Sample Onsite Temp: 37.4°C Sample Receipt Temp: 17°C	Source: RCC Tank	Date(s) Tested: 26.10-05.11.2019
	Sample Container: 1X 1L PB	Date Reported: 07.11.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

TEST REPORT

REPORT NO:-QMTL/R-77490

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-77490
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received: 26.10.2019
Sample Description : Club House- Pump Room, Fire Tank UG Sample Onsite Temp: 35.8°C Sample Receipt Temp: 17°C	Source: RCC Tank	Date(s) Tested: 26.10-05.11.2019
	Sample Container: 1X 1L PB	Date Reported: 07.11.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets DM Water Systems quality (2010) specifications for evaporative air coolers, misters, airwashers & humidifiers with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Available

Report prepared by Emp#: 75
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

TEST REPORT

REPORT NO:-QMTL/R-77492

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-77492
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received: 26.10.2019
Sample Description : Comfort Station 14, GRP Tank, UG Sample Onsite Temp: 33.2°C Sample Receipt Temp: 17°C	Source: RCC Tank	Date(s) Tested: 26.10-05.11.2019
	Sample Container: 1X 1L PB	Date Reported: 07.11.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE
LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

TEST REPORT

REPORT NO:-QMTL/R-77493

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-77493
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received: 26.10.2019
Sample Description : Comfort Station 15, GRP Tank 1 Sample Onsite Temp: 29.4°C Sample Receipt Temp: 17°C	Source: RCC Tank	Date(s) Tested: 26.10-05.11.2019
	Sample Container: 1X 1L PB	Date Reported: 07.11.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp# 75
Test Method deviation: None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-77494

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-77494
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received: 26.10.2019
Sample Description : Comfort Station 15, GRP Tank 2 Sample Onsite Temp: 29.1°C Sample Receipt Temp: 17°C	Source: RCC Tank	Date(s) Tested: 26.10-05.11.2019
	Sample Container: 1X 1L PB	Date Reported: 07.11.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-77495

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-77495
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received: 26.10.2019
Sample Description : Comfort Station 06, GRP Tank UG Sample Onsite Temp: 31.2°C Sample Receipt Temp: 17°C	Source: RCC Tank	Date(s) Tested: 26.10-05.11.2019
	Sample Container: 1X 1L PB	Date Reported: 07.11.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-77496

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-77496
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received: 26.10.2019
Sample Description : Tennis Accademy, GRP Tank 1 Sample Onsite Temp: 32.1°C Sample Receipt Temp: 17°C	Source: RCC Tank	Date(s) Tested: 26.10-05.11.2019
	Sample Container: 1X 1L PB	Date Reported: 07.11.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pnueomophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pnueomophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-77497

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-77497
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received: 26.10.2019
Sample Description : Tennis Accademy, GRP Tank 2 Sample Onsite Temp: 33.9°C Sample Receipt Temp: 17°C	Source: RCC Tank	Date(s) Tested: 26.10-05.11.2019
	Sample Container: 1X 1L PB	Date Reported: 07.11.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pnueomphila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pnueomphila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75
Test Method deviation: None
The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-77498

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-77498
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received: 26.10.2019
Sample Description : Tennis Accademy, GRP Tank 3, Roof Sample Onsite Temp: 35.2°C Sample Receipt Temp: 17°C	Source: RCC Tank	Date(s) Tested: 26.10-05.11.2019
	Sample Container: 1X 1L PB	Date Reported: 07.11.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75
Test Method deviation : None
The above test results are only applicable to the sample(s) referred above

Reported By

**ANILA GEORGE
LABORATORY MANAGER**

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

Page 1 of 1

QMTL-FRM-58 Revision : 02; Revision Date : 03.01.2016

TEST REPORT

REPORT NO:-QMTL/R-77499

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-77499
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received: 26.10.2019
Sample Description : ETP 1, GRP Tank 1, Roof Sample Onsite Temp: 34.6°C Sample Receipt Temp: 17°C	Source: RCC Tank	Date(s) Tested: 26.10-05.11.2019
	Sample Container: 1X 1L PB	Date Reported: 07.11.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-77500

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-77500
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received: 26.10.2019
Sample Description : ETP 1, GRP Tank 2, Roof Sample Onsite Temp: 34.2°C Sample Receipt Temp: 17°C	Source: RCC Tank	Date(s) Tested: 26.10-05.11.2019
	Sample Container: 1X 1L PB	Date Reported: 07.11.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-77501

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-77501
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received: 26.10.2019
Sample Description : ETP 1, GRP Tank 3, Roof Sample Onsite Temp: 34.5°C Sample Receipt Temp: 17°C	Source: RCC Tank	Date(s) Tested: 26.10-05.11.2019
	Sample Container: 1X 1L PB	Date Reported: 07.11.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-77502

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN:MR. JASMAN PINTO		
Product: Water	Sampling Method: BS 7592	Sample ID: QMTL/S-77502
Reference: JUMEIRAH GOLF ESTATES	Sampled By: QMTL Representative	Date Received: 26.10.2019
Sample Description : Agronomy, UG Tank Sample Onsite Temp: 35.7°C Sample Receipt Temp: 17°C	Source: RCC Tank	Date(s) Tested: 26.10-05.11.2019
	Sample Container: 1X 1L PB	Date Reported: 07.11.2019
	Sample Appearance: Clear	Date of Sampling: 26.10.2019
On-Site Treatment: NA	Tested by Emp#: 14 & 55	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-14	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT