

## SWIMMING POOL - WATER ANALYSIS REPORT

**Client Name:** TAFAWUQ FACILITY MANAGEMENT, ABU DHABI

<b>Site Name:</b>	AL NOOR TOWER	<b>Visit Date:</b>	03-05-2020
-------------------	---------------	--------------------	------------

<b>Source of Sample</b>	Swimming Pool	<b>Sample Point</b>	Main Swimming Pool
-------------------------	---------------	---------------------	--------------------


### TEST RESULT

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.42
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	---	268
3	TDS, ppm	Max 1500	174
4	Alkalinity	80 - 120	81
5	Calcium Hardness	200 - 500	156
6	Residual Chlorine	1.0 - 3.0	1.21
7	Cyanuric Acid	20 - 60	21
8	Dip slide	$<10^3$	ND

\*\*\* All test results expressed in parts per million (ppm) as  $\text{CaCO}_3$  except pH and conductivity ( $\mu\text{mhos}$ ).

### COMMENTS AND RECOMMENDATIONS

- All Parameters are within control limit – No action Recommended.

Reported By,  
  
 Murugaraj  
 Service Engineer

