

SWIMMING POOL - WATER ANALYSIS REPORT

Client Name: TAFAWUQ FACILITY MANAGEMENT, ABU DHABI			
Site Name:	AL RAYYANA	Visit Date:	03-06-2020
Sampled By	Crystalline Rep	Last visit:	03-05-2020
Source of Sample	Swimming Pool	Sample Point	Main Swimming Pool

TEST RESULT

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.54
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	---	265
3	TDS, ppm	Max 1500	172
4	Alkalinity	80 - 120	82
5	Calcium Hardness	200 - 500	211
6	Residual Chlorine	1.0 - 3.0	1.19
7	Cyanuric Acid	20 - 60	20
8	Dip slide	$<10^3$	ND

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS AND RECOMMENDATIONS

- All Parameters are within control limit - No action Recommended.

Reported By,
P. Murugaraj
Murugaraj
Service Engineer

