



SWIMMING POOL - WATER ANALYSIS REPORT

Client Name: TAFAWUQ FACILITY MANAGEMENT, ABU DHABI			
Site Name:	SAS AL NAKHEEL VILLAGE	Visit Date:	03-06-2020
Sampled By:	Crystalline Rep.	Last Visit:	01-05-2020
Source of Sample	Swimming Pool	Sample Point	Main Swimming Pool

TEST RESULT


No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.55
2	Conductivity at 25°C, µs/cm	---	409
3	TDS, ppm	Max 1500	265
4	Alkalinity	80 - 120	80
5	Calcium Hardness	200 - 500	204
6	Residual Chlorine	1.0 - 3.0	1.07
7	Cyanuric Acid	20 - 60	22
8	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

- All Parameters are within control limit – No action Recommended.

Reported By,
P. Murugaraj
Murugaraj
Service Engineer



SWIMMING POOL - WATER ANALYSIS REPORT

Client Name: TAFAWUQ FACILITY MANAGEMENT, ABU DHABI			
Site Name:	SAS AL NAKHEEL VILLAGE	Visit Date:	03-06-2020
Sampled By:	Crystalline Rep.	Last Visit:	01-05-2020
Source of Sample	Swimming Pool	Sample Point	Kids Swimming Pool

TEST RESULT			
No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.37
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	---	1358
3	TDS, ppm	Max 1500	882
4	Alkalinity	80 - 120	89
5	Calcium Hardness	200 - 500	274
6	Residual Chlorine	1.0 - 3.0	1.12
7	Cyanuric Acid	20 - 60	25
8	Dip slide	$<10^3$	ND

** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).*

COMMENTS AND RECOMMENDATIONS
<ul style="list-style-type: none"> All Parameters are within control limit - No action Recommended.

Reported By,

P. Murugan
Murugan
Service Engineer

