

TEST REPORT

Report No:QMTL/R-107619/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		Sample ID	QMTL/S-107619
P.O.Box.131463, Abu Dhabi, U.A.E		Date Received	16 Jun 2020
Ph:02-6508930/0557167017		Date(s) Tested	16 Jun 2020-20 Jun 2020
ATTN: Mr. JASMAN PINTO		Date Reported	21 Jun 2020
Sample Description	Level 4, Clinic Dental Water Storage		
Sample Type	Water	Sampling Method	QMTL-SOP- 128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 10:30 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample On-site Temp	18°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 rd EDITION)	UNITS	RESULTS
CHEMICAL ANALYSIS			
pH @24°C	APHA 4500-H ⁺ B	-	7.76
Conductivity@24.1°C	APHA 2510 B	µs/cm	227
Total Suspended Solids @105°C	APHA 2540-D	mg/L	<3
Total Dissolved Solids @180°C	APHA 2540-C	mg/L	136
Total Hardness as(CaCO ₃)	APHA 2340-C	mg/L	60.2
Total Alkalinity to pH 4.4	APHA 2320-B	mg/L	41
Chloride (Cl)	APHA 4500-Cl ⁻ B	mg/L	40.6
Iron (Fe)	APHA 3120 B	mg/L	<0.05

Remarks	Nil
---------	-----

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
----------	--

Test Method Deviation	None
Test performed by Emp#	13
Report prepared by Emp#	75

The above test results are only applicable to the sample(s) referred above.

Reported By


ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107610/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-107610	
	Date Received	16 Jun 2020	
	Date(s) Tested	16 Jun 2020 - 18 Jun 2020	
	Date Reported	24 Jun 2020	
Sample Description	Level- 4, Clinic Dental Water Storage		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 10:10 AM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample Onsite Temp	18°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107620/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		Sample ID	QMTL/S-107620
P.O.Box.131463, Abu Dhabi, U.A.E		Date Received	16 Jun 2020
Ph:02-6508930/0557167017		Date(s) Tested	16 Jun 2020-20 Jun 2020
ATTN: Mr. JASMAN PINTO		Date Reported	21 Jun 2020
Sample Description	DSU Softner		
Sample Type	Water	Sampling Method	QMTL-SOP- 128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 11:30 AM
Sample Container	1x500 ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample On-site Temp	33.6°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 rd EDITION)	UNITS	GUIDELINES	RESULTS
CHEMICAL ANALYSIS				
pH @24°C	APHA 4500-H ⁺ B	-	7.0-9.2	7.90
Conductivity@24°C	APHA 2510 B	µs/cm	-	203.2
Total Suspended Solids @105°C	APHA 2540-D	mg/L	-	<3
Total Hardness as(CaCO ₃)	APHA 2340-C	mg/L	Max 300	60.2
Chloride (Cl)	APHA 4500-Cl B	mg/L	Max 250	46.5
Calcium (Ca)	APHA 3500-Ca B	mg/L	-	21
Iron (Fe)	APHA 3120 B	mg/L	Max 0.2	<0.05

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided
----------	---

Test Method Deviation	None
Test performed by Emp#	13
Report prepared by Emp#	75

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No:QMTL/R-107621/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		Sample ID	QMTL/S-107621
		Date Received	16 Jun 2020
		Date(s) Tested	16 Jun 2020-20 Jun 2020
ATTN: Mr. JASMAN PINTO		Date Reported	21 Jun 2020
Sample Description	CSSD Preparation		
Sample Type	Water	Sampling Method	QMTL-SOP- 128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 11:50 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample On-site Temp	20.6°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 rd EDITION)	UNITS	GUIDELINES	RESULTS
CHEMICAL ANALYSIS				
pH @24.1°C	APHA 4500-H ⁺ B	-	7.0-9.2	7.97
Conductivity@24.1°C	APHA 2510 B	µs/cm	-	200
Total Suspended Solids @105°C	APHA 2540-D	mg/L	-	<3
Total Hardness as(CaCO ₃)	APHA 2340-C	mg/L	Max 300	58.2
Chloride (Cl)	APHA 4500-Cl ⁻ B	mg/L	Max 250	41.6
Calcium (Ca)	APHA 3500-Ca B	mg/L	-	20.2
Iron (Fe)	APHA 3120 B	mg/L	Max 0.2	<0.05

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided
----------	---

Test Method Deviation	None
Test performed by Emp#	13
Report prepared by Emp#	75

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107622/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		Sample ID	QMTL/S-107622
		Date Received	16 Jun 2020
		Date(s) Tested	16 Jun 2020-20 Jun 2020
ATTN: Mr. JASMAN PINTO		Date Reported	21 Jun 2020
Sample Description	RO Plant		
Sample Type	Water	Sampling Method	QMTL-SOP- 128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 12:00 PM
Sample Container	1x500ml PB	Sampling Point	Tank
Sample Receipt Temp	4°C	Sample On-site Temp	18°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 rd EDITION)	UNITS	GUIDELINES	RESULTS
CHEMICAL ANALYSIS				
pH @24.1°C	APHA 4500-H ⁺ B	-	7.0-9.2	8.21
Conductivity@24.1°C	APHA 2510 B	µs/cm	-	22.7
Total Suspended Solids @105°C	APHA 2540-D	mg/L	-	<3
Total Hardness as(CaCO ₃)	APHA 2340-C	mg/L	Max 300	<3
Chloride (Cl)	APHA 4500-Cl ⁻ B	mg/L	Max 250	<3
Calcium (Ca)	APHA 3500-Ca B	mg/L	-	<3
Iron (Fe)	APHA 3120 B	mg/L	Max 0.2	<0.05

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided
----------	---

Test Method Deviation	None
Test performed by Emp#	13
Report prepared by Emp#	75
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107623/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		Sample ID	QMTL/S-107623
		Date Received	16 Jun 2020
		Date(s) Tested	16 Jun 2020-20 Jun 2020
ATTN: Mr. JASMAN PINTO		Date Reported	21 Jun 2020
Sample Description	Operation Theatre #6		
Sample Type	Water	Sampling Method	QMTL-SOP- 128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 12:15 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample On-site Temp	35°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 rd EDITION)	UNITS	GUIDELINES	RESULTS
CHEMICAL ANALYSIS				
pH @24.2°C	APHA 4500-H ⁺ B	-	7.0-9.2	7.76
Conductivity@24.1°C	APHA 2510 B	µs/cm	-	196
Total Suspended Solids @105°C	APHA 2540-D	mg/L	-	<3
Total Hardness as(CaCO ₃)	APHA 2340-C	mg/L	Max 300	56.3
Chloride (Cl)	APHA 4500-Cl ·B	mg/L	Max 250	42.1
Calcium (Ca)	APHA 3500-Ca B	mg/L	-	19.5
Iron (Fe)	APHA 3120 B	mg/L	Max 0.2	<0.05

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided
----------	---

Test Method Deviation	None
Test performed by Emp#	13
Report prepared by Emp#	75
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No:QMTL/R-107616/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		Sample ID	QMTL/S-107616
		Date Received	16 Jun 2020
		Date(s) Tested	16 Jun 2020-20 Jun 2020
ATTN: Mr. JASMAN PINTO		Date Reported	21 Jun 2020
Sample Description	ICLDC Lab, Hand Wash		
Sample Type \	Water	Sampling Method	QMTL-SOP- 128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 09:30 AM
Sample Container	1x500 ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample On-site Temp	27°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 rd EDITION)	UNITS	GUIDELINES	RESULTS
CHEMICAL ANALYSIS				
pH @24.1°C	APHA 4500-H ⁺ B	-	7.0-9.2	7.83
Conductivity@24.1°C	APHA 2510 B	µs/cm	-	223.7
Total Dissolved Solids@180°C	APHA 2540-C	mg/L	Min100-Max1000	135
Total Hardness as(CaCO ₃)	APHA 2340-C	mg/L	Max 300	58.2
Chloride (Cl)	APHA 4500-Cl ·B	mg/L	Max 250	37.0
Calcium (Ca)	APHA 3500-Ca B	mg/L	-	20.2
Iron (Fe)	APHA 3120 B	mg/L	Max 0.2	<0.05

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided
----------	---

Test Method Deviation	None
Test performed by Emp#	13
Report prepared by Emp#	75

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107607/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-107607
		Date Received	16 Jun 2020
		Date(s) Tested	16 Jun 2020 - 18 Jun 2020
ATTN : MR. JASMAN PINTO		Date Reported	24 Jun 2020
Sample Description	ICDLC Lab- Hand Wash		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 9:30 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample Onsite Temp	27°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107612/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-107612		
	Date Received	16 Jun 2020		
	Date(s) Tested	16 Jun 2020 - 26 Jun 2020		
	Date Reported	29 Jun 2020		
Sample Description	ICLDC Lab- Hand Wash			
Sample Type	Water	Sampling Method	QMTL-WI-16	
Client Name/Project	NP	Sampled By	QMTL Representative	
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 9:40 AM	
Sample Container	1X1L PB	Sampling Point	Tap	
Sample Receipt Temp	20°C	Sample Onsite Temp	27°C	
Sample Appearance	Clear	On-site Treatment	NA	
Reference	NP			

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107617/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		Sample ID	QMTL/S-107617
		Date Received	16 Jun 2020
		Date(s) Tested	16 Jun 2020-20 Jun 2020
ATTN: Mr. JASMAN PINTO		Date Reported	21 Jun 2020
Sample Description	ICLDC Lab - Eye Wash		
Sample Type \	Water	Sampling Method	QMTL-SOP- 128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 09:50 AM
Sample Container	1x500 ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample On-site Temp	18.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 rd EDITION)	UNITS	GUIDELINES	RESULTS
CHEMICAL ANALYSIS				
pH @24°C	APHA 4500-H ⁺ B	-	7.0-9.2	7.42
Conductivity@24.1°C	APHA 2510 B	µs/cm	-	220.3
Total Dissolved Solids@180°C	APHA 2540-C	mg/L	Min100-Max1000	137
Total Hardness as(CaCO ₃)	APHA 2340-C	mg/L	Max 300	56.3
Chloride (Cl)	APHA 4500-Cl B	mg/L	Max 250	36.2
Calcium (Ca)	APHA 3500-Ca B	mg/L	-	20.2
Iron (Fe)	APHA 3120 B	mg/L	Max 0.2	<0.05

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided
----------	---

Test Method Deviation	None
Test performed by Emp#	13
Report prepared by Emp#	75

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107608/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-107608	
	Date Received	16 Jun 2020	
	Date(s) Tested	16 Jun 2020 - 18 Jun 2020	
	Date Reported	24 Jun 2020	
ATTN : MR. JASMAN PINTO			
Sample Description	ICDLC Lab - Emergency Eye Wash		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 9:50 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample Onsite Temp	18.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107613/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-107613
		Date Received	16 Jun 2020
		Date(s) Tested	16 Jun 2020 - 26 Jun 2020
ATTN : MR. JASMAN PINTO		Date Reported	29 Jun 2020
Sample Description	ICLDC Lab- Eye Wash		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 9:55 AM
Sample Container	1X1L PB	Sampling Point	Tap
Sample Receipt Temp	20°C	Sample Onsite Temp	18.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By


ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107618/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		Sample ID	QMTL/S-107618
ATTN: Mr. JASMAN PINTO		Date Received	16 Jun 2020
		Date(s) Tested	16 Jun 2020-20 Jun 2020
		Date Reported	21 Jun 2020
Sample Description	ICLDC Lab- Millipore		
Sample Type	Water	Sampling Method	QMTL-SOP- 128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 10:10 AM
Sample Container	1x500 ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample On-site Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 rd EDITION)	UNITS	RESULTS
CHEMICAL ANALYSIS			
pH @24.1°C	APHA 4500-H ⁺ B	-	7.82
Conductivity@24.1°C	APHA 2510 B	µs/cm	0.82
Total Suspended Solids @105°C	APHA 2540-D	mg/L	<3
Total Dissolved Solids @180°C	APHA 2540-C	mg/L	<6
Total Hardness as(CaCO ₃)	APHA 2340-C	mg/L	<3
Total Alkalinity to pH 4.4	APHA 2320-B	mg/L	<0.20
Chloride (Cl)	APHA 4500-Cl B	mg/L	<3
Iron (Fe)	APHA 3120 B	mg/L	<0.05

Remarks	Nil
---------	-----

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
----------	--

Test Method Deviation	None
Test performed by Emp#	13
Report prepared by Emp#	75

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107609/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-107609
		Date Received	16 Jun 2020
		Date(s) Tested	16 Jun 2020 - 18 Jun 2020
		Date Reported	24 Jun 2020
ATTN : MR. JASMAN PINTO			
Sample Description	ICDLC Lab- Millipore		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 10:00 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	(10/1000ml)	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero

Remarks	The sample meets with ASTM D 1193 Standard Specification for Reagent Water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, ASTM: American Society for Testing and Materials, NA: Not Applicable, WI: Work Instruction, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107614/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-107614
		Date Received	16 Jun 2020
		Date(s) Tested	16 Jun 2020 - 26 Jun 2020
		Date Reported	29 Jun 2020
Sample Description	ICLDC Lab- Millipore		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	16.06.2020/ 10:15 AM
Sample Container	1X1L PB	Sampling Point	Tap
Sample Receipt Temp	20°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	RESULTS
LEGIONELLA ANALYSIS			
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	Absent
Legionella Species	ISO 11731:2017 E	-	Absent

Remarks	The sample meets with ASTM D 1193 Standard Specification for Reagent Water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, ASTM: American Society for Testing and Materials, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107456/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		Sample ID	QMTL/S-107456
		Date Received	15 Jun 2020
		Date(s) Tested	15 Jun 2020-19 Jun 2020
		Date Reported	21 Jun 2020
ATTN: Mr. JASMAN PINTO			
Sample Description	Emergency Eye Wash, NRL Lab		
Sample Type	Water	Sampling Method	QMTL-SOP- 128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	15.06.2020/10:05 AM
Sample Container	1x500 ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample On-site Temp	NP
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 rd EDITION)	UNITS	GUIDELINES	RESULTS
CHEMICAL ANALYSIS				
pH @24.1°C	APHA 4500-H ⁺ B	-	7.0-9.2	7.52
Conductivity@24.1°C	APHA 2510 B	µs/cm	-	220
Total Dissolved Solids@180°C	APHA 2540-C	mg/L	Min 100-Max 1000	132
Total Hardness as(CaCO ₃)	APHA 2340-C	mg/L	Max 300	58.2
Chloride (Cl)	APHA 4500-Cl B	mg/L	Max 250	35.2
Calcium (Ca)	APHA 3500-Ca B	mg/L	-	21.7
Iron (Fe)	APHA 3120 B	mg/L	Max 0.2	<0.05

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided
----------	---

Test Method Deviation	None
Test performed by Emp#	13
Report prepared by Emp#	75
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107438/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-107438	
	Date Received	15 Jun 2020	
	Date(s) Tested	15 Jun 2020 - 17 Jun 2020	
	Date Reported	21 Jun 2020	
Sample Description	Emergency Eye Wash, NRL Lab		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	15.06.2020 / 10.05 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107446/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-107446
ATTN : MR. JASMAN PINTO		Date Received	15 Jun 2020
		Date(s) Tested	15 Jun 2020 - 25 Jun 2020
		Date Reported	30 Jun 2020
Sample Description	Emergency Eye Wash, NRL Lab		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	15.06.2020/ 10:00 AM
Sample Container	1X1L PB	Sampling Point	Tap
Sample Receipt Temp	18°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107457/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		Sample ID	QMTL/S-107457
		Date Received	15 Jun 2020
		Date(s) Tested	15 Jun 2020-19 Jun 2020
ATTN: Mr. JASMAN PINTO		Date Reported	21 Jun 2020
Sample Description	Hand Wash, NRL Lab		
Sample Type	Water	Sampling Method	QMTL-SOP- 128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	15.06.2020/ 10:35 AM
Sample Container	1x500 ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample On-site Temp	NP
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 rd EDITION)	UNITS	GUIDELINES	RESULTS
CHEMICAL ANALYSIS				
pH @24.1°C	APHA 4500-H ⁺ B	-	7.0-9.2	7.42
Conductivity@24.1°C	APHA 2510 B	µs/cm	-	219.2
Total Dissolved Solids@180°C	APHA 2540-C	mg/L	Min 100-Max 1000	130
Total Hardness as(CaCO ₃)	APHA 2340-C	mg/L	Max 300	56.3
Chloride (Cl)	APHA 4500-Cl B	mg/L	Max 250	34.7
Calcium (Ca)	APHA 3500-Ca B	mg/L	-	21.7
Iron (Fe)	APHA 3120 B	mg/L	Max 0.2	<0.05

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided
----------	---

Test Method Deviation	None
Test performed by Emp#	13
Report prepared by Emp#	75
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107439/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-107439
		Date Received	15 Jun 2020
		Date(s) Tested	15 Jun 2020 - 17 Jun 2020
		Date Reported	21 Jun 2020
ATTN : MR. JASMAN PINTO			
Sample Description	Hand Wash, NRL Lab		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	15.06.2020 / 10.35 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample Onsite Temp	25.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107447/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-107447
		Date Received	15 Jun 2020
		Date(s) Tested	15 Jun 2020 - 25 Jun 2020
ATTN : MR. JASMAN PINTO		Date Reported	30 Jun 2020
Sample Description	Hand Wash, NRL Lab		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	15.06.2020/ 10:10 AM
Sample Container	1X1L PB	Sampling Point	Tap
Sample Receipt Temp	18°C	Sample Onsite Temp	25.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107458/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		Sample ID	QMTL/S-107458
		Date Received	15 Jun 2020
		Date(s) Tested	15 Jun 2020-19 Jun 2020
ATTN: Mr. JASMAN PINTO		Date Reported	21 Jun 2020
Sample Description	Millipore, NRL Lab		
Sample Type	Water	Sampling Method	QMTL-SOP- 128
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	15.06.2020/10:55 AM
Sample Container	1x500 ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample On-site Temp	NP
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 rd EDITION)	UNITS	RESULTS
CHEMICAL ANALYSIS			
pH @24.1°C	APHA 4500-H ⁺ B	-	8.02
Conductivity@24.1°C	APHA 2510 B	µs/cm	1.06
Total Suspended Solids @105°C	APHA 2540-D	mg/L	<3
Total Dissolved Solids @180°C	APHA 2540-C	mg/L	<6
Total Hardness as(CaCO ₃)	APHA 2340-C	mg/L	<3
Total Alkalinity	APHA 2320-B	mg/L	<0.20
Chloride (Cl)	APHA 4500-Cl B	mg/L	<3
Iron (Fe)	APHA 3120 B	mg/L	<0.05

Remarks	Nil
---------	-----

Keywords	pH: Potential Hydrogen, APHA: American Public Health Association, SOP: Standard Operating Procedure, NA: Not Applicable, NP: Not Provided.
----------	--

Test Method Deviation	None
Test performed by Emp#	13
Report prepared by Emp#	75

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107440/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-107440
ATTN : MR. JASMAN PINTO		Date Received	15 Jun 2020
		Date(s) Tested	15 Jun 2020 - 17 Jun 2020
		Date Reported	21 Jun 2020
Sample Description	Millipore, NRL Lab		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	15.06.2020 / 10.55 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	4°C	Sample Onsite Temp	22.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	(10/1000ml)	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero


Remarks	The sample meets with ASTM D 1193 Standard Specification for Reagent Water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, ASTM: American Society for Testing and Materials, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-107448/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-107448
ATTN : MR. JASMAN PINTO		Date Received	15 Jun 2020
		Date(s) Tested	15 Jun 2020 - 25 Jun 2020
		Date Reported	30 Jun 2020
Sample Description	Millipore, NRL Lab		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital - Abu Dhabi	Sampling Date/Time	15.06.2020/ 10:20 AM
Sample Container	1X1L PB	Sampling Point	Tap
Sample Receipt Temp	18°C	Sample Onsite Temp	22.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	RESULTS
LEGIONELLA ANALYSIS			
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	Absent
Legionella Species	ISO 11731:2017 E	-	Absent

Remarks	NP
---------	----

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA: Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT