



Microbiology Test Report

Report No. WA-R-L-2005-9419

Customer Details

Crystalline Environmental Services



Request No.	: WA-Q-L-2005-1485	Sample No.	: WA-S-L-2005-9210
Sampling Date/time	: 18/5/2020 , 12:00	Report Date.	: 21/5/2020
Analysis Start Date.	: 18/5/2020	Analysis End Date.	: 20/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 0901	Sampling Method	: APHA 9060 A & B
Temperature °C	: 23.4	Site Observation	: Clear
Sampling Container	: Sterile Glass Bottle	Source of Sample	: Dental Chair - Cup Filler
Sampling Point	: Dental Clinic: Dental Chair - 1	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml*
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml*
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

*Limit based on HAAD/HED/ST/0012/HS_EHSMS, Department of Health Abu Dhabi, water quality version 1.0

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.



مختبرات ويمبي ذ م م
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034
Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2005-9419

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2005-9420



Request No.	: WA-Q-L-2005-1485	Sample No.	: WA-S-L-2005-9211
Sampling Date/time	: 18/5/2020 , 12:00	Report Date.	: 21/5/2020
Analysis Start Date.	: 18/5/2020	Analysis End Date.	: 20/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 0901	Sampling Method	: APHA 9060 A & B
Temperature °C	: 22.3	Site Observation	: Clear
Sampling Container	: Sterile Glass Bottle	Source of Sample	: Dental Chair - Cup Filler
Sampling Point	: Dental Clinic: Dental Chair - 2	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml*
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml*
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

*Limit based on HAAD/HED/ST/0012/HS_EHSMS, Department of Health Abu Dhabi, water quality version 1.0

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.



مختبرات ويمبي ذم م
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034

Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2005-9420

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2005-9421



Request No.	: WA-Q-L-2005-1485	Sample No.	: WA-S-L-2005-9212
Sampling Date/time	: 18/5/2020 , 12:00	Report Date.	: 21/5/2020
Analysis Start Date.	: 18/5/2020	Analysis End Date.	: 20/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 0901	Sampling Method	: APHA 9060 A & B
Temperature °C	: 23	Site Observation	: Clear
Sampling Container	: Sterile Glass Bottle	Source of Sample	: Dental Chair - Cup Filler
Sampling Point	: Dental Clinic: Dental Chair - 3	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml*
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml*
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

*Limit based on HAAD/HED/ST/0012/HS_EHSMS, Department of Health Abu Dhabi, water quality version 1.0

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.



مختبرات ويمبي ذ.م.م
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034

Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2005-9421

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Report No. WA-R-L-2005-9422

Crystalline Environmental Services



Request No.	: WA-Q-L-2005-1485	Sample No.	: WA-S-L-2005-9213
Sampling Date/time	: 18/5/2020 , 12:00	Report Date.	: 21/5/2020
Analysis Start Date.	: 18/5/2020	Analysis End Date.	: 20/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 0901	Sampling Method	: APHA 9060 A & B
Temperature °C	: 22.5	Site Observation	: Clear
Sampling Container	: Sterile Glass Bottle	Source of Sample	: Dental Chair - Cup Filler
Sampling Point	: Dental Clinic: Dental Chair - 4	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml*
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml*
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

*Limit based on HAAD/HED/ST/0012/HS_EHSMS, Department of Health Abu Dhabi, water quality version 1.0

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.



مختبرات ويمبي ذ م م
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034

Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2005-9422

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2005-9423



Request No.	: WA-Q-L-2005-1485	Sample No.	: WA-S-L-2005-9214
Sampling Date/time	: 18/5/2020 , 12:00	Report Date.	: 21/5/2020
Analysis Start Date.	: 18/5/2020	Analysis End Date.	: 20/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 0902	Sampling Method	: APHA 9060 A & B
Temperature °C	: 28.1	Site Observation	: Clear
Sampling Container	: Sterile Glass Bottle	Source of Sample	: Dental Chair - Cup Filler
Sampling Point	: Dental Clinic: Dental Chair - 5	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml*
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml*
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

*Limit based on HAAD/HED/ST/0012/HS_EHSMS, Department of Health Abu Dhabi, water quality version 1.0

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.



مختبرات ويمبي ذم م
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034

Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2005-9423

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2005-9424



Request No.	: WA-Q-L-2005-1485	Sample No.	: WA-S-L-2005-9215
Sampling Date/time	: 18/5/2020 , 12:00	Report Date.	: 21/5/2020
Analysis Start Date.	: 18/5/2020	Analysis End Date.	: 20/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 0902	Sampling Method	: APHA 9060 A & B
Temperature °C	: 20.5	Site Observation	: Clear
Sampling Container	: Sterile Glass Bottle	Source of Sample	: Dental Chair - Cup Filler
Sampling Point	: Dental Clinic: Dental Chair - 6	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	100CFU/ml*
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	Zero/100ml*
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	Zero/100ml

Note : Not Detected=<1CFU

*Limit based on HAAD/HED/ST/0012/HS_EHSMS, Department of Health Abu Dhabi, water quality version 1.0

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.



مختبرات ويمبي ذ م م
Wimpey Laboratories LLC

P.O. Box 115086, Musaffah M-34, Abu Dhabi, U.A.E.
Tel: +971 2 5503324, Fax: +971 2 5503387



Testing - NAL 034

Testing - NAL 034

Microbiology Test Report

Report No. : WA-R-L-2005-9424

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2005-9436



Request No.	: WA-Q-L-2005-1485	Sample No.	: WA-S-L-2005-9227
Sampling Date/time	: 18/5/2020 , 12:00	Report Date.	: 28/5/2020
Analysis Start Date.	: 18/5/2020	Analysis End Date.	: 28/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 0902	Sampling Method	: BS 7592
Temperature °C	: 21.3	Site Observation	: Clear
Sampling Container	: Sterile Glass Bottle	Source of Sample	: Dental Chair - Cup Filler
Sampling Point	: Dental Clinic: Dental Chair - 7	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	100CFU/100ml

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limit based on HAAD/HED/ST/0012/HS_EHSMS, Department of Health Abu Dhabi, water quality version 1.0.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2005-9437



Request No.	: WA-Q-L-2005-1485	Sample No.	: WA-S-L-2005-9228
Sampling Date/time	: 18/5/2020 , 12:00	Report Date.	: 28/5/2020
Analysis Start Date.	: 18/5/2020	Analysis End Date.	: 28/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 0902	Sampling Method	: BS 7592
Temperature °C	: 22.3	Site Observation	: Clear
Sampling Container	: Sterile Glass Bottle	Source of Sample	: Dental Chair - Cup Filler
Sampling Point	: Dental Clinic: Dental Chair - 8	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	100CFU/100ml

Note : Limit of Detection= \leq 1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limit based on HAAD/HED/ST/0012/HS_EHSMS, Department of Health Abu Dhabi, water quality version 1.0.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2005-9438

Crystalline Environmental Services



Request No.	: WA-Q-L-2005-1485	Sample No.	: WA-S-L-2005-9229
Sampling Date/time	: 18/5/2020 , 12:00	Report Date.	: 28/5/2020
Analysis Start Date.	: 18/5/2020	Analysis End Date.	: 28/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 0902	Sampling Method	: BS 7592
Temperature °C	: 23.1	Site Observation	: Clear
Sampling Container	: Sterile Glass Bottle	Source of Sample	: Dental Chair - Cup Filler
Sampling Point	: Dental Clinic: Dental Chair - 9	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	100CFU/100ml

Note : Limit of Detection= \leq 1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limit based on HAAD/HED/ST/0012/HS_EHSMS, Department of Health Abu Dhabi, water quality version 1.0.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Report No. WA-R-L-2005-9439

Customer Details

Crystalline Environmental Services



Request No.	: WA-Q-L-2005-1485	Sample No.	: WA-S-L-2005-9230
Sampling Date/time	: 18/5/2020 , 12:00	Report Date.	: 28/5/2020
Analysis Start Date.	: 18/5/2020	Analysis End Date.	: 28/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 0902	Sampling Method	: BS 7592
Temperature °C	: 22	Site Observation	: Clear
Sampling Container	: Sterile Glass Bottle	Source of Sample	: Dental Chair - Cup Filler
Sampling Point	: Dental Clinic: Dental Chair - 10	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	100CFU/100ml

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limit based on HAAD/HED/ST/0012/HS_EHSMS, Department of Health Abu Dhabi, water quality version 1.0.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES

CRYSTALLINE CLEANING & ENVIRONMENTAL SERVICES P.O.Box: 131463
Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE. Tel: 971 265 08930; Fax:
971 265 8942

Report No. WA-R-L-2005-9442



Request No.	: WA-Q-L-2005-1485	Sample No.	: WA-S-L-2005-9233
Sampling Date/time	: 18/5/2020 , 12:00	Report Date.	: 28/5/2020
Analysis Start Date.	: 18/5/2020	Analysis End Date.	: 28/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 0903	Sampling Method	: BS 7592
Temperature °C	: 23.7	Site Observation	: Clear
Sampling Container	: Sterile Glass Bottle	Source of Sample	: Dental Chair - Cup Filler
Sampling Point	: Dental clinic- Dental Chair -10A	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	100CFU/100ml

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed
by Washing Procedure in Funnel.

Limit based on HAAD/HED/ST/0012/HS_EHSMS, Department of Health Abu Dhabi, water quality version 1.0.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D.
Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Environmental Services

Report No. WA-R-L-2005-9440



Request No.	: WA-Q-L-2005-1485	Sample No.	: WA-S-L-2005-9231
Sampling Date/time	: 18/5/2020 , 12:00	Report Date.	: 28/5/2020
Analysis Start Date.	: 18/5/2020	Analysis End Date.	: 28/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 0902	Sampling Method	: BS 7592
Temperature °C	: Not Given	Site Observation	: Clear
Sampling Container	: Sterile Glass Bottle	Source of Sample	: Dental Chair - Cup Filler
Sampling Point	: Dental Clinic: Dental Chair - 11	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	100CFU/100ml

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limit based on HAAD/HED/ST/0012/HS_EHSMS, Department of Health Abu Dhabi, water quality version 1.0.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2005-9441

Crystalline Environmental Services



Request No.	: WA-Q-L-2005-1485	Sample No.	: WA-S-L-2005-9232
Sampling Date/time	: 18/5/2020 , 12:00	Report Date.	: 28/5/2020
Analysis Start Date.	: 18/5/2020	Analysis End Date.	: 28/5/2020
Sample Location.	: Health Point Hospital	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 0903	Sampling Method	: BS 7592
Temperature °C	: 22	Site Observation	: Clear
Sampling Container	: Sterile Glass Bottle	Source of Sample	: Dental Chair - Cup Filler
Sampling Point	: Dental Clinic: Dental Chair - 12	Sample Description	: Water

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	100CFU/100ml

Note : Limit of Detection=<1CFU/L

Procedure: WSOP-MB-0051 Direct Placing of Membrane on BCYE+L-Cysteine/Membrane Filter Followed by Washing Procedure in Funnel.

Limit based on HAAD/HED/ST/0012/HS_EHSMS, Department of Health Abu Dhabi, water quality version 1.0.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Senior Microbiologist

Test results relate only to the samples tested.

This report shall not be reproduced except in full, without the written approval of the Laboratory.

This is a LIMS software generated document with E Signature.



Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -