

TEST REPORT

Report No: QMTL/R-129998/2020

| | | | |
|--|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-129998 |
| ATTN : MR. JASMAN PINTO | | Date Received | 21 Oct 2020 |
| | | Date(s) Tested | 21 Oct 2020 - 31 Oct 2020 |
| | | Date Reported | 03 Nov 2020 |
| Sample Description | Dental Treatment Room 1 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 21.10.2020 / 01:20 PM |
| Sample Container | 1x1L PB | Sampling Point | Cup Filler |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 20.8°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|--|
| Keywords | CFU: Colony Forming Unit, RSB: Regulation & Supervision Bureau, ISO : International Organization for Standardization, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|--|

| | |
|-------------------------|----------|
| Test method deviation | None |
| Test performed by Emp# | 103 & 74 |
| Report prepared by Emp# | 72 |

The above test results are only applicable to the sample(s) referred above.

Reported By


ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-129999/2020

| | | | |
|---|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-129999 |
| ATTN : MR. JASMAN PINTO | | Date Received | 21 Oct 2020 |
| | | Date(s) Tested | 21 Oct 2020 - 31 Oct 2020 |
| | | Date Reported | 03 Nov 2020 |
| Sample Description | Dental Treatment Room 2 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 21.10.2020 / 01:30 PM |
| Sample Container | 1x1L PB | Sampling Point | Cup Filler |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 17.3°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|--|
| Keywords | CFU: Colony Forming Unit, RSB: Regulation & Supervision Bureau, ISO : International Organization for Standardization, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|--|

| | |
|-------------------------|----------|
| Test method deviation | None |
| Test performed by Emp# | 103 & 74 |
| Report prepared by Emp# | 72 |

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-130000/2020

| | | | |
|---|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-130000 |
| ATTN : MR. JASMAN PINTO | | Date Received | 21 Oct 2020 |
| | | Date(s) Tested | 21 Oct 2020 - 31 Oct 2020 |
| | | Date Reported | 03 Nov 2020 |
| Sample Description | Dental Treatment Room 3 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 21.10.2020 / 01:40 PM |
| Sample Container | 1x1L PB | Sampling Point | Cup Filler |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 18.1°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS


| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|--|
| Keywords | CFU: Colony Forming Unit, RSB: Regulation & Supervision Bureau, ISO : International Organization for Standardization, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|--|

| | |
|---|----------|
| Test method deviation | None |
| Test performed by Emp# | 103 & 74 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-130001/2020

| | | | |
|---|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-130001 |
| ATTN : MR. JASMAN PINTO | | Date Received | 21 Oct 2020 |
| | | Date(s) Tested | 21 Oct 2020 - 31 Oct 2020 |
| | | Date Reported | 03 Nov 2020 |
| Sample Description | Dental Treatment Room 4 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 21.10.2020 / 01:50 PM |
| Sample Container | 1x1L PB | Sampling Point | Cup Filler |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 17.8°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|--|
| Keywords | CFU: Colony Forming Unit, RSB: Regulation & Supervision Bureau, ISO : International Organization for Standardization, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|--|

| | |
|-------------------------|----------|
| Test method deviation | None |
| Test performed by Emp# | 103 & 74 |
| Report prepared by Emp# | 72 |

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-130002/2020

| | | | |
|---|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-130002 |
| ATTN : MR. JASMAN PINTO | | Date Received | 21 Oct 2020 |
| | | Date(s) Tested | 21 Oct 2020 - 31 Oct 2020 |
| | | Date Reported | 03 Nov 2020 |
| Sample Description | Dental Treatment Room 5 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 21.10.2020 / 02:00 PM |
| Sample Container | 1x1L PB | Sampling Point | Cup Filler |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 22°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS


| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|--|
| Keywords | CFU: Colony Forming Unit, RSB: Regulation & Supervision Bureau, ISO : International Organization for Standardization, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|--|

| | |
|---|----------|
| Test method deviation | None |
| Test performed by Emp# | 103 & 74 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Reported By


ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-130003/2020

| | | | |
|---|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-130003 |
| | | Date Received | 21 Oct 2020 |
| | | Date(s) Tested | 21 Oct 2020 - 31 Oct 2020 |
| ATTN : MR. JASMAN PINTO | | Date Reported | 03 Nov 2020 |
| Sample Description | Dental Treatment Room 6 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-16 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 21.10.2020 / 02:10 PM |
| Sample Container | 1x1L PB | Sampling Point | Cup Filler |
| Sample Receipt Temp | 21°C | Sample Onsite Temp | 14.7°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|--|---|-----------|------------|---------|
| LEGIONELLA ANALYSIS | | | | |
| Legionella | ISO 11731:2017 E (Matrix A-Procedure-5) | CFU/litre | <1 | <1 |
| Legionella Species | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 1 | ISO 11731:2017 E | - | - | Absent |
| Legionella pneumophila sero group 2-15 | ISO 11731:2017 E | - | - | Absent |


| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|--|
| Keywords | CFU: Colony Forming Unit, RSB: Regulation & Supervision Bureau, ISO : International Organization for Standardization, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar |
|----------|--|

| | |
|-------------------------|----------|
| Test method deviation | None |
| Test performed by Emp# | 103 & 74 |
| Report prepared by Emp# | 72 |

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-129984/2020

| | | | |
|---|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO | | Sample ID | QMTL/S-129984 |
| | | Date Received | 21 Oct 2020 |
| | | Date(s) Tested | 21 Oct 2020 - 23 Oct 2020 |
| | | Date Reported | 01 Nov 2020 |
| Sample Description | Dental Treatment Room 7 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-15 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 21.10.2020 / 02:20 PM |
| Sample Container | 1x500ml PB | Sampling Point | Cup Filler |
| Sample Receipt Temp | 4°C | Sample Onsite Temp | 21.9°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|---------------------------------|--------------------------------|------------|------------|---------|
| MICROBIOLOGICAL ANALYSIS | | | | |
| Total Bacterial Count | APHA 9215 B (23rd Edition) | CFU/ml | 10@37°C | 2 |
| Total Coliforms | APHA 9222 B (23rd Edition) | CFU/100 ml | Zero | Zero |
| Fecal coliforms | APHA 9222 D (23rd Edition) | CFU/100 ml | Zero | Zero |
| Pseudomonas aeruginosa | APHA 9213 E (23rd Edition) | CFU/100 ml | Zero | Zero |
| E.coli | APHA 9222 H & I (23rd Edition) | CFU/100 ml | Zero | Zero |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|---|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction |
|----------|---|

| | |
|---|----------|
| Test method deviation | None |
| Test performed by Emp# | 103 & 74 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-129985/2020

| | | | |
|---|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO | | Sample ID | QMTL/S-129985 |
| | | Date Received | 21 Oct 2020 |
| | | Date(s) Tested | 21 Oct 2020 - 23 Oct 2020 |
| | | Date Reported | 01 Nov 2020 |
| Sample Description | Dental Treatment Room 8 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-15 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 21.10.2020 / 02:30 PM |
| Sample Container | 1x500ml PB | Sampling Point | Cup Filler |
| Sample Receipt Temp | 4°C | Sample Onsite Temp | 18.6°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|---------------------------------|--------------------------------|------------|------------|---------|
| MICROBIOLOGICAL ANALYSIS | | | | |
| Total Bacterial Count | APHA 9215 B (23rd Edition) | CFU/ml | 10@37°C | 2 |
| Total Coliforms | APHA 9222 B (23rd Edition) | CFU/100 ml | Zero | Zero |
| Fecal coliforms | APHA 9222 D (23rd Edition) | CFU/100 ml | Zero | Zero |
| Pseudomonas aeruginosa | APHA 9213 E (23rd Edition) | CFU/100 ml | Zero | Zero |
| E.coli | APHA 9222 H & I (23rd Edition) | CFU/100 ml | Zero | Zero |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|---|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction |
|----------|---|

| | |
|-------------------------|----------|
| Test method deviation | None |
| Test performed by Emp# | 103 & 74 |
| Report prepared by Emp# | 72 |

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-129986/2020

| | | | |
|--|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-129986 |
| ATTN : MR. JASMAN PINTO | | Date Received | 21 Oct 2020 |
| | | Date(s) Tested | 21 Oct 2020 - 23 Oct 2020 |
| | | Date Reported | 01 Nov 2020 |
| Sample Description | Dental Treatment Room 9 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-15 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 21.10.2020 / 02:40 PM |
| Sample Container | 1x500ml PB | Sampling Point | Cup Filler |
| Sample Receipt Temp | 4°C | Sample Onsite Temp | 21.3°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|---------------------------------|--------------------------------|------------|------------|---------|
| MICROBIOLOGICAL ANALYSIS | | | | |
| Total Bacterial Count | APHA 9215 B (23rd Edition) | CFU/ml | 10@37°C | <1 |
| Total Coliforms | APHA 9222 B (23rd Edition) | CFU/100 ml | Zero | Zero |
| Fecal coliforms | APHA 9222 D (23rd Edition) | CFU/100 ml | Zero | Zero |
| Pseudomonas aeruginosa | APHA 9213 E (23rd Edition) | CFU/100 ml | Zero | Zero |
| E.coli | APHA 9222 H & I (23rd Edition) | CFU/100 ml | Zero | Zero |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|---|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction |
|----------|---|

| | |
|-----------------------|------|
| Test method deviation | None |
|-----------------------|------|

| | |
|------------------------|----------|
| Test performed by Emp# | 103 & 74 |
|------------------------|----------|

| | |
|-------------------------|----|
| Report prepared by Emp# | 72 |
|-------------------------|----|

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-129987/2020

| | | | |
|--|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-129987 |
| ATTN : MR. JASMAN PINTO | | Date Received | 21 Oct 2020 |
| | | Date(s) Tested | 21 Oct 2020 - 23 Oct 2020 |
| | | Date Reported | 01 Nov 2020 |
| Sample Description | Dental Treatment Room 10 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-15 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 21.10.2020 / 02:50 PM |
| Sample Container | 1x500ml PB | Sampling Point | Cup Filler |
| Sample Receipt Temp | 4°C | Sample Onsite Temp | 25.4°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|---------------------------------|--------------------------------|------------|------------|---------|
| MICROBIOLOGICAL ANALYSIS | | | | |
| Total Bacterial Count | APHA 9215 B (23rd Edition) | CFU/ml | 10@37°C | 7 |
| Total Coliforms | APHA 9222 B (23rd Edition) | CFU/100 ml | Zero | Zero |
| Fecal coliforms | APHA 9222 D (23rd Edition) | CFU/100 ml | Zero | Zero |
| Pseudomonas aeruginosa | APHA 9213 E (23rd Edition) | CFU/100 ml | Zero | Zero |
| E.coli | APHA 9222 H & I (23rd Edition) | CFU/100 ml | Zero | Zero |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|---|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction |
|----------|---|


| | |
|-----------------------|------|
| Test method deviation | None |
|-----------------------|------|

| | |
|------------------------|----------|
| Test performed by Emp# | 103 & 74 |
|------------------------|----------|

| | |
|-------------------------|----|
| Report prepared by Emp# | 72 |
|-------------------------|----|

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-129990/2020

| | | | |
|--|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-129990 |
| ATTN : MR. JASMAN PINTO | | Date Received | 21 Oct 2020 |
| | | Date(s) Tested | 21 Oct 2020 - 23 Oct 2020 |
| | | Date Reported | 01 Nov 2020 |
| Sample Description | Dental Treatment Room 10A | | |
| Sample Type | Water | Sampling Method | QMTL-WI-15 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 21.10.2020 / 03:20 PM |
| Sample Container | 1x500ml PB | Sampling Point | Cup Filler |
| Sample Receipt Temp | 4°C | Sample Onsite Temp | 27.4°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|---------------------------------|--------------------------------|------------|------------|---------|
| MICROBIOLOGICAL ANALYSIS | | | | |
| Total Bacterial Count | APHA 9215 B (23rd Edition) | CFU/ml | 10@37°C | 5 |
| Total Coliforms | APHA 9222 B (23rd Edition) | CFU/100 ml | Zero | Zero |
| Fecal coliforms | APHA 9222 D (23rd Edition) | CFU/100 ml | Zero | Zero |
| Pseudomonas aeruginosa | APHA 9213 E (23rd Edition) | CFU/100 ml | Zero | Zero |
| E.coli | APHA 9222 H & I (23rd Edition) | CFU/100 ml | Zero | Zero |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|---|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction |
|----------|---|

| | |
|-------------------------|----------|
| Test method deviation | None |
| Test performed by Emp# | 103 & 74 |
| Report prepared by Emp# | 72 |

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-129988/2020

| | | | |
|---|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO | | Sample ID | QMTL/S-129988 |
| | | Date Received | 21 Oct 2020 |
| | | Date(s) Tested | 21 Oct 2020 - 23 Oct 2020 |
| | | Date Reported | 01 Nov 2020 |
| Sample Description | Dental Treatment Room 11 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-15 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 21.10.2020 / 03:00 PM |
| Sample Container | 1x500ml PB | Sampling Point | Cup Filler |
| Sample Receipt Temp | 4°C | Sample Onsite Temp | 19.7°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|---------------------------------|--------------------------------|------------|------------|---------|
| MICROBIOLOGICAL ANALYSIS | | | | |
| Total Bacterial Count | APHA 9215 B (23rd Edition) | CFU/ml | 10@37°C | 3 |
| Total Coliforms | APHA 9222 B (23rd Edition) | CFU/100 ml | Zero | Zero |
| Fecal coliforms | APHA 9222 D (23rd Edition) | CFU/100 ml | Zero | Zero |
| Pseudomonas aeruginosa | APHA 9213 E (23rd Edition) | CFU/100 ml | Zero | Zero |
| E.coli | APHA 9222 H & I (23rd Edition) | CFU/100 ml | Zero | Zero |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|---|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction |
|----------|---|

| | |
|-------------------------|----------|
| Test method deviation | None |
| Test performed by Emp# | 103 & 74 |
| Report prepared by Emp# | 72 |

The above test results are only applicable to the sample(s) referred above.

Reported By


ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-129989/2020

| | | | |
|---|---------------------------------|--------------------|---------------------------|
| CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates | | Sample ID | QMTL/S-129989 |
| ATTN : MR. JASMAN PINTO | | Date Received | 21 Oct 2020 |
| | | Date(s) Tested | 21 Oct 2020 - 23 Oct 2020 |
| | | Date Reported | 01 Nov 2020 |
| Sample Description | Dental Treatment Room 12 | | |
| Sample Type | Water | Sampling Method | QMTL-WI-15 |
| Client Name/Project | NP | Sampled By | QMTL Representative |
| Location | Healthpoint Hospital, Abu Dhabi | Sampling Date/Time | 21.10.2020 / 03:10 PM |
| Sample Container | 1x500ml PB | Sampling Point | Cup Filler |
| Sample Receipt Temp | 4°C | Sample Onsite Temp | 19.3°C |
| Sample Appearance | Clear | On-site Treatment | NA |
| Reference | NP | | |

TEST RESULTS

| PARAMETERS | TEST METHODS | UNITS | GUIDELINES | RESULTS |
|---------------------------------|--------------------------------|------------|------------|---------|
| MICROBIOLOGICAL ANALYSIS | | | | |
| Total Bacterial Count | APHA 9215 B (23rd Edition) | CFU/ml | 10@37°C | 2 |
| Total Coliforms | APHA 9222 B (23rd Edition) | CFU/100 ml | Zero | Zero |
| Fecal coliforms | APHA 9222 D (23rd Edition) | CFU/100 ml | Zero | Zero |
| Pseudomonas aeruginosa | APHA 9213 E (23rd Edition) | CFU/100 ml | Zero | Zero |
| E.coli | APHA 9222 H & I (23rd Edition) | CFU/100 ml | Zero | Zero |

| | |
|---------|--|
| Remarks | The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only. |
|---------|--|

| | |
|----------|---|
| Keywords | CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, HAAD: The Health –Authority- Abu Dhabi, EHSMS: Environment, Health and Safety Management System, NP: Not Provided, NA: Not Applicable, WI: Work Instruction |
|----------|---|

| | |
|---|----------|
| Test method deviation | None |
| Test performed by Emp# | 103 & 74 |
| Report prepared by Emp# | 72 |
| The above test results are only applicable to the sample(s) referred above. | |

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT