

## TEST REPORT

Report No: QMTL/R-98042/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-98042	
	Date Received	17 Mar 2020	
	Date(s) Tested	17 Mar 2020 - 27 Mar 2020	
	Date Reported	07 Apr 2020	
Sample Description	L-3 Dental Clinic -01		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital	Sampling Date/Time	17.03.2020/ 1:25 PM
Sample Container	1x1L PB	Sampling Point	Dental Chair Cup Filler
Sample Receipt Temp	18°C	Sample Onsite Temp	23.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-98041/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-98041	
	Date Received	17 Mar 2020	
	Date(s) Tested	17 Mar 2020 - 27 Mar 2020	
	Date Reported	07 Apr 2020	
ATTN : MR. JASMAN PINTO			
Sample Description	L-3 Dental Clinic -2		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital	Sampling Date/Time	17.03.2020/ 1:10 PM
Sample Container	1x1L PB	Sampling Point	Dental Chair Cup Filler
Sample Receipt Temp	18°C	Sample Onsite Temp	22.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-98040/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-98040	
	Date Received	17 Mar 2020	
	Date(s) Tested	17 Mar 2020 - 27 Mar 2020	
	Date Reported	07 Apr 2020	
ATTN : MR. JASMAN PINTO			
Sample Description	L-3 Dental Clinic -3		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital	Sampling Date/Time	17.03.2020/ 1:10 PM
Sample Container	1x1L PB	Sampling Point	Dental Chair Cup Filler
Sample Receipt Temp	18°C	Sample Onsite Temp	22.7°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		


### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-98039/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-98039	
	Date Received	17 Mar 2020	
	Date(s) Tested	17 Mar 2020 - 27 Mar 2020	
	Date Reported	07 Apr 2020	
Sample Description	L-3 Dental Clinic -4		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital	Sampling Date/Time	17.03.2020/ 12:56 PM
Sample Container	1x1L PB	Sampling Point	Dental Chair Cup Filler
Sample Receipt Temp	18°C	Sample Onsite Temp	24.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-98025/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-98025
		Date Received	17 Mar 2020
		Date(s) Tested	17 Mar 2020 - 19 Mar 2020
<b>ATTN : MR. JASMAN PINTO</b>		Date Reported	22 Mar 2020
Sample Description	<b>L-3, Dental Clinic-05</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital	Sampling Date/Time	17.03.2020/ 1:24 PM
Sample Container	1x500ml PB	Sampling Point	Cup Filler
Sample Receipt Temp	5.1°C	Sample Onsite Temp	23.8°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, WI: Work Instruction.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

  
**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

**TEST REPORT**

Report No: QMTL/R-98024/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-98024
<b>ATTN : MR. JASMAN PINTO</b>		Date Received	17 Mar 2020
		Date(s) Tested	17 Mar 2020 - 19 Mar 2020
		Date Reported	22 Mar 2020
Sample Description	<b>L-3, Dental Clinic-06</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital	Sampling Date/Time	17.03.2020/ 12:25 PM
Sample Container	1x500ml PB	Sampling Point	Cup Filler
Sample Receipt Temp	5.1°C	Sample Onsite Temp	23.4°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, WI: Work Instruction.
----------	---

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72

The above test results are only applicable to the sample(s) referred above.

Reported By

  
**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-98038/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-98038	
	Date Received	17 Mar 2020	
	Date(s) Tested	17 Mar 2020 - 27 Mar 2020	
	Date Reported	07 Apr 2020	
Sample Description	L-3 Dental Clinic -07		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital	Sampling Date/Time	17.03.2020/ 12:30 PM
Sample Container	1x1L PB	Sampling Point	Dental Chair Cup Filler
Sample Receipt Temp	18°C	Sample Onsite Temp	22.9°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-98026/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Sample ID</td> <td>QMTL/S-98026</td> </tr> <tr> <td>Date Received</td> <td>17 Mar 2020</td> </tr> <tr> <td>Date(s) Tested</td> <td>17 Mar 2020 - 19 Mar 2020</td> </tr> <tr> <td>Date Reported</td> <td>22 Mar 2020</td> </tr> </table>	Sample ID	QMTL/S-98026	Date Received	17 Mar 2020	Date(s) Tested	17 Mar 2020 - 19 Mar 2020	Date Reported	22 Mar 2020
Sample ID	QMTL/S-98026								
Date Received	17 Mar 2020								
Date(s) Tested	17 Mar 2020 - 19 Mar 2020								
Date Reported	22 Mar 2020								
Sample Description	<b>L-3, Dental Clinic-08</b>								
Sample Type	Water	Sampling Method	NP						
Client Name/Project	NP	Sampled By	QMTL Representative						
Location	Healthpoint Hospital	Sampling Date/Time	17.03.2020/ 1:50 PM						
Sample Container	1x500ml PB	Sampling Point	Cup Filler						
Sample Receipt Temp	5.1°C	Sample Onsite Temp	24°C						
Sample Appearance	Clear	On-site Treatment	NP						
Reference	NP								

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	6
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, WI: Work Instruction.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

  
**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-98035/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-98035	
	Date Received	17 Mar 2020	
	Date(s) Tested	17 Mar 2020 - 27 Mar 2020	
	Date Reported	07 Apr 2020	
Sample Description	L-3 Dental Clinic -9		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital	Sampling Date/Time	17.03.2020/ 12:10 PM
Sample Container	1x1L PB	Sampling Point	Dental Chair Cup Filler
Sample Receipt Temp	18°C	Sample Onsite Temp	24°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		


### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-98023/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-98023
<b>ATTN : MR. JASMAN PINTO</b>		Date Received	17 Mar 2020
		Date(s) Tested	17 Mar 2020 - 19 Mar 2020
		Date Reported	22 Mar 2020
Sample Description	<b>L-3, Dental Clinic 10A-VIP Dental Chair, L3 Clinic</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital	Sampling Date/Time	17.03.2020/ 11:12 AM
Sample Container	1x500ml PB	Sampling Point	Cup Filler
Sample Receipt Temp	5.1°C	Sample Onsite Temp	23°C
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, WI: Work Instruction.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-98034/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-98034	
	Date Received	17 Mar 2020	
	Date(s) Tested	17 Mar 2020 - 27 Mar 2020	
	Date Reported	07 Apr 2020	
Sample Description	L-3, Dental Clinic 10A-VIP Dental Chair		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital	Sampling Date/Time	17.03.2020/ 12:00 PM
Sample Container	1x1L PB	Sampling Point	Dental Chair Cup Filler
Sample Receipt Temp	18°C	Sample Onsite Temp	23.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets DM Water Systems quality (2010) specifications for Cooling Water Systems with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, DM: Dubai Municipality, ISO: International Organization for Standardization NP: Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar, GVPC: Glycine Vancomycin Polymyxin Cycloheximide. Culture Media: BCYE & GVPC Agar
----------	---

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-98036/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-98036	
	Date Received	17 Mar 2020	
	Date(s) Tested	17 Mar 2020 - 27 Mar 2020	
	Date Reported	07 Apr 2020	
Sample Description	L-3 Dental Clinic -11		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital	Sampling Date/Time	17.03.2020/ 12:15 PM
Sample Container	1x1L PB	Sampling Point	Dental Chair Cup Filler
Sample Receipt Temp	18°C	Sample Onsite Temp	23.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-98037/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-98037	
	Date Received	17 Mar 2020	
	Date(s) Tested	17 Mar 2020 - 27 Mar 2020	
	Date Reported	07 Apr 2020	
Sample Description	L-3 Dental Clinic -12		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	Healthpoint Hospital	Sampling Date/Time	17.03.2020/ 12:25 PM
Sample Container	1x1L PB	Sampling Point	Dental Chair Cup Filler
Sample Receipt Temp	18°C	Sample Onsite Temp	24.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided, BCYE: Buffered Charcoal Yeast Extract, Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	78 & 74 & 55
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**