

TEST REPORT

Report No: QMTL/R-96897/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96897
ATTN : MR. JASMAN PINTO		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 11 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	A1 Building Ground Floor Drinking Fountain(NYUAD 00064663)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/2:15 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.7°C	Sample Onsite Temp	17.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	4
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96898/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-96898	
	Date Received	09 Mar 2020	
	Date(s) Tested	09 Mar 2020 - 11 Mar 2020	
	Date Reported	18 Mar 2020	
Sample Description	A1 Building First Floor Drinking Water Fountain (NYUAD 000878832)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/2:30 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.7°C	Sample Onsite Temp	19°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	9
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96895/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96895
ATTN : MR. JASMAN PINTO		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 11 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	A2 Building, Ground Floor Drinking Fountain(NYUAD 00086447)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/1:56 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.7°C	Sample Onsite Temp	18.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	4
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96896/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Sample ID</td> <td>QMTL/S-96896</td> </tr> <tr> <td>Date Received</td> <td>09 Mar 2020</td> </tr> <tr> <td>Date(s) Tested</td> <td>09 Mar 2020 - 11 Mar 2020</td> </tr> <tr> <td>Date Reported</td> <td>18 Mar 2020</td> </tr> </table>	Sample ID	QMTL/S-96896	Date Received	09 Mar 2020	Date(s) Tested	09 Mar 2020 - 11 Mar 2020	Date Reported	18 Mar 2020
Sample ID	QMTL/S-96896								
Date Received	09 Mar 2020								
Date(s) Tested	09 Mar 2020 - 11 Mar 2020								
Date Reported	18 Mar 2020								
Sample Description	A2 Building, First Floor Drinking Water Fountain (NYUAD 00088865)								
Sample Type	Water	Sampling Method	QMTL-WI-15						
Client Name/Project	NP	Sampled By	QMTL Representative						
Location	NYUAD	Sampling Date/Time	09.03.2020/1:59 PM						
Sample Container	1x500ml PB	Sampling Point	Drinking Fountain						
Sample Receipt Temp	4.7°C	Sample Onsite Temp	16.4°C						
Sample Appearance	Clear	On-site Treatment	NA						
Reference	NP								

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96893/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96893
		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 11 Mar 2020
ATTN : MR. JASMAN PINTO		Date Reported	18 Mar 2020
Sample Description	A3 Building Ground Floor Drinking Fountain (NYUAD 00088969)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/1:30 AM
Sample Container	1x500ml PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.7°C	Sample Onsite Temp	19°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--


Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96894/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-96894	
	Date Received	09 Mar 2020	
	Date(s) Tested	09 Mar 2020 - 11 Mar 2020	
	Date Reported	18 Mar 2020	
Sample Description	A3 Building, Frist Floor,Drinking Water Foutain (NYUAD: 00088740)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/1:45 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.7°C	Sample Onsite Temp	17.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	6
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--


Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96891/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96891
		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 11 Mar 2020
ATTN : MR. JASMAN PINTO		Date Reported	18 Mar 2020
Sample Description	A4 Building Ground Floor Drinking Fountain (NYUAD 00119015)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/12:55 PM
Sample Container	1x500ml PB	Sampling Point	Dinking Fountain
Sample Receipt Temp	4.7°C	Sample Onsite Temp	17.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96892/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Sample ID</td> <td>QMTL/S-96892</td> </tr> <tr> <td>Date Received</td> <td>09 Mar 2020</td> </tr> <tr> <td>Date(s) Tested</td> <td>09 Mar 2020 - 11 Mar 2020</td> </tr> <tr> <td>Date Reported</td> <td>18 Mar 2020</td> </tr> </table>	Sample ID	QMTL/S-96892	Date Received	09 Mar 2020	Date(s) Tested	09 Mar 2020 - 11 Mar 2020	Date Reported	18 Mar 2020
Sample ID	QMTL/S-96892								
Date Received	09 Mar 2020								
Date(s) Tested	09 Mar 2020 - 11 Mar 2020								
Date Reported	18 Mar 2020								
Sample Description	A4 Building First Floor Drinking Fountain (NYUAD 0019054)								
Sample Type	Water	Sampling Method	QMTL-WI-15						
Client Name/Project	NP	Sampled By	QMTL Representative						
Location	NYUAD	Sampling Date/Time	09.03.2020/01:10 PM						
Sample Container	1x500ml PB	Sampling Point	Drinking Fountain						
Sample Receipt Temp	4.7°C	Sample Onsite Temp	18.5°C						
Sample Appearance	Clear	On-site Treatment	NA						
Reference	NP								

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96889/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID Date Received Date(s) Tested Date Reported	QMTL/S-96889 09 Mar 2020 09 Mar 2020 - 11 Mar 2020 18 Mar 2020
Sample Description	A5 Building, Ground Floor, Drinking Fountain (NYUAD 00049079)	
Sample Type	Water	Sampling Method
Client Name/Project	NP	Sampled By
Location	NYUAD	Sampling Date/Time
Sample Container	1x500ml PB	Sampling Point
Sample Receipt Temp	4.7°C	Sample Onsite Temp
Sample Appearance	Clear	On-site Treatment
Reference	NP	NA

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96890/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID Date Received Date(s) Tested Date Reported	QMTL/S-96890 09 Mar 2020 09 Mar 2020 - 11 Mar 2020 18 Mar 2020
Sample Description	A5 Building, Frist Floor, Drinking Water Fountain (NYUAD 00116414)	
Sample Type	Water	Sampling Method
Client Name/Project	NP	Sampled By
Location	NYUAD	Sampling Date/Time
Sample Container	1x500ml PB	Sampling Point
Sample Receipt Temp	4.7°C	Sample Onsite Temp
Sample Appearance	Clear	On-site Treatment
Reference	NP	NA

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96886/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID Date Received Date(s) Tested Date Reported	QMTL/S-96886 09 Mar 2020 09 Mar 2020 - 11 Mar 2020 18 Mar 2020
Sample Description	A6 Building Ground Floor Drnking Fountain(NYUAD 00087225)	
Sample Type	Water	Sampling Method
Client Name/Project	NP	Sampled By
Location	NYUAD	Sampling Date/Time
Sample Container	1x500ml PB	Sampling Point
Sample Receipt Temp	4.7°C	Sample Onsite Temp
Sample Appearance	Clear	On-site Treatment
Reference	NP	NA

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96888/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-96888
		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 11 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	A6 Building Frist Level Drinking Water Fountain(NYUAD 00087694)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/12:30 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.7°C	Sample Onsite Temp	19.6°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97033/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 30%;">Sample ID</td> <td>QMTL/S-97033</td> </tr> <tr> <td>Date Received</td> <td>10 Mar 2020</td> </tr> <tr> <td>Date(s) Tested</td> <td>10 Mar 2020 - 12 Mar 2020</td> </tr> <tr> <td>Date Reported</td> <td>18 Mar 2020</td> </tr> </table>	Sample ID	QMTL/S-97033	Date Received	10 Mar 2020	Date(s) Tested	10 Mar 2020 - 12 Mar 2020	Date Reported	18 Mar 2020
Sample ID	QMTL/S-97033								
Date Received	10 Mar 2020								
Date(s) Tested	10 Mar 2020 - 12 Mar 2020								
Date Reported	18 Mar 2020								
Sample Description	C1- Building- Ground Level, Drinking Water Fountain (NYUAD:00101820)								
Sample Type	Water	Sampling Method	QMTL-WI-15						
Client Name/Project	NP	Sampled By	QMTL Representative						
Location	NYUAD	Sampling Date/Time	10.03.2020/10:30 AM						
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain						
Sample Receipt Temp	4.2°C	Sample Onsite Temp	22.5°C						
Sample Appearance	Clear	On-site Treatment	NA						
Reference	NP								

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	7
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97034/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97034	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 12 Mar 2020	
	Date Reported	18 Mar 2020	
Sample Description	C1- Building - Level 01 - Drinking Water Fountain (NYUAD:00135524)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/10:50 AM
Sample Container	1x500ml PB	Sampling Point	Fountain
Sample Receipt Temp	4.2°C	Sample Onsite Temp	21°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97037
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020-12 Mar 2020
		Date Reported	24 Mar 2020
ATTN: MR. JASMAN PINTO			
Sample Description	C2 Building, Ground Floor Drinking Water Fountain (NYUAD 00104738)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/12:10 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4°C	Sample On-site Temp	23.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
Escherichia coli	APHA 9222 H & I (23 RD EDITION))	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D (23 RD EDITION))	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23 RD EDITION))	CFU/100ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23 RD EDITION))	CFU/ml	10@37°C	6
Total Coliforms	APHA 9222 B (23 RD EDITION))	CFU/100ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirement for potable water with respect to the above tests only. This report supersedes the report no QMTL/R-97037 reported on 18 Mar 2020.
---------	---

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable, NP: Not Provided, WI: Work Instruction
----------	--

Test Method Deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	75
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97041/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-97041
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	C2- Building - Level 01 - Drinking Fountain (NYUAD:00077408)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/01:40 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4.2°C	Sample Onsite Temp	18.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97044/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-97044
		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	C2 - Building - Level 02 - Drinking Water Fountain (NYUAD:00077435)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/02:30 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4.2°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---


Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97046/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-97046
ATTN : MR. JASMAN PINTO		Date Received	10 Mar 2020
		Date(s) Tested	10 Mar 2020 - 12 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	C2 - Building - Level 03 - Drinking Water Fountain (NYUAD:00119472)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/03:00 PM
Sample Container	1x500ml PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	4.2°C	Sample Onsite Temp	19°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	7
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NP: Not Provided, NA: Not Applicable.
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96884/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-96884	
	Date Received	09 Mar 2020	
	Date(s) Tested	09 Mar 2020 - 11 Mar 2020	
	Date Reported	18 Mar 2020	
Sample Description	C3 Building Ground Level Drinking Water Fountain(NYUAD:00113058)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/10:40 AM
Sample Container	1x500ml PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.7°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96885/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96885
ATTN : MR. JASMAN PINTO		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 11 Mar 2020
		Date Reported	18 Mar 2020
Sample Description	C3 Building First Level Drinking Water Fountain(NYUAD 00113094)		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/10:50 AM
Sample Container	1x500ml PB	Sampling Point	Drinking Fountain
Sample Receipt Temp	4.7°C	Sample Onsite Temp	18°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
MICROBIOLOGICAL ANALYSIS				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, WI: Work Instruction, NA: Not Applicable, NP: Not Provided
----------	--


Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78 & 55
------------------------	--------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96932/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96932
ATTN : MR. JASMAN PINTO		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 19 Mar 2020
		Date Reported	22 Mar 2020
Sample Description	A1 Building Ground Floor, Drinking Fountain (NYUAD: 00064663)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/2:15 PM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	17.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS


PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55, 74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs. our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96933/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-96933		
	Date Received	09 Mar 2020		
	Date(s) Tested	09 Mar 2020 - 19 Mar 2020		
	Date Reported	22 Mar 2020		
Sample Description	A1 Building First Floor, Drinking Water Fountain (NYUAD: 00088832)			
Sample Type	Water	Sampling Method	QMTL-WI-16	
Client Name/Project	NP	Sampled By	QMTL Representative	
Location	NYUAD	Sampling Date/Time	09.03.2020/12:30 PM	
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain	
Sample Receipt Temp	21°C	Sample Onsite Temp	19°C	
Sample Appearance	Clear	On-site Treatment	NA	
Reference	NP			

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96930/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-96930	
	Date Received	09 Mar 2020	
	Date(s) Tested	09 Mar 2020 - 19 Mar 2020	
	Date Reported	22 Mar 2020	
Sample Description	A2 Building Ground Floor, Drinking Water Fountain (NYUAD: 00086447)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/1:56 PM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	18.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96931/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-96931	
	Date Received	09 Mar 2020	
	Date(s) Tested	09 Mar 2020 - 19 Mar 2020	
	Date Reported	22 Mar 2020	
Sample Description	A2 Building First Floor, Drinking Water Fountain (NYUAD: 00088865)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/1:59 PM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	16.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--


Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96928/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96928
ATTN : MR. JASMAN PINTO		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 19 Mar 2020
		Date Reported	22 Mar 2020
Sample Description	A3 Building Ground Floor, Drinking Water Fountain (NYUAD: 00088969)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/1:30 PM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	19°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55, 74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96929/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-96929	
	Date Received	09 Mar 2020	
	Date(s) Tested	09 Mar 2020 - 19 Mar 2020	
	Date Reported	22 Mar 2020	
Sample Description	A3 Building First Floor, Drinking Water Fountain (NYUAD: 00088740)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/1:45 PM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	17.4°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96926/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO		Sample ID	QMTL/S-96926
		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 19 Mar 2020
		Date Reported	22 Mar 2020
Sample Description	A4 Building Ground Floor, Drinking Water Fountain (NYUAD: 00119015)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/12:55 PM
Sample Container	1x1L PB	Sampling Point	Water Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	17.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--


Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96927/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96927
ATTN : MR. JASMAN PINTO		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 19 Mar 2020
		Date Reported	22 Mar 2020
Sample Description	A4 Building First Floor, Drinking Water Fountain (NYUAD: 0019054)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/1:10 PM
Sample Container	1x1L PB	Sampling Point	Water Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	18.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96924/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-96924
ATTN : MR. JASMAN PINTO		Date Received	09 Mar 2020
		Date(s) Tested	09 Mar 2020 - 19 Mar 2020
		Date Reported	22 Mar 2020
Sample Description	A5 Building Ground Floor Drinking Water Fountain (NYUAD: 00049079)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/12:30 PM
Sample Container	1x1L PB	Sampling Point	Water Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	18.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96925/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-96925	
	Date Received	09 Mar 2020	
	Date(s) Tested	09 Mar 2020 - 19 Mar 2020	
	Date Reported	22 Mar 2020	
Sample Description	A5 Building First Floor, Drinking Water Fountain (NYUAD: 000116414)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/12:40 PM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	19.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS


PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	55, 74 & 78
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96921/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-96921	
	Date Received	09 Mar 2020	
	Date(s) Tested	09 Mar 2020 - 19 Mar 2020	
	Date Reported	22 Mar 2020	
Sample Description	A6 Building Ground Floor, Drinking Fountain, (NYUAD: 00087225)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/11:10 AM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	18.3°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96923/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-96923		
	Date Received	09 Mar 2020		
	Date(s) Tested	09 Mar 2020 - 19 Mar 2020		
	Date Reported	22 Mar 2020		
Sample Description	A6 Building, First Level, Drinking Water Fountain (NYUAD: 00087694)			
Sample Type	Water	Sampling Method	QMTL-WI-16	
Client Name/Project	NP	Sampled By	QMTL Representative	
Location	NYUAD	Sampling Date/Time	09.03.2020/11:30 AM	
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain	
Sample Receipt Temp	21°C	Sample Onsite Temp	19.6°C	
Sample Appearance	Clear	On-site Treatment	NA	
Reference	NP			

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA: Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97049/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97049	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	C1- Building- Ground Level, Drinking Water Fountain (NYUAD:00101820)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/10:30 AM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	22.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, RSB: Regulation & Supervision Bureau, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97050/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97050	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	C1- Building - Level 01- Drinking Water Fountain (NYUAD:00135524)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/10:50 AM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	21°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA: Not Applicable, NP: Not Provided, RSB: Regulation & Supervision Bureau, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97053/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates	Sample ID	QMTL/S-97053	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
ATTN : MR. JASMAN PINTO			
Sample Description	C2 Building, Ground Floor Drinking Water Fountain (NYUAD 00104738)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/12:10 PM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	22°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU : Colony Forming Unit, ISO: International Organization for Standardization, RSB: Regulation & Supervision Bureau, HAAD: The Health -Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar.
----------	--

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97057/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97057	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	C2- Building - Level 01- Drinking Water Fountain (NYUAD:00077408)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/01:40 PM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	18.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA: Not Applicable, NP: Not Provided, RSB: Regulation & Supervision Bureau, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE
LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97060/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97060	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	C2- Building- Level 02- Drinking Fountain (NYUAD:00077435)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/02: 30 PM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA: Not Applicable, NP: Not Provided, RSB: Regulation & Supervision Bureau, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-97062/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-97062	
	Date Received	10 Mar 2020	
	Date(s) Tested	10 Mar 2020 - 20 Mar 2020	
	Date Reported	30 Mar 2020	
Sample Description	C2- Building - Level 03- Drinking Water Fountain (NYUAD:00119472)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	10.03.2020/03:00 PM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	19°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Zero
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Zero
Legionella Species	ISO 11731:2017 E	-	-	Zero
Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA: Not Applicable, NP: Not Provided, RSB: Regulation & Supervision Bureau, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	---

Test method deviation	None
Test performed by Emp#	74 & 55
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96919/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-96919	
	Date Received	09 Mar 2020	
	Date(s) Tested	09 Mar 2020 - 19 Mar 2020	
	Date Reported	22 Mar 2020	
Sample Description	C3 Building, Ground Level Drinking Water Fountain(NYUAD : 00113058)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/10:40 AM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	17°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-96920/2020

CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates ATTN : MR. JASMAN PINTO	Sample ID	QMTL/S-96920	
	Date Received	09 Mar 2020	
	Date(s) Tested	09 Mar 2020 - 19 Mar 2020	
	Date Reported	22 Mar 2020	
Sample Description	C3 Building,First Level Drinking Water Fountain (NYUAD: 0113094)		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	NYUAD	Sampling Date/Time	09.03.2020/10:50 AM
Sample Container	1x1L PB	Sampling Point	Drinking Water Fountain
Sample Receipt Temp	21°C	Sample Onsite Temp	18°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
LEGIONELLA ANALYSIS				
Legionella	ISO 11731:2017 E (Matrix A-Procedure-5)	CFU/litre	<1	<1
Legionella pneumophila sero group 1	ISO 11731:2017 E	-	-	Absent
Legionella pneumophila sero group 2-15	ISO 11731:2017 E	-	-	Absent
Legionella Species	ISO 11731:2017 E	-	-	Absent

Remarks	The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, ISO: International Organization for Standardization, NA:Not Applicable, NP: Not Provided, WI: Work Instruction, BCYE: Buffered Charcoal Yeast Extract Agar. Culture Media :- BCYE Agar
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	55, 74 & 78
------------------------	-------------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By




ANILA GEORGE
LABORATORY MANAGER

The test report shall not be reproduced(except in full) without the written approval of QMTL.When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT