

TEST REPORT

Report No: QMTL/R-102215/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		Sample ID	QMTL/S-102215
ATTN: Mr. JASMAN PINTO		Date Received	30 Apr 2020
Sample Description		Date(s) Tested	30 Apr 2020- 02 May2020
Sample Type		Date Reported	04 May 2020
Sample Description	AVIATION		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	ETIHAD AIRWAYS ENGINEERING	Sampling Date/Time	30.04.2020/NP
Sample Container	1x1 L PB	Sampling Point	Tap
Sample Receipt Temp	35 .1°C	Sample On-site Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	8
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided
----------	--

Test Method Deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-102216/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: Mr. JASMAN PINTO		Sample ID	QMTL/S-102216
		Date Received	30 Apr 2020
		Date(s) Tested	30 Apr 2020- 02 May2020
		Date Reported	04 May 2020
Sample Description	AVIATION		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	ETIHAD AIRWAYS ENGINEERING	Sampling Date/Time	30.04.2020/NP
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	35 .1°C	Sample On-site Temp	NP
Sample Appearance	Clear	On-site Treatment	NA
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided
----------	--

Test Method Deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-102217/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017 ATTN: Mr. JASMAN PINTO		Sample ID	QMTL/S-102217
		Date Received	30 Apr 2020
		Date(s) Tested	30 Apr 2020-02 May2020
		Date Reported	04 May 2020
Sample Description	HANGER -04		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	ETIHAD AIRWAYS ENGINEERING	Sampling Date/Time	30.04.2020/NP
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	35 .1°C	Sample On-site Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	5
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided
----------	--

Test Method Deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-102218/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		Sample ID	QMTL/S-102218
		Date Received	30 Apr 2020
		Date(s) Tested	30 Apr 2020- 02 May2020
ATTN: Mr. JASMAN PINTO		Date Reported	04 May 2020
Sample Description	HANGER -05		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	ETIHAD AIRWAYS ENGINEERING	Sampling Date/Time	30.04.2020/NP
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	35 .1°C	Sample On-site Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided
----------	--

Test Method Deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By


ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

Report No: QMTL/R-102219/2020

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		Sample ID	QMTL/S-102219
ATTN: Mr. JASMAN PINTO		Date Received	30 Apr 2020
		Date(s) Tested	30 Apr 2020- 02 May2020
		Date Reported	04 May 2020
Sample Description	BAY -06		
Sample Type	Water	Sampling Method	NP
Client Name/Project	NP	Sampled By	Client Representative
Location	ETIHAD AIRWAYS ENGINEERING	Sampling Date/Time	30.04.2020/NP
Sample Container	1x1L PB	Sampling Point	Tap
Sample Receipt Temp	35 .1°C	Sample On-site Temp	NP
Sample Appearance	Clear	On-site Treatment	NP
Reference	NP		

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

Remarks	The sample meets RSB Water Quality Regulations (4 th Edition) January 2014 requirements for potable water with respect to the above tests only.
---------	--

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NP: Not Provided
----------	--

Test Method Deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	72
The above test results are only applicable to the sample(s) referred above.	

Reported By

ANILA GEORGE
LABORATORY MANAGER

The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT