

CONSULTING SERVICE REPORT

CUSTOMER: FARAH EXPERIENCES, ABUDHABI

DATE: 11-06-2020

SITE: FERRARI WORLD

LOCATION: TANK 1

POTABLE WATER ANALYSIS

| PARAMETER | CONTROL LIMITS | POTABLE WATER |
|---|----------------|---------------|
| pH at 25°C | 7.0 – 9.2 | 8.49 |
| Conductivity at 25°C, $\mu\text{s}/\text{cm}$ | -- | 254 |
| Total Dissolved Solids at 180°C (TDS) | 1000 Max. | 165 |
| Total Hardness, ppm as CaCO_3 | 300 Max. | 73 |
| Calcium Hardness, ppm as CaCO_3 | 200 Max. | 65 |
| Chloride, ppm as Cl^- | 250 Max. | 61 |
| Iron, ppm as Fe | 0.2 Max. | <0.05 |
| Zinc (Zn), mg/l | 0.1 Max | <0.05 |
| Sulphate | 250 Max. | <10 |
| Fluorides (F) | 1.5 Max | <0.10 |

Treatment Residuals

| | | |
|------------------|-----------------|-------|
| Color, mg/l | 15 Max. | Clear |
| Odor | Unobjectionable | ND |
| Turbidity in NTU | 5 Max | <2.0 |

***** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).**

COMMENTS:

ACTION:

| | |
|---|------------------------|
| The pH and Conductivity/TDS are found satisfactory. \Rightarrow | No action recommended. |
| Dissolved iron levels are within control limits. \Rightarrow | No action recommended. |
| Zinc levels are satisfactory. \Rightarrow | No action recommended. |

Service Engineer: MURUGARAJ P


Client:

M/S: FARAH EXPERIENCES, ABUDHABI

Signature:

P. Mummy

Signature:



CONSULTING SERVICE REPORT

CUSTOMER: FARAH EXPERIENCES, ABUDHABI

DATE: 11-06-2020

SITE: FERRARI WORLD

LOCATION: TANK 2

POTABLE WATER ANALYSIS

| PARAMETER | CONTROL LIMITS | POTABLE WATER |
|--|----------------|---------------|
| pH at 25°C | 7.0 – 9.2 | 8.43 |
| Conductivity at 25°C, µs/cm | -- | 251 |
| Total Dissolved Solids at 180°C (TDS) | 1000 Max. | 163 |
| Total Hardness, ppm as CaCO ₃ | 300 Max. | 70 |
| Calcium Hardness, ppm as CaCO ₃ | 200 Max. | 64 |
| Chloride, ppm as Cl ⁻ | 250 Max. | 57 |
| Iron, ppm as Fe | 0.2 Max. | <0.05 |
| Zinc (Zn), mg/l | 0.1 Max | <0.05 |
| Sulphate | 250 Max. | <10 |
| Fluorides (F) | 1.5 Max | <0.10 |

Treatment Residuals

| | | |
|------------------|-----------------|-------|
| Color, mg/l | 15 Max. | Clear |
| Odor | Unobjectionable | ND |
| Turbidity in NTU | 5 Max | <2.0 |

***** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).**

COMMENTS:

ACTION:

| | |
|---|------------------------|
| The pH and Conductivity/TDS are found satisfactory. ⇨ | No action recommended. |
| Dissolved iron levels are within control limits. ⇨ | No action recommended. |
| Zinc levels are satisfactory. ⇨ | No action recommended. |

Service Engineer: MURUGARAJ P


Client:

M/S: FARAH EXPERIENCES, ABUDHABI

Signature:

P. Murugaraaj P.

Signature:



CONSULTING SERVICE REPORT

CUSTOMER: FARAH EXPERIENCES, ABUDHABI
DATE: 11-06-2020
SITE: FERRARI WORLD
LOCATION: WATER TAP

POTABLE WATER ANALYSIS

| PARAMETER | CONTROL LIMITS | POTABLE WATER |
|--|----------------|---------------|
| pH at 25°C | 7.0 – 9.2 | 8.44 |
| Conductivity at 25°C, µs/cm | -- | 236 |
| Total Dissolved Solids at 180°C (TDS) | 1000 Max. | 153 |
| Total Hardness, ppm as CaCO ₃ | 300 Max. | 66 |
| Calcium Hardness, ppm as CaCO ₃ | 200 Max. | 57 |
| Chloride, ppm as Cl ⁻ | 250 Max. | 55 |
| Iron, ppm as Fe | 0.2 Max. | <0.05 |
| Zinc (Zn), mg/l | 0.1 Max | <0.05 |
| Sulphate | 250 Max. | <10 |
| Fluorides (F) | 1.5 Max | <0.10 |

Treatment Residuals

| | | |
|------------------|-----------------|-------|
| Color, mg/l | 15 Max. | Clear |
| Odor | Unobjectionable | ND |
| Turbidity in NTU | 5 Max | <2.0 |

*** Aqll test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS:
ACTION:

| | |
|---|------------------------|
| The pH and Conductivity/TDS are found satisfactory. ⇨ | No action recommended. |
| Dissolved iron levels are within control limits. ⇨ | No action recommended. |
| Zinc levels are satisfactory. ⇨ | No action recommended. |

Service Engineer:
MURUGARAJ P
Client:
M/S: FARAH EXPERIENCES, ABUDHABI
Signature:

Signature:
