

CONSULTING SERVICE REPORT

CUSTOMER: FARAH EXPERIENCES, ABUDHABI

DATE: 21-05-2020

SITE: FERRARI WORLD

LOCATION: TANK 1

POTABLE WATER ANALYSIS


PARAMETER	CONTROL LIMITS	POTABLE WATER
pH at 25°C	7.0 – 9.2	8.65
Conductivity at 25°C, µs/cm	--	267
Total Dissolved Solids at 180°C (TDS)	1000 Max.	173
Total Hardness, ppm as CaCO ₃	300 Max.	69
Calcium Hardness, ppm as CaCO ₃	200 Max.	65
Chloride, ppm as Cl ⁻	250 Max.	56
Iron, ppm as Fe	0.2 Max.	<0.05
Zinc (Zn), mg/l	0.1 Max	<0.05
Sulphate	250 Max.	<10
Fluorides (F)	1.5 Max	<0.10

Treatment Residuals

Color, mg/l	15 Max.	Clear
Odor	Unobjectionable	ND
Turbidity in NTU	5 Max	3

***** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).**

COMMENTS:	ACTION:
The pH and Conductivity/TDS are found satisfactory. ⇨	No action recommended.
Dissolved iron levels are within control limits. ⇨	No action recommended.
Zinc levels are satisfactory. ⇨	No action recommended.

Service Engineer:	MURUGARAJ P	Client:	M/S: FARAH EXPERIENCES, ABUDHABI
Signature:		Signature:	



CONSULTING SERVICE REPORT

CUSTOMER: FARAH EXPERIENCES, ABUDHABI

DATE: 21-05-2020

SITE: FERRARI WORLD

LOCATION: TANK 2

POTABLE WATER ANALYSIS

PARAMETER	CONTROL LIMITS	POTABLE WATER
pH at 25°C	7.0 – 9.2	8.68
Conductivity at 25°C, µs/cm	--	262
Total Dissolved Solids at 180°C (TDS)	1000 Max.	107
Total Hardness, ppm as CaCO ₃	300 Max.	68
Calcium Hardness, ppm as CaCO ₃	200 Max.	61
Chloride, ppm as Cl ⁻	250 Max.	60
Iron, ppm as Fe	0.2 Max.	<0.05
Zinc (Zn), mg/l	0.1 Max	<0.05
Sulphate	250 Max.	<10
Fluorides (F)	1.5 Max	<0.10

Treatment Residuals

Color, mg/l	15 Max.	Clear
Odor	Unobjectionable	ND
Turbidity in NTU	5 Max	3

***** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).**

COMMENTS:

ACTION:

The pH and Conductivity/TDS are found satisfactory. ⇨	No action recommended.
Dissolved iron levels are within control limits. ⇨	No action recommended.
Zinc levels are satisfactory. ⇨	No action recommended.

Service Engineer: MURUGARAJ P

Client:

M/S: FARAH EXPERIENCES, ABUDHABI

Signature:

P. Murugaraaj

Signature:



CONSULTING SERVICE REPORT

CUSTOMER: FARAH EXPERIENCES, ABUDHABI

DATE: 21-05-2020

SITE: FERRARI WORLD

LOCATION: WATER TAP

POTABLE WATER ANALYSIS


PARAMETER	CONTROL LIMITS	POTABLE WATER
pH at 25°C	7.0 – 9.2	8.63
Conductivity at 25°C, µs/cm	--	268
Total Dissolved Solids at 180°C (TDS)	1000 Max.	174
Total Hardness, ppm as CaCO ₃	300 Max.	67
Calcium Hardness, ppm as CaCO ₃	200 Max.	63
Chloride, ppm as Cl ⁻	250 Max.	58
Iron, ppm as Fe	0.2 Max.	<0.05
Zinc (Zn), mg/l	0.1 Max	<0.05
Sulphate	250 Max.	<10
Fluorides (F)	1.5 Max	<0.10

Treatment Residuals

Color, mg/l	15 Max.	Clear
Odor	Unobjectionable	ND
Turbidity in NTU	5 Max	2

***** Aqll test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).**

COMMENTS:	ACTION:
The pH and Conductivity/TDS are found satisfactory. ⇨	No action recommended.
Dissolved iron levels are within control limits. ⇨	No action recommended.
Zinc levels are satisfactory. ⇨	No action recommended.

Service Engineer:	MURUGARAJ P	Client:	M/S: FARAH EXPERIENCES, ABUDHABI
Signature:		Signature:	

