



## CONSULTING SERVICE REPORT

<b>CUSTOMER: FARAH EXPERIENCES, ABUDHABI</b>	<b>DATE: 04-03-2020</b>
<b>SITE: FERRARI WORLD</b>	<b>LOCATION: TANK 1</b>

### POTABLE WATER ANALYSIS

PARAMETER	CONTROL LIMITS	POTABLE WATER
pH at 25°C	7.0 – 9.2	8.77
Conductivity at 25°C, µs/cm	--	265
Total Dissolved Solids at 180°C (TDS)	1000 Max.	172
Total Hardness, ppm as CaCO <sub>3</sub>	300 Max.	55
Calcium Hardness, ppm as CaCO <sub>3</sub>	200 Max.	46
Chloride, ppm as Cl <sup>-</sup>	250 Max.	39
Iron, ppm as Fe	0.2 Max.	<0.05
Sulphate	250 Max.	<10
Fluorides (F)	1.5 Max	<0.05

Treatment Residuals		
Color, mg/l	15 Max.	Clear
Odor	Unobjectionable	ND
Turbidity in NTU	5 Max	<1.0

**\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).**

COMMENTS:	ACTION:
The pH and Conductivity/TDS are found satisfactory. ⇨	No action recommended.
Dissolved iron levels are within control limits ⇨	No action recommended.

<b>Service Engineer:</b>	<b>MURUGARAJ P</b>	<b>Client:</b>	<b>M/S: FARAH EXPERIENCES</b>
<b>Signature:</b>		<b>Signature:</b>	





## CONSULTING SERVICE REPORT

<b>CUSTOMER: FARAH EXPERIENCES, ABUDHABI</b>	<b>DATE: 04-03-2020</b>
<b>SITE: FERRARI WORLD</b>	<b>LOCATION: TANK 2</b>

### POTABLE WATER ANALYSIS

PARAMETER	CONTROL LIMITS	POTABLE WATER
pH at 25°C	7.0 – 9.2	8.61
Conductivity at 25°C, µs/cm	--	275
Total Dissolved Solids at 180°C (TDS)	1000 Max.	178
Total Hardness, ppm as CaCO <sub>3</sub>	300 Max.	61
Calcium Hardness, ppm as CaCO <sub>3</sub>	200 Max.	46
Chloride, ppm as Cl <sup>-</sup>	250 Max.	48
Iron, ppm as Fe	0.2 Max.	<0.05
Sulphate	250 Max.	<10
Fluorides (F)	1.5 Max	<0.05

Treatment Residuals		
Color, mg/l	15 Max.	Clear
Odor	Unobjectionable	ND
Turbidity in NTU	5 Max	<1.0

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

COMMENTS:	ACTION:
The pH and Conductivity/TDS are found satisfactory. ⇨	No action recommended.
Dissolved iron levels are within control limits ⇨	No action recommended.

<b>Service Engineer:</b>	<b>MURUGARAJ P</b>	<b>Client:</b>	<b>M/S: FARAH EXPERIENCES</b>
<b>Signature:</b>		<b>Signature:</b>	



## CONSULTING SERVICE REPORT

<b>CUSTOMER:</b> FARAH EXPERIENCES, ABUDHABI	<b>DATE:</b> 04-03-2020
<b>SITE:</b> FERRARI WORLD	<b>LOCATION:</b> PLANT ROOM : 04, WATER TAP

### POTABLE WATER ANALYSIS

PARAMETER	CONTROL LIMITS	POTABLE WATER
pH at 25°C	7.0 – 9.2	8.54
Conductivity at 25°C, µs/cm	--	279
Total Dissolved Solids at 180°C (TDS)	1000 Max.	181
Total Hardness, ppm as CaCO <sub>3</sub>	300 Max.	74
Calcium Hardness, ppm as CaCO <sub>3</sub>	200 Max.	62
Chloride, ppm as Cl <sup>-</sup>	250 Max.	41
Iron, ppm as Fe	0.2 Max.	<0.05
Sulphate	250 Max.	<10
Fluorides (F)	1.5 Max	<0.05

#### Treatment Residuals

Color, mg/l	15 Max.	Clear
Odor	Unobjectionable	ND
Turbidity in NTU	5 Max	<1.0

**\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).**

COMMENTS:	ACTION:
The pH and Conductivity/TDS are found satisfactory. ⇨	No action recommended.
Dissolved iron levels are within control limits ⇨	No action recommended.

<b>Service Engineer:</b>	<b>MURUGARAJ P</b>	<b>Client:</b>	<b>M/S: FARAH EXPERIENCES</b>
<b>Signature:</b>		<b>Signature:</b>	

