



## CONSULTING SERVICE REPORT

<b>CUSTOMER: FARAH EXPERIENCES, ABUDHABI</b>	<b>DATE: 29-07-2020</b>
<b>SITE: FERRARI WORLD</b>	<b>LOCATION: TANK 1</b>

### POTABLE WATER ANALYSIS

PARAMETER	CONTROL LIMITS	POTABLE WATER
pH at 25°C	7.0 – 9.2	8.16
Conductivity at 25°C, µs/cm	--	196
Total Dissolved Solids at 180°C (TDS)	1000 Max.	127
Total Hardness, ppm as CaCO <sub>3</sub>	300 Max.	83
Calcium Hardness, ppm as CaCO <sub>3</sub>	200 Max.	78
Chloride, ppm as Cl <sup>-</sup>	250 Max.	70
Iron, ppm as Fe	0.2 Max.	<0.05
Zinc (Zn), mg/l	0.1 Max	<0.05
Sulphate	250 Max.	23
Fluorides (F)	1.5 Max	<0.05

Treatment Residuals		
Residual Chlorine	0.2 – 0.5	0.36
Color, mg/l	15 Max.	Clear
Odor	Unobjectionable	ND
Turbidity in NTU	5 Max	<1

**\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).**

COMMENTS:	ACTION:
The pH and Conductivity/TDS are found satisfactory. ⇨	No action recommended.
Dissolved iron levels are within control limits. ⇨	No action recommended.
Zinc levels are satisfactory. ⇨	No action recommended.

<b>Service Engineer:</b>	MURUGARAJ P	<b>Client:</b>	M/S: FARAH EXPERIENCES, ABUDHABI
<b>Signature:</b>		<b>Signature:</b>	





## CONSULTING SERVICE REPORT

<b>CUSTOMER: FARAH EXPERIENCES, ABUDHABI</b>		<b>DATE: 29-07-2020</b>	
<b>SITE: FERRARI WORLD</b>		<b>LOCATION: TANK 2</b>	
<b>POTABLE WATER ANALYSIS</b>			
PARAMETER	CONTROL LIMITS	POTABLE WATER	
pH at 25°C	7.0 – 9.2	8.23	
Conductivity at 25°C, µs/cm	--	189	
Total Dissolved Solids at 180°C (TDS)	1000 Max.	122	
Total Hardness, ppm as CaCO <sub>3</sub>	300 Max.	80	
Calcium Hardness, ppm as CaCO <sub>3</sub>	200 Max.	73	
Chloride, ppm as Cl <sup>-</sup>	250 Max.	69	
Iron, ppm as Fe	0.2 Max.	<0.05	
Zinc (Zn), mg/l	0.1 Max	<0.05	
Sulphate	250 Max.	31	
Fluorides (F)	1.5 Max	<0.05	
<b>Treatment Residuals</b>			
Residual Chlorine	0.2 – 0.5	0.33	
Color, mg/l	15 Max.	Clear	
Odor	Unobjectionable	ND	
Turbidity in NTU	5 Max	<1	
<b>*** All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).</b>			
<b>COMMENTS:</b>		<b>ACTION:</b>	
The pH and Conductivity/TDS are found satisfactory. ⇨		No action recommended.	
Dissolved iron levels are within control limits. ⇨		No action recommended.	
Zinc levels are satisfactory. ⇨		No action recommended.	
<b>Service Engineer:</b>	<b>MURUGARAJ P</b>	<b>Client:</b>	<b>M/S: FARAH EXPERIENCES, ABUDHABI</b>
<b>Signature:</b>		<b>Signature:</b>	





## CONSULTING SERVICE REPORT

<b>CUSTOMER: FARAH EXPERIENCES, ABUDHABI</b>		<b>DATE: 29-07-2020</b>	
<b>SITE: FERRARI WORLD</b>		<b>LOCATION: WATER TAP</b>	
<b>POTABLE WATER ANALYSIS</b>			
PARAMETER	CONTROL LIMITS	POTABLE WATER	
pH at 25°C	7.0 – 9.2	8.16	
Conductivity at 25°C, µs/cm	--	210	
Total Dissolved Solids at 180°C (TDS)	1000 Max.	136	
Total Hardness, ppm as CaCO <sub>3</sub>	300 Max.	85	
Calcium Hardness, ppm as CaCO <sub>3</sub>	200 Max.	78	
Chloride, ppm as Cl <sup>-</sup>	250 Max.	70	
Iron, ppm as Fe	0.2 Max.	<0.05	
Zinc (Zn), mg/l	0.1 Max	<0.05	
Sulphate	250 Max.	27	
Fluorides (F)	1.5 Max	<0.05	
<b>Treatment Residuals</b>			
Residual Chlorine	0.2 – 0.5	0.32	
Color, mg/l	15 Max.	Clear	
Odor	Unobjectionable	ND	
Turbidity in NTU	5 Max	<1	
<b>*** Aqll test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).</b>			
<b>COMMENTS:</b>		<b>ACTION:</b>	
The pH and Conductivity/TDS are found satisfactory. ⇨		No action recommended.	
Dissolved iron levels are within control limits. ⇨		No action recommended.	
Zinc levels are satisfactory. ⇨		No action recommended.	
<b>Service Engineer:</b>	<b>Murugaraaj</b>	<b>Client:</b>	<b>M/S: Farah Experiences, Abu Dhabi</b>
<b>Signature:</b>		<b>Signature:</b>	

