




CRYSTALLINE ENVIRONMENTAL SERVICES

CONSULTING SERVICE REPORT

CUSTOMER: FARAH EXPERIENCES, ABUDHABI		DATE: 03-01-2021	
SITE: FERRARI WORLD		LOCATION: TANK 1	
POTABLE WATER ANALYSIS			
PARAMETER	CONTROL LIMITS	POTABLE WATER	
pH at 25°C	7.0 – 9.2	8.76	
Conductivity at 25°C, µs/cm	--	227	
Total Dissolved Solids at 180°C (TDS)	1000 Max.	147	
Total Hardness, ppm as CaCO ₃	300 Max.	71	
Calcium Hardness, ppm as CaCO ₃	200 Max.	62	
Chloride, ppm as Cl ⁻	250 Max.	49	
Iron, ppm as Fe	0.2 Max.	<0.05	
Zinc (Zn), mg/l	0.1 Max	<0.05	
Sulphate	250 Max.	<10	
Fluorides (F)	1.5 Max	<0.05	
Treatment Residuals			
Color, mg/l	15 Max.	Clear	
Odor	Unobjectionable	ND	
Turbidity in NTU	5 Max	<1.0	
*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).			
COMMENTS:		ACTION:	
The pH and Conductivity/TDS are found satisfactory. <input type="checkbox"/>		No action recommended.	
Dissolved iron levels are within control limits. <input type="checkbox"/>		No action recommended.	
Zinc levels are satisfactory. <input type="checkbox"/>		No action recommended.	
Service Engineer:	MURUGARAJ P	Client:	M/S: FARAH EXPERIENCES, ABUDHABI
Signature:		Signature:	





CRYSTALLINE ENVIRONMENTAL SERVICES

CONSULTING SERVICE REPORT

CUSTOMER: FARAH EXPERIENCES, ABUDHABI	DATE: 03-01-2021
SITE: FERRARI WORLD	LOCATION: TANK 2

POTABLE WATER ANALYSIS

PARAMETER	CONTROL LIMITS	POTABLE WATER
pH at 25°C	7.0 – 9.2	8.44
Conductivity at 25°C, $\mu\text{s}/\text{cm}$	--	226
Total Dissolved Solids at 180°C (TDS)	1000 Max.	146
Total Hardness, ppm as CaCO_3	300 Max.	69
Calcium Hardness, ppm as CaCO_3	200 Max.	56
Chloride, ppm as Cl^-	250 Max.	54
Iron, ppm as Fe	0.2 Max.	<0.05
Zinc (Zn), mg/l	0.1 Max	<0.05
Sulphate	250 Max.	<10
Fluorides (F)	1.5 Max	<0.05

Treatment Residuals

Color, mg/l	15 Max.	Clear
Odor	Unobjectionable	ND
Turbidity in NTU	5 Max	<1.0

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS:

ACTION:

The pH and Conductivity/TDS are found satisfactory. \Rightarrow	No action recommended.
Dissolved iron levels are within control limits. \Rightarrow	No action recommended.
Zinc levels are satisfactory. \Rightarrow	No action recommended.

Service Engineer:	MURUGARAJ P	Client:	M/S: FARAH EXPERIENCES, ABUDHABI
Signature:		Signature:	





CRYSTALLINE ENVIRONMENTAL SERVICES

CONSULTING SERVICE REPORT

CUSTOMER: FARAH EXPERIENCES, ABUDHABI	DATE: 03-01-2021
SITE: FERRARI WORLD	LOCATION: WATER TAP

POTABLE WATER ANALYSIS

PARAMETER	CONTROL LIMITS	POTABLE WATER
pH at 25°C	7.0 - 9.2	8.33
Conductivity at 25°C, $\mu\text{s}/\text{cm}$	--	241
Total Dissolved Solids at 180°C (TDS)	1000 Max.	156
Total Hardness, ppm as CaCO_3	300 Max.	66
Calcium Hardness, ppm as CaCO_3	200 Max.	57
Chloride, ppm as Cl^-	250 Max.	42
Iron, ppm as Fe	0.2 Max.	<0.05
Zinc (Zn), mg/l	0.1 Max	<0.05
Sulphate	250 Max.	<10
Fluorides (F)	1.5 Max	<0.05

Treatment Residuals


Color, mg/l	15 Max.	Clear
Odor	Unobjectionable	ND
Turbidity in NTU	5 Max	<1.0

*** All test results expressed in parts per million (ppm) as CaCO_3 except pH and conductivity (μmhos).

COMMENTS:

ACTION:

The pH and Conductivity/TDS are found satisfactory. \Rightarrow	No action recommended.
Dissolved iron levels are within control limits. \Rightarrow	No action recommended.
Zinc levels are satisfactory. \Rightarrow	No action recommended.

Service Engineer:	MURUGARAJ P	Client:	M/S: FARAH EXPERIENCES, ABUDHABI
Signature:		Signature:	

