

## TEST REPORT

Report No: QMTL/R-94343/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-94343	
	Date Received	20 Feb 2020	
	Date(s) Tested	20 Feb 2020 - 22 Feb 2020	
	Date Reported	29 Feb 2020	
Sample Description	Hot Calorifier ,P1- Solar Water Tank- 1		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	20.02.2020/12:18 PM
Sample Container	1x500ml PB	Sampling Point	Valve
Sample Receipt Temp	5°C	Sample Onsite Temp	20.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	500	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero
Remarks	The sample meets DM Water Systems quality (2010) specifications for Hot & Cold Water System with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	55 & 78 & 74
Report prepared by Emp#	22

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

**TEST REPORT**

Report No: QMTL/R-94344/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-94344
	Date Received	20 Feb 2020
	Date(s) Tested	20 Feb 2020 - 22 Feb 2020
	Date Reported	29 Feb 2020
Sample Description	Hot Calorifier ,P1- Solar Water Tank- 2	
Sample Type	Water	Sampling Method QMTL-WI-15
Client Name/Project	NP	Sampled By QMTL Representative
Location	AUH	Sampling Date/Time 20.02.2020/12:23 PM
Sample Container	1x500ml PB	Sampling Point Valve
Sample Receipt Temp	5°C	Sample Onsite Temp 21°C
Sample Appearance	Clear	On-site Treatment NA
Reference	HEALTHPOINT HOSPITAL	

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	500	2
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero
Remarks	The sample meets DM Water Systems quality (2010) specifications for Hot & Cold Water System with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	55 & 78 & 74
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By




**ANILA GEORGE**

**LABORATORY MANAGER**

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-94089/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-94089	
	Date Received	19 Feb 2020	
	Date(s) Tested	19 Feb 2020 - 21 Feb 2020	
	Date Reported	27 Feb 2020	
Sample Description	<b>Hot Calorifier No: 03</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	19.02.2020/10:35 AM
Sample Container	1x500ml PB	Sampling Point	Valve
Sample Receipt Temp	5°C	Sample Onsite Temp	59°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	-	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	-	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	-	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	500	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	-	Zero
Remarks	The sample meets DM Water Systems quality (2010) specifications for Hot & Cold water system with respect to the above tests only.			

Keywords	CFU: Colony Forming Unit, APHA: American Public Health Association, DM: Dubai Municipality, NP: Not Provided;NA: Not Applicable, WI: Work Instruction
----------	---

Test method deviation	None
-----------------------	------

Test performed by Emp#	55 & 74
------------------------	---------

Report prepared by Emp#	22
-------------------------	----

The above test results are only applicable to the sample(s) referred above.

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-94092/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-94092	
	Date Received	19 Feb 2020	
	Date(s) Tested	19 Feb 2020 - 21 Feb 2020	
	Date Reported	27 Feb 2020	
Sample Description	P1.14, Men's Rest Room ( Staff ) - Hot Water		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	19.02.2020/11:00 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	5°C	Sample Onsite Temp	52.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-94350/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-94350	
	Date Received	20 Feb 2020	
	Date(s) Tested	20 Feb 2020 - 22 Feb 2020	
	Date Reported	29 Feb 2020	
Sample Description	P2 Kitchen, Cooking Area, Hot Water		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	20.02.2020/01:23 PM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	5°C	Sample Onsite Temp	48.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			
Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health -Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, WI: Work Instruction			
Test method deviation	None			
Test performed by Emp#	55 & 78 & 74			
Report prepared by Emp#	22			
The above test results are only applicable to the sample(s) referred above.				

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-94341/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-94341	
	Date Received	20 Feb 2020	
	Date(s) Tested	20 Feb 2020 - 22 Feb 2020	
	Date Reported	29 Feb 2020	
Sample Description	Level 3, Hot Water Men's Rest Room, Hospital Side		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	20.02.2020/12:00 PM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	5°C	Sample Onsite Temp	40°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health -Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	55 & 78 & 74
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By




ANILA GEORGE

LABORATORY MANAGER

The test report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-94333/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-94333	
	Date Received	20 Feb 2020	
	Date(s) Tested	20 Feb 2020 - 22 Feb 2020	
	Date Reported	29 Feb 2020	
Sample Description	Level 02, Wooridul Wash Room, Hot Water ( Male Changing Room )		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	20.02.2020/10:30 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	5°C	Sample Onsite Temp	41°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	4
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	55 & 78 & 74
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-94349/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-94349		
	Date Received	20 Feb 2020		
	Date(s) Tested	20 Feb 2020 - 22 Feb 2020		
	Date Reported	29 Feb 2020		
Sample Description	P2 Kitchen, Cooking Area, Cold Water			
Sample Type	Water	Sampling Method	QMTL-WI-15	
Client Name/Project	NP	Sampled By	QMTL Representative	
Location	AUH	Sampling Date/Time	20.02.2020/01:18 PM	
Sample Container	1x500ml PB	Sampling Point	Tap	
Sample Receipt Temp	5°C	Sample Onsite Temp	19.6°C	
Sample Appearance	Clear	On-site Treatment	NA	
Reference	HEALTHPOINT HOSPITAL			

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			
Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health -Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, WI: Work Instruction			
Test method deviation	None			
Test performed by Emp#	55 & 78 & 74			
Report prepared by Emp#	22			
The above test results are only applicable to the sample(s) referred above.				

Reported By



ANILA GEORGE

LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

END OF REPORT

## TEST REPORT

Report No: QMTL/R-94091/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-94091	
	Date Received	19 Feb 2020	
	Date(s) Tested	19 Feb 2020 - 21 Feb 2020	
	Date Reported	27 Feb 2020	
Sample Description	<b>P1.14, Men's Rest Room ( Staff ) - Cold Water</b>		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	19.02.2020/10:50 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	5°C	Sample Onsite Temp	24.2°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets the limits of HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, , WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	55 & 74
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

## TEST REPORT

Report No: QMTL/R-94334/2020

<b>CLIENT</b> : CRYSTALLINE ENVIRONMENTAL SERVICES Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN</b> : MR. JASMAN PINTO	Sample ID	QMTL/S-94334	
	Date Received	20 Feb 2020	
	Date(s) Tested	20 Feb 2020 - 22 Feb 2020	
	Date Reported	29 Feb 2020	
Sample Description	Level 02, H2.30 Cold Water Men's Rest Room		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	20.02.2020/10:42 AM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	5°C	Sample Onsite Temp	21.5°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

### TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			

Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health –Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, WI: Work Instruction
----------	--

Test method deviation	None
Test performed by Emp#	55 & 78 & 74
Report prepared by Emp#	22
The above test results are only applicable to the sample(s) referred above.	

Reported By



**ANILA GEORGE**  
LABORATORY MANAGER



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**

**TEST REPORT**

Report No: QMTL/R-94342/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates  <b>ATTN : MR. JASMAN PINTO</b>	Sample ID	QMTL/S-94342	
	Date Received	20 Feb 2020	
	Date(s) Tested	20 Feb 2020 - 22 Feb 2020	
	Date Reported	29 Feb 2020	
Sample Description	Level 3, Cold Water Men's Rest Room, Hospital Side		
Sample Type	Water	Sampling Method	QMTL-WI-15
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	20.02.2020/12:10 PM
Sample Container	1x500ml PB	Sampling Point	Tap
Sample Receipt Temp	5°C	Sample Onsite Temp	23.1°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

**TEST RESULTS**

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>MICROBIOLOGICAL ANALYSIS</b>				
E.coli	APHA 9222 H & I (23rd Edition)	CFU/100 ml	Zero	Zero
Fecal Coliforms	APHA 9222 D (23rd Edition)	CFU/100 ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E (23rd Edition)	CFU/100 ml	Zero	Zero
Total Bacterial Count	APHA 9215 B (23rd Edition)	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B (23rd Edition)	CFU/100 ml	Zero	Zero
Remarks	The sample meets HAAD EHSMS Standard for Healthcare Providers- RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.			
Keywords	CFU : Colony Forming Unit, APHA : American Public Health Association, RSB : Regulation & Supervision Bureau HAAD : The Health -Authority- Abu Dhabi, EHSMS : Environment, Health and Safety Management System, NP : Not Provided, NA: Not Applicable, WI: Work Instruction			
Test method deviation	None			
Test performed by Emp#	55 & 78 & 74			
Report prepared by Emp#	22			
The above test results are only applicable to the sample(s) referred above.				

Reported By



**ANILA GEORGE**

**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**