

## POTABLE WATER ANALYSIS REPORT

<b>Client Name: SERCO, MIDDLE EAST</b>			
<b>Site location</b>	Abu Dhabi Investment Authority, Abu Dhabi	<b>Service Visit:</b>	15/10/2019
<b>Sampled By</b>	Crystalline Rep	<b>Location</b>	ADIA - HQ
<b>Sample Type</b>	Potable Water (Hot Outlet)	<b>Sample Point</b>	LG- Calorifier # 04

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.08
2	Conductivity at 25°C, µs/cm	----	221
3	Total Dissolved Solids (TDS)	Max 1000	143
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	<0.03
7	Calcium Hardness at 25°C	200	49
8	Total Hardness at 25°C	300	56

### Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	37
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

### COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,  
*Murugaraaj*  
Murugaraaj  
Service Engineer



## POTABLE WATER ANALYSIS REPORT

<b>Client Name: SERCO, MIDDLE EAST</b>			
<b>Site location</b>	<b>Abu Dhabi Investment Authority, Abu Dhabi</b>	<b>Service Visit:</b>	<b>15/10/2019</b>
<b>Sampled By</b>	<b>Crystalline Rep</b>	<b>Location</b>	<b>ADIA - HQ</b>
<b>Sample Type</b>	<b>Potable Water (Hot Outlet)</b>	<b>Sample Point</b>	<b>LG- Calorifier # 05</b>

	<b>Parameter</b>	<b>Control Limits</b>	<b>Test Results</b>
1	pH at 25°C	7.0 - 9.2	8.10
2	Conductivity at 25°C, µs/cm	----	225
3	Total Dissolved Solids (TDS)	Max 1000	146
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	<0.03
7	Calcium Hardness at 25°C	200	49
8	Total Hardness at 25°C	300	58

### Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	37
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

### COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,  
  
 Murugaraaj  
 Service Engineer



## POTABLE WATER ANALYSIS REPORT

**Client Name: SERCO, MIDDLE EAST**

<b>Site location</b>	Abu Dhabi Investment Authority, Abu Dhabi	<b>Service Visit:</b>	15/10/2019
<b>Sampled By</b>	Crystalline Rep	<b>Location</b>	ADIA - HQ
<b>Sample Type</b>	Potable Water (Hot Outlet)	<b>Sample Point</b>	HQ Mezzanine Floor Kitchen

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.12
2	Conductivity at 25°C, µs/cm	----	217
3	Total Dissolved Solids (TDS)	Max 1000	141
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	<0.03
7	Calcium Hardness at 25°C	200	50
8	Total Hardness at 25°C	300	55

### Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	31
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

### COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit .
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,  
*Murugaraaj*  
Murugaraaj  
Service Engineer





## POTABLE WATER ANALYSIS REPORT

<b>Client Name: SERCO, MIDDLE EAST</b>			
Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	15/10/2019
Sampled By	Crystalline Rep	Location	ADIA - HQ
Sample Type	Potable Water (Hot Outlet)	Sample Point	Basement Shower Room

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.20
2	Conductivity at 25°C, µs/cm	----	227
3	Total Dissolved Solids (TDS)	Max 1000	149
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 – 0.5	<0.03
7	Calcium Hardness at 25°C	200	46
8	Total Hardness at 25°C	300	50

### Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	24
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

### COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,  
*Murugaraaj*  
Murugaraaj  
Service Engineer



## POTABLE WATER ANALYSIS REPORT

**Client Name: SERCO, MIDDLE EAST**

<b>Site location</b>	Abu Dhabi Investment Authority, Abu Dhabi	<b>Service Visit:</b>	15/10/2019
<b>Sampled By</b>	Crystalline Rep	<b>Location</b>	ADIA - HQ
<b>Sample Type</b>	Potable Water (Hot Outlet)	<b>Sample Point</b>	Wing 16A pantry

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.19
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	----	206
3	Total Dissolved Solids (TDS)	Max 1000	140
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	<0.03
7	Calcium Hardness at 25°C	200	47
8	Total Hardness at 25°C	300	54

### Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	30
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05


\*\*\* All test results expressed in parts per million (ppm) as  $\text{CaCO}_3$  except pH and conductivity ( $\mu\text{mhos}$ ).

### COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

Murugaraaj  
Service Engineer



## POTABLE WATER ANALYSIS REPORT

**Client Name: SERCO, MIDDLE EAST**

<b>Site location</b>	<b>Abu Dhabi Investment Authority, Abu Dhabi</b>	<b>Service Visit:</b>	<b>15/10/2019</b>
<b>Sampled By</b>	<b>Crystalline Rep</b>	<b>Location</b>	<b>ADIA - HQ</b>
<b>Sample Type</b>	<b>Potable Water (Hot Outlet)</b>	<b>Sample Point</b>	<b>Wing 16B pantry</b>

	<b>Parameter</b>	<b>Control Limits</b>	<b>Test Results</b>
1	pH at 25°C	7.0 - 9.2	8.21
2	Conductivity at 25°C, $\mu\text{s}/\text{cm}$	----	215
3	Total Dissolved Solids (TDS)	Max 1000	139
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	<0.03
7	Calcium Hardness at 25°C	200	44
8	Total Hardness at 25°C	300	51

### Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	28
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

\*\*\* All test results expressed in parts per million (ppm) as  $\text{CaCO}_3$  except pH and conductivity ( $\mu\text{mhos}$ ).

### COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,  
Murugaraaj  
Service Engineer



## POTABLE WATER ANALYSIS REPORT

**Client Name: SERCO, MIDDLE EAST**

<b>Site location</b>	<b>Abu Dhabi Investment Authority, Abu Dhabi</b>	<b>Service Visit:</b>	<b>15/10/2019</b>
<b>Sampled By</b>	<b>Crystalline Rep</b>	<b>Location</b>	<b>ADIA - HQ</b>
<b>Sample Type</b>	<b>Potable Water (Hot Outlet))</b>	<b>Sample Point</b>	<b>L 36 Shower Room</b>

	<b>Parameter</b>	<b>Control Limits</b>	<b>Test Results</b>
1	<b>pH at 25°C</b>	7.0 - 9.2	8.16
2	<b>Conductivity at 25°C, µs/cm</b>	----	224
3	<b>Total Dissolved Solids (TDS)</b>	Max 1000	145
4	<b>Odor</b>	Unobjectionable	ND
5	<b>Turbidity (including suspended solids)</b>	4.0	<1.0
6	<b>Residual Chlorine</b>	0.2 - 0.5	<0.03
7	<b>Calcium Hardness at 25°C</b>	200	49
8	<b>Total Hardness at 25°C</b>	300	58

### Inorganic Chemical Parameters

1	<b>Sulphate</b>	Max 250.0	<10
2	<b>Chlorides</b>	Max 250.0	36
3	<b>Iron</b>	Max 0.2	<0.05
4	<b>Copper</b>	Max 1.0	<0.05
5	<b>Zinc</b>	Max 5.0	<0.05
6	<b>Nitrate</b>	Max 50.0	<1.0
7	<b>Nitrite</b>	Max 3.0	<0.05
8	<b>potassium</b>	Max 12.0	<5.0
9	<b>Aluminium</b>	Max 0.2	<0.05

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

### COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,  
*Murugaraaj*  
Murugaraaj  
Service Engineer



## POTABLE WATER ANALYSIS REPORT

**Client Name: SERCO, MIDDLE EAST**

Site location	Abu Dhabi Investment Authority, Abu Dhabi	Service Visit:	16/10/2019
Sampled By	Crystalline Rep	Location	ADIA - Car Parking
Sample Type	Potable Water (Hot Outlet)	Sample Point	B3 - Mess Hall

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.16
2	Conductivity at 25°C, $\mu\text{S/cm}$	----	220
3	Total Dissolved Solids (TDS)	Max 1000	143
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	<0.03
7	Calcium Hardness at 25°C	200	41
8	Total Hardness at 25°C	300	50

### Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	26
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

\*\*\* All test results expressed in parts per million (ppm) as  $\text{CaCO}_3$  except pH and conductivity ( $\mu\text{mhos}$ ).

### COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

Murugaraaj  
Service Engineer



## POTABLE WATER ANALYSIS REPORT

<b>Client Name: SERCO, MIDDLE EAST</b>			
<b>Site location</b>	<b>Abu Dhabi Investment Authority, Abu Dhabi</b>	<b>Service Visit:</b>	<b>16/10/2019</b>
<b>Sampled By</b>	<b>Crystalline Rep</b>	<b>Location</b>	<b>ADIA - Car Parking</b>
<b>Sample Type</b>	<b>Potable Water (Hot Outlet)</b>	<b>Sample Point</b>	<b>L1- Driver Shower Room</b>

	<b>Parameter</b>	<b>Control Limits</b>	<b>Test Results</b>
1	pH at 25°C	7.0 - 9.2	8.13
2	Conductivity at 25°C, µs/cm	----	218
3	Total Dissolved Solids (TDS)	Max 1000	414
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	<0.03
7	Calcium Hardness at 25°C	200	43
8	Total Hardness at 25°C	300	49

### Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	26
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

### COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,  
Murugaraaj  
Service Engineer



## POTABLE WATER ANALYSIS REPORT

**Client Name: SERCO, MIDDLE EAST**

<b>Site location</b>	<b>Abu Dhabi Investment Authority, Abu Dhabi</b>	<b>Service Visit:</b>	<b>16/10/2019</b>
<b>Sampled By</b>	<b>Crystalline Rep</b>	<b>Location</b>	<b>ADIA - BRC</b>
<b>Sample Type</b>	<b>Potable Water (Hot Outlet)</b>	<b>Sample Point</b>	<b>Ground Floor Pantry</b>

	<b>Parameter</b>	<b>Control Limits</b>	<b>Test Results</b>
1	pH at 25°C	7.0 - 9.2	8.13
2	Conductivity at 25°C, µs/cm	----	217
3	Total Dissolved Solids (TDS)	Max 1000	414
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	<0.03
7	Calcium Hardness at 25°C	200	44
8	Total Hardness at 25°C	300	51

### Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	27
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

### COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

Murugaraaj  
Service Engineer



## POTABLE WATER ANALYSIS REPORT

<b>Client Name: SERCO, MIDDLE EAST</b>			
<b>Site location</b>	Abu Dhabi Investment Authority, Abu Dhabi	<b>Service Visit:</b>	16/10/2019
<b>Sampled By</b>	Crystalline Rep	<b>Location</b>	ADIA - BRC
<b>Sample Type</b>	Potable Water (Hot Outlet)	<b>Sample Point</b>	Ground Floor Kitchen

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.09
2	Conductivity at 25°C, µs/cm	----	214
3	Total Dissolved Solids (TDS)	Max 1000	139
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	<0.03
7	Calcium Hardness at 25°C	200	47
8	Total Hardness at 25°C	300	53

### Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	30
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

### COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,  
Murugaraaj  
Service Engineer



## POTABLE WATER ANALYSIS REPORT

**Client Name: SERCO, MIDDLE EAST**

<b>Site location</b>	Abu Dhabi Investment Authority, Abu Dhabi	<b>Service Visit:</b>	16/10/2019
<b>Sampled By</b>	Crystalline Rep	<b>Location</b>	ADIA - BRC
<b>Sample Type</b>	Potable Water (Hot Outlet)	<b>Sample Point</b>	Ground Floor Wash Room

	Parameter	Control Limits	Test Results
1	pH at 25°C	7.0 - 9.2	8.07
2	Conductivity at 25°C, µS/cm	----	207
3	Total Dissolved Solids (TDS)	Max 1000	134
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	<0.03
7	Calcium Hardness at 25°C	200	45
8	Total Hardness at 25°C	300	52
<b>Inorganic Chemical Parameters</b>			
1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	27
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

### COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,

Murugaraaj

Service Engineer



## POTABLE WATER ANALYSIS REPORT

**Client Name: SERCO, MIDDLE EAST**

<b>Site location</b>	<b>Abu Dhabi Investment Authority, Abu Dhabi</b>	<b>Service Visit:</b>	<b>16/10/2019</b>
<b>Sampled By</b>	<b>Crystalline Rep</b>	<b>Location</b>	<b>ADIA - BRC</b>
<b>Sample Type</b>	<b>Potable Water (Hot Outlet)</b>	<b>Sample Point</b>	<b>Mezzanine Floor Wash Room</b>

	<b>Parameter</b>	<b>Control Limits</b>	<b>Test Results</b>
1	pH at 25°C	7.0 - 9.2	7.98
2	Conductivity at 25°C, µs/cm	----	201
3	Total Dissolved Solids (TDS)	Max 1000	131
4	Odor	Unobjectionable	ND
5	Turbidity (including suspended solids)	4.0	<1.0
6	Residual Chlorine	0.2 - 0.5	<0.03
7	Calcium Hardness at 25°C	200	47
8	Total Hardness at 25°C	300	55


### Inorganic Chemical Parameters

1	Sulphate	Max 250.0	<10
2	Chlorides	Max 250.0	31
3	Iron	Max 0.2	<0.05
4	Copper	Max 1.0	<0.05
5	Zinc	Max 5.0	<0.05
6	Nitrate	Max 50.0	<1.0
7	Nitrite	Max 3.0	<0.05
8	potassium	Max 12.0	<5.0
9	Aluminium	Max 0.2	<0.05

\*\*\* All test results expressed in parts per million (ppm) as CaCO<sub>3</sub> except pH and conductivity (µmhos).

### COMMENTS AND RECOMMENDATIONS

1	PH, Conductivity & TDS levels are normal
2	Residual chlorine level is low, kindly maintain the level with in the control limit
3	Calcium hardness and Total Hardness levels are satisfactory
4	All inorganic parameters are within the control limit

Reported By,  
  
 Murugaraaj  
 Service Engineer

