



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31960



Request No. : WA-Q-L-2101-04511

Sample No. : WA-S-L-2101-31417

Sampling Date	: 07/01/2021	Report Date.	: 10/01/2021
Analysis Start Date.	: 07/01/2021	Analysis End Date.	: 10/01/2021
Sample Location.	: City of Lights C4 Tower	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3286	Sampling Method	: APHA 9060 A&B
Temperature °C	: 10.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: B2
Sampling Point	: ETS Room - Low Zone	Preservation	: 4-8°C
Sample Description	: Chilled Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H&I 23rd Ed. 2017	CFU/100ml	Not Detected	-
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	-
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	10000CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	-
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	-

Note : Not Detected=<1CFU

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D.

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31961



Request No. : WA-Q-L-2101-04511

Sample No. : WA-S-L-2101-31418

Sampling Date	: 07/01/2021	Report Date.	: 18/01/2021
Analysis Start Date.	: 07/01/2021	Analysis End Date.	: 17/01/2021
Sample Location.	: City of Lights C4 Tower	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3286	Sampling Method	: BS 7592
Temperature °C	: 10.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: B2
Sampling Point	: ETS Room - Low Zone	Preservation	: 10°C
Sample Description	: Chilled Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	100CFU/L

Note : Limit of Detection=<20CFU/L

Procedure: WSOP-MB-0051. Filtration, Washing, Heat Treatment, Acid Treatment followed by Plating on GVPC/BCYE Agar.

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested.This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31963



Request No. : WA-Q-L-2101-04511

Sample No. : WA-S-L-2101-31420

Sampling Date	: 07/01/2021	Report Date.	: 18/01/2021
Analysis Start Date.	: 07/01/2021	Analysis End Date.	: 17/01/2021
Sample Location.	: City of Lights C4 Tower	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3286	Sampling Method	: BS 7592
Temperature °C	: 11.2	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: B2
Sampling Point	: ETS Room - High Zone	Preservation	: 10°C
Sample Description	: Chilled Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	100CFU/L

Note : Limit of Detection= \leq 20CFU/L

Procedure: WSOP-MB-0051. Filtration, Washing, Heat Treatment, Acid Treatment followed by Plating on GVPC/BCYE Agar.

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31968



Request No. : WA-Q-L-2101-04513

Sample No. : WA-S-L-2101-31425

Sampling Date	: 07/01/2021	Report Date.	: 11/01/2021
Analysis Start Date.	: 07/01/2021	Analysis End Date.	: 10/01/2021
Sample Location.	: City of Lights C5Tower	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3288	Sampling Method	: APHA 9060 A&B
Temperature °C	: 9.9	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: B2
Sampling Point	: ETS Room - Low Zone	Preservation	: 4-8°C
Sample Description	: Chilled Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	-
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	-
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	10000CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	-
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	-

Note : Not Detected=<1CFU

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31970



Request No. : WA-Q-L-2101-04513

Sample No. : WA-S-L-2101-31427

Sampling Date	: 07/01/2021	Report Date.	: 18/01/2021
Analysis Start Date.	: 07/01/2021	Analysis End Date.	: 17/01/2021
Sample Location.	: City of Lights C5Tower	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3288	Sampling Method	: BS 7592
Temperature °C	: 9.9	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: B2
Sampling Point	: ETS Room - Low Zone	Preservation	: 10°C
Sample Description	: Chilled Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	100CFU/L

Note : Limit of Detection= \leq 20CFU/L

Procedure: WSOP-MB-0051. Filtration, Washing, Heat Treatment, Acid Treatment followed by Plating on GVPC/BCYE Agar.

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31969



Request No. : WA-Q-L-2101-04513

Sample No. : WA-S-L-2101-31426

Sampling Date	: 07/01/2021	Report Date.	: 11/01/2021
Analysis Start Date.	: 07/01/2021	Analysis End Date.	: 10/01/2021
Sample Location.	: City of Lights C5Tower	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3288	Sampling Method	: APHA 9060 A&B
Temperature °C	: 9.6	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: B2
Sampling Point	: ETS Room - High Zone	Preservation	: 4-8°C
Sample Description	: Chilled Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	-
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	-
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	10000CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	-
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	-

Note : Not Detected=<1CFU

Limits based on RSB Water Quality Regulation 2014. Schedule 1. Table F For Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31971



Request No. : WA-Q-L-2101-04513

Sample No. : WA-S-L-2101-31428

Sampling Date	: 07/01/2021	Report Date.	: 18/01/2021
Analysis Start Date.	: 07/01/2021	Analysis End Date.	: 17/01/2021
Sample Location.	: City of Lights C5Tower	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3288	Sampling Method	: BS 7592
Temperature °C	: 9.6	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: B2
Sampling Point	: ETS Room - High Zone	Preservation	: 10°C
Sample Description	: Chilled Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	100CFU/L

Note : Limit of Detection= \leq 20CFU/L

Procedure: WSOP-MB-0051. Filtration, Washing, Heat Treatment, Acid Treatment followed by Plating on GVPC/BCYE Agar.

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31972



Request No. : WA-Q-L-2101-04514

Sample No. : WA-S-L-2101-31429

Sampling Date	: 07/01/2021	Report Date.	: 10/01/2021
Analysis Start Date.	: 07/01/2021	Analysis End Date.	: 10/01/2021
Sample Location.	: City of Lights C6 Tower	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3286	Sampling Method	: APHA 9060 A&B
Temperature °C	: 11.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: B2
Sampling Point	: ETS Room - Low Zone	Preservation	: 4-8°C
Sample Description	: Chilled Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	-
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	-
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	10000CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	-
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	-

Note : Not Detected=<1CFU

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2101-31974

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2101-04514

Sample No. : WA-S-L-2101-31431

Sampling Date	: 07/01/2021	Report Date.	: 18/01/2021
Analysis Start Date.	: 07/01/2021	Analysis End Date.	: 17/01/2021
Sample Location.	: City of Lights C6 Tower	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3286	Sampling Method	: BS 7592
Temperature °C	: 11.1	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: B2
Sampling Point	: ETS Room - Low Zone	Preservation	: 10°C
Sample Description	: Chilled Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	100CFU/L

Note : Limit of Detection= \leq 20CFU/L

Procedure: WSOP-MB-0051. Filtration, Washing, Heat Treatment, Acid Treatment followed by Plating on GVPC/BCYE Agar.

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31973



Request No. : WA-Q-L-2101-04514

Sample No. : WA-S-L-2101-31430

Sampling Date	: 07/01/2021	Report Date.	: 10/01/2021
Analysis Start Date.	: 07/01/2021	Analysis End Date.	: 10/01/2021
Sample Location.	: City of Lights C6 Tower	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3286	Sampling Method	: APHA 9060 A&B
Temperature °C	: 10.4	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: B2
Sampling Point	: ETS Room - High Zone	Preservation	: 4-8°C
Sample Description	: Chilled Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	-
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	-
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	Not Detected	10000CFU/ml
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	-
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	Not Detected	-

Note : Not Detected=<1CFU

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested results of the sample are found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2101-31975



Request No. : WA-Q-L-2101-04514

Sample No. : WA-S-L-2101-31432

Sampling Date	: 07/01/2021	Report Date.	: 18/01/2021
Analysis Start Date.	: 07/01/2021	Analysis End Date.	: 17/01/2021
Sample Location.	: City of Lights C6 Tower	Sampled By	: Shoukth
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 3286	Sampling Method	: BS 7592
Temperature °C	: 10.4	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: B2
Sampling Point	: ETS Room - High Zone	Preservation	: 10°C
Sample Description	: Chilled Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/L	Not Detected	100CFU/L

Note : Limit of Detection= \leq 20CFU/L

Procedure: WSOP-MB-0051. Filtration, Washing, Heat Treatment, Acid Treatment followed by Plating on GVPC/BCYE Agar.

Limit based on DM. Rev2.Dated 6/2010 for guidelines for control of legionella in water system. Public Safety Department.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -

CLIENT: TAFAWUQ FACILITY MANAGEMENT
 SITE: CITY OF LIGHTS
 AL REEM ISLAND
 ABU DHABI

VISIT DATE: 26 Jan 2021

CHILLED WATER ANALYSIS

Test	C4 HZ	C4 LZ	C5 HZ	C5 LZ	C6 HZ	C6 LZ
pH	10.17	9.54	10.18	10.09	10.16	10.14
	8.5 - 10.0	8.5 - 10.0	8.5 - 10.0	8.5 - 10.0	8.5 - 10.0	8.5 - 10.0
Conductivity, $\mu\text{s}/\text{cm}$	2294	2281	2217	2286	2267	2239
	< 2250	< 2250	< 2250	< 2250	< 2250	< 2250
Total Dissolved Solid, ppm	1491	1485	1441	1485	1473	1455
	< 1500	< 1500	< 1500	< 1500	< 1500	< 1500
Iron, ppm as Fe	<0.10	<0.10	0.16	0.13	0.16	<0.10
	0 - 1	0 - 1	0 - 1	0 - 1	0 - 1	0 - 1
Total Hardness, ppm	73	58	57	84	87	74
	< 100	< 100	< 100	< 100	< 100	< 100
Total Alkalinity, ppm	96	92	73	96	83	81
	< 250	< 250	< 250	< 250	< 250	< 250
Chlorides as Cl-, ppm	92	88	86	72	82	86
	< 150	< 150	< 150	< 150	< 150	< 150
Nitrite, ppm	980	950	990	960	970	950
	800 - 1000	800 - 1000	800 - 1000	800 - 1000	800 - 1000	800 - 1000

***All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (μmhos).

BUILDING	COMMENTS	ACTION
C4 - HZ	pH & Conductivity levels are slightly high	Please arrange to drain the water
C4 - LZ	Conductivity levels are slightly high	Please arrange to drain the water
C5 - HZ	pH levels are slightly high	Please arrange to drain the water
C5 - LZ	pH & Conductivity levels are slightly high	Please arrange to drain the water
C6 - HZ	pH & Conductivity levels are slightly high	Please arrange to drain the water
C6 - LZ	pH levels are slightly high	Please arrange to drain the water

Reported By:


 Murugaraaj
 Service Engineer

