

## TEST REPORT

Report No: QMTL/R-94104/2020

<b>CLIENT : CRYSTALLINE ENVIRONMENTAL SERVICES</b> Abu Dhabi PO Box : 131463 United Arab Emirates		Sample ID	QMTL/S-94104
		Date Received	19 Feb 2020
		Date(s) Tested	19 Feb 2020 - 29 Feb 2020
<b>ATTN : MR. JASMAN PINTO</b>		Date Reported	02 Mar 2020
Sample Description	<b>P1 - Hydrotherapy Pool</b>		
Sample Type	Water	Sampling Method	QMTL-WI-16
Client Name/Project	NP	Sampled By	QMTL Representative
Location	AUH	Sampling Date/Time	19.02.2020/10:00 AM
Sample Container	1x1L PB	Sampling Point	Pool
Sample Receipt Temp	16°C	Sample Onsite Temp	31.8°C
Sample Appearance	Clear	On-site Treatment	NA
Reference	HEALTHPOINT HOSPITAL		

## TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	GUIDELINES	RESULTS
<b>LEGIONELLA ANALYSIS</b>				
Legionella	CCFRA 3.9.1 (5th Edition)	CFU/litre	<1	Not Detected
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5th Edition)	-	-	Absent
Legionella Species	CCFRA 3.9.1 (5th Edition)	-	-	Absent

Remarks	The sample meets DM Water Systems quality (2010) specifications for Pool Water with respect to the above tests only.
---------	--

Keywords	CFU : Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, DM: Dubai Municipality WI: Work Instruction, NP : Not Provided, NA: Not Applicable.
----------	--

Test method deviation	None
-----------------------	------

Test performed by Emp#	74 & 78
------------------------	---------

Report prepared by Emp#	72
-------------------------	----

The above test results are only applicable to the sample(s) referred above.	
---	--

Reported By



**ANILA GEORGE**  
**LABORATORY MANAGER**



The test report shall not be reproduced(except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is solely to ensure that the analysis is conducted to standard test methods in accordance with Industry accepted practice.

**END OF REPORT**