



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28685



Request No. : WA-Q-L-2012-04077

Sample No.: WA-S-L-2012-28074

Sampling Date	: 08/12/2020	Report Date.	: 10/12/2020
Analysis Start Date.	: 08/12/2020	Analysis End Date.	: 10/12/2020
Sample Location.	: Zayed University	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2971	Sampling Method	: APHA 9060 A&B
Temperature °C	: 35	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: SV1 Irrigation Water Tank
Sampling Point	: Underground Tank	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	-
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	23CFU/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	400	-
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	-
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	10	-

Note : Not Detected= \leq 10CFU/100ml

Limit based on RSB Abu Dhabi Recycled water and biosolids regulation, 2018. Table A2 for Microbiological Parameters.

Remarks :The tested results of the sample are found to be satisfactory within the available specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report should not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28688



Request No. : WA-Q-L-2012-04077

Sample No. : WA-S-L-2012-28077

Sampling Date	: 08/12/2020	Report Date.	: 10/12/2020
Analysis Start Date.	: 08/12/2020	Analysis End Date.	: 10/12/2020
Sample Location.	: Zayed University	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2971	Sampling Method	: APHA 9060 A&B
Temperature °C	: 34	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Irrigation Water Sprinkler Outlet
Sampling Point	: Cortyard Female Side	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	-
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	23CFU/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	550	-
Pseudomonas aeruginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	-
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	08	-

Note : Not Detected=<10CFU/100ml

Limit based on RSB Abu Dhabi Recycled water and biosolids regulation, 2018. Table A2 for Microbiological Parameters

Remarks :The tested results of the sample are found to be satisfactory within the available specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Microbiology Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28687



Request No. : WA-Q-L-2012-04077

Sample No. : WA-S-L-2012-28076

Sampling Date	: 08/12/2020	Report Date.	: 10/12/2020
Analysis Start Date.	: 08/12/2020	Analysis End Date.	: 10/12/2020
Sample Location.	: Zayed University	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2971	Sampling Method	: APHA 9060 A&B
Temperature °C	: 33	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Irrigation Water Sprinkler Outlet
Sampling Point	: Cortyard Male Side	Preservation	: 4-8°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Escherichia Coli	APHA 9222 B,H& I 23rd Ed. 2017	CFU/100ml	Not Detected	-
Faecal Coliforms	APHA 9222 D 23rd Ed. 2017	CFU/100ml	Not Detected	23CFU/100ml
Heterotrophic plate count	APHA 9215 B 23rd Ed. 2017	CFU/ml	500	-
Pseudomonas aeroginosa	CCFRA 2.5.2 5th Ed. 2007	CFU/250ml	Not Detected	-
Total Coliforms	APHA 9222 B 23rd Ed. 2017	CFU/100ml	10	-

Note : Not Detected=<10CFU/100ml

Limit based on RSB Abu Dhabi Recycled water and biosolids regulation, 2018. Table A2 for Microbiological Parameters

Remarks :The tested results of the sample are found to be satisfactory within the available specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; APHA-American Public Health Association; CCFRA-Campden Chorleywood Food Research Association

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D
Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-01 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2012-28700

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2012-04077

Sample No. : WA-S-L-2012-28089

Sampling Date	: 08/12/2020	Report Date.	: 19/12/2020
Analysis Start Date.	: 08/12/2020	Analysis End Date.	: 18/12/2020
Sample Location.	: Zayed University	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2971	Sampling Method	: BS 7592
Temperature °C	: 35	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: SV1 Irrigation Water Tank
Sampling Point	: Underground Tank	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/ml	Not Detected	100CFU or MPN/ml

Note : Limit of Detection=<10CFU/ml

Procedure: WSOP-MB-0051. Dilution, Heat Treatment, Acid Treatment followed by Plating on GVPC/MWY Agar.

Limit based on RSB Abu Dhabi Recycled water and biosolids regulation, 2018. Table A2 for Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28701



Request No. : WA-Q-L-2012-04077

Sample No. : WA-S-L-2012-28090

Sampling Date	: 08/12/2020	Report Date.	: 19/12/2020
Analysis Start Date.	: 08/12/2020	Analysis End Date.	: 18/12/2020
Sample Location.	: Zayed University	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2971	Sampling Method	: BS 7592
Temperature °C	: 34	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: FF2 Irrigation Water Sprinkler
Sampling Point	: Outlet	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/ml	Not Detected	100CFU or MPN/ml

Note : Limit of Detection=<10CFU/ml

Procedure: WSOP-MB-0051. Dilution, Heat Treatment, Acid Treatment followed by Plating on GVPC/MWY Agar.
Limit based on RSB Abu Dhabi Recycled water and biosolids regulation, 2018. Table A2 for Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Report No. WA-R-L-2012-28703

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.



Request No. : WA-Q-L-2012-04077

Sample No. : WA-S-L-2012-28092

Sampling Date	: 08/12/2020	Report Date.	: 19/12/2020
Analysis Start Date.	: 08/12/2020	Analysis End Date.	: 18/12/2020
Sample Location.	: Zayed University	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2971	Sampling Method	: BS 7592
Temperature °C	: 34	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Irrigation Water Sprinkler Outlet
Sampling Point	: Cortyard Female Side	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/ml	Not Detected	100CFU or MPN/ml

Note : Limit of Detection=<10CFU/ml

Procedure: WSOP-MB-0051. Dilution, Heat Treatment, Acid Treatment followed by Plating on GVPC/MWY Agar.

Limit based on RSB Abu Dhabi Recycled water and biosolids regulation, 2018. Table A2 for Microbiological Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories



Dr. Suresh Murugan Ph.D

Head of Microbiology Department

Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -



Legionella Test Report

Customer Details

Crystalline Cleaning & Environmental Services

P.O.Box: 131463 Warehouse no: 84, M-45. Mussafah, Abu Dhabi, UAE.

Report No. WA-R-L-2012-28702



Request No. : WA-Q-L-2012-04077

Sample No. : WA-S-L-2012-28091

Sampling Date	: 08/12/2020	Report Date.	: 19/12/2020
Analysis Start Date.	: 08/12/2020	Analysis End Date.	: 18/12/2020
Sample Location.	: Zayed University	Sampled By	: Amin ullah
Sample Identification	: Not Given	Sample Submitted as	: Water
Sample Certificate No	: 2971	Sampling Method	: BS 7592
Temperature °C	: 33	Site Observation	: Clear
Sampling Container	: Sterile Plastic Bottle	Source of Sample	: Irrigation Water Sprinkler Outlet
Sampling Point	: Cortyard Male Side	Preservation	: 10°C
Sample Description	: Water		

Parameters	Test Methods	Units	Results	Specification
Legionella	ISO 11731: 2017	CFU/ml	Not Detected	100CFU or MPN/ml

Note : Limit of Detection= \leq 10CFU/ml

Procedure: WSOP-MB-0051. Dilution, Heat Treatment, Acid Treatment followed by Plating on GVPC/MWY Agar.

Limit based on RSB Abu Dhabi Recycled water and biosolids regulation, 2018. Table A2 for Microbiological

Parameters.

Remarks :The tested result of the sample is found to be satisfactory within the specified limits.

Analyst	Reviewed By	Method Variation
HS	SM	None

Key Words :CFU-Colony Forming Unit; BS-British Standard; ISO-International Organization for Standardization.

Signed for and on behalf of Wimpey Laboratories

Dr. Suresh Murugan Ph.D.

Head of Microbiology Department



Test results relate only to the samples tested. This report shall not be reproduced except in full, without the written approval of the Laboratory. This is a LIMS software generated document with E Signature.

Form No: WARF-MB-03 Issue No.:01 Rev No:00 Issued Date:22-01-2020

- End of Text -