

TEST REPORT

REPORT NO:-QMTL/R-87912

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:Mr. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-87912
Reference: ETIHAD AIRWAYS ENGINEERING	Sampled By: Client Representative	Date Received: 09.01.2020
Sample Description: Main Utility, Sink Tap Sample Onsite Temp: 29°C Sample Receipt Temp: 26°C	Source: Tap	Date(s) Tested: 09.01.2020-11.01.2020
	Sample Container: 1x500 ml PB	Date Reported: 16.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 09.01.2020/01.30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	3
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-87913

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:Mr. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-87913
Reference: ETIHAD AIRWAYS ENGINEERING	Sampled By: Client Representative	Date Received: 09.01.2020
Sample Description: Aviation, Sink Tap Sample Onsite Temp: 27°C Sample Receipt Temp: 26°C	Source: Tap	Date(s) Tested: 09.01.2020-11.01.2020
	Sample Container: 1x500 ml PB	Date Reported: 16.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 09.01.2020/01.30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-87914

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:Mr. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-87914
Reference: ETIHAD AIRWAYS ENGINEERING	Sampled By: Client Representative	Date Received: 09.01.2020
Sample Description: Bay- 06, Sink Tap Sample Onsite Temp: 26°C Sample Receipt Temp: 26°C	Source: Tap	Date(s) Tested: 09.01.2020-11.01.2020
	Sample Container: 1x500 ml PB	Date Reported: 16.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 09.01.2020/01.30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-87915

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:Mr. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-87915
Reference: ETIHAD AIRWAYS ENGINEERING	Sampled By: Client Representative	Date Received: 09.01.2020
Sample Description: Hanger- 04, Sink Tap Sample Onsite Temp: 28°C Sample Receipt Temp: 26°C	Source: Tap	Date(s) Tested: 09.01.2020-11.01.2020
	Sample Container: 1x500 ml PB	Date Reported: 16.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 09.01.2020/01.30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	<1
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-87916

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN:Mr. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-87916
Reference: ETIHAD AIRWAYS ENGINEERING	Sampled By: Client Representative	Date Received: 09.01.2020
Sample Description: Hanger- 06, Sink Tap Sample Onsite Temp: 25°C Sample Receipt Temp: 26°C	Source: Tap	Date(s) Tested: 09.01.2020-11.01.2020
	Sample Container: 1x500 ml PB	Date Reported: 16.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 09.01.2020/01.30 PM
On-Site Treatment: NA	Tested by Emp#: 55 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS (APHA 23 RD EDITION)	UNITS	SPECIFICATIONS	RESULTS
MICROBIOLOGICAL ANALYSIS				
Total Bacterial Count	APHA 9215 B	CFU/ml	10@37°C	2
Total Coliforms	APHA 9222 B	CFU/100ml	Zero	Zero
Faecal coliform	APHA 9222 D	CFU/100ml	Zero	Zero
Pseudomonas aeruginosa	APHA 9213 E	CFU/100ml	Zero	Zero
Escherichia coli	APHA 9222 H & I	CFU/100ml	Zero	Zero

REMARKS:The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words:- CFU: Colony Forming Unit, APHA: American Public Health Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable

Report prepared by Emp#: 75

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-87917

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-87917
Reference: ETIHAD AIRWAYS ENGINEERING	Sampled By: Client Representative	Date Received: 09.01.2020
Sample Description: Main Utility, Sink Tap Sample Onsite Temp: 29°C Sample Receipt Temp: 26°C	Source: Tap	Date(s) Tested: 09.01.2020-19.01.2020
	Sample Container: 1x1 L PB	Date Reported: 23.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 09.01.2020/01.30 PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-87918

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-87918
Reference: ETIHAD AIRWAYS ENGINEERING	Sampled By: Client Representative	Date Received: 09.01.2020
Sample Description: Aviation, Sink Tap Sample Onsite Temp: 27°C Sample Receipt Temp: 26°C	Source: Tap	Date(s) Tested: 09.01.2020-19.01.2020
	Sample Container: 1x1 L PB	Date Reported: 23.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 09.01.2020/01.30 PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-87919

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-87919
Reference: ETIHAD AIRWAYS ENGINEERING	Sampled By: Client Representative	Date Received: 09.01.2020
Sample Description: Bay- 06, Sink Tap Sample Onsite Temp: 26°C Sample Receipt Temp: 26°C	Source: Tap	Date(s) Tested: 09.01.2020-19.01.2020
	Sample Container: 1x1 L PB	Date Reported: 23.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 09.01.2020/01.30 PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pnueumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pnueumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-87920

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-87920
Reference: ETIHAD AIRWAYS ENGINEERING	Sampled By: Client Representative	Date Received: 09.01.2020
Sample Description: Hanger- 04, Sink Tap Sample Onsite Temp: 28°C Sample Receipt Temp: 26°C	Source: Tap	Date(s) Tested: 09.01.2020-19.01.2020
	Sample Container: 1x1 L PB	Date Reported: 23.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 09.01.2020/01.30 PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT

TEST REPORT

REPORT NO:-QMTL/R-87921

CLIENT:- CRYSTALLINE ENVIRONMENTAL SERVICES		
P.O.Box.131463, Abu Dhabi, U.A.E		
Ph:02-6508930/0557167017		
ATTN: Mr. JASMAN PINTO		
Product: Water	Sampling Method: NA	Sample ID: QMTL/S-87921
Reference: ETIHAD AIRWAYS ENGINEERING	Sampled By: Client Representative	Date Received: 09.01.2020
Sample Description: Hanger- 06, Sink Tap Sample Onsite Temp: 25°C Sample Receipt Temp: 26°C	Source: Tap	Date(s) Tested: 09.01.2020-19.01.2020
	Sample Container: 1x1 L PB	Date Reported: 23.01.2020
	Sample Appearance: Clear	Date of Sampling/Time: 09.01.2020/01.30 PM
On-Site Treatment: NA	Tested by Emp#: 74 & 78	Location: AUH

TEST RESULTS

PARAMETERS	TEST METHODS	UNITS	LIMITS	RESULTS
LEGIONELLA ANALYSIS				
Legionella	CCFRA 3.9.1 (5 th Edition)	cfu/litre	<1	Not Detected
IDENTIFICATION				
Legionella Species	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 1	CCFRA 3.9.1 (5 th Edition)	-	-	Absent
Legionella pneumophila sero group 2-15	CCFRA 3.9.1 (5 th Edition)	-	-	Absent

REMARKS: The sample meets RSB Water Quality Regulations (4th Edition) January 2014 requirements for potable water with respect to the above tests only.

Key Words: CFU: Colony Forming Unit, CCFRA: Campden & Chorleywood Food Research Association, RSB: Regulation & Supervision Bureau, NA: Not Applicable.

Report prepared by Emp#: 61

Test Method deviation : None

The above test results are only applicable to the sample(s) referred above

Reported By

ANILA GEORGE
LABORATORY MANAGER



The test Report shall not be reproduced (except in full) without the written approval of QMTL. When analysis is witnessed by us or carried out by sub contract labs, our responsibility is only to ensure that the analysis is conducted to standard test methods in accordance with industry accepted practice.

END OF REPORT