

SWIMMING POOL - WATER ANALYSIS REPORT

Client Name: INAYA FACILITIES MANAGEMENT SERVICES LLC			
Site Name:	SEA SIDE	Visit Date:	30-01-2020
Sampled By:	Crystalline Rep.	Sample Point	Main Swimming Pool
Source of Sample	Swimming Pool		

TEST RESULT

No	Parameter	Control limits	Test Results
1	pH at 25°C	7.2 - 7.6	7.58
2	Conductivity at 25°C, µs/cm	---	681
3	TDS, ppm	Max 1500	443
4	Alkalinity	80 - 120	96
5	Calcium Hardness	200 - 500	214
6	Residual Chlorine	1.0 - 3.0	1.05
7	Cyanuric Acid	20 - 60	23
8	Dip slide	<10 ³	ND

*** All test results expressed in parts per million (ppm) as CaCO₃ except pH and conductivity (µmhos).

COMMENTS AND RECOMMENDATIONS

- All Parameters are within control limit only - No action recommended.

Reported By,

P. Murugaraj
Murugaraj
Service Engineer

